

# Structural and Nonstructural Earthquake Design: The Challenge of Integrating Specialty Areas in Designing Complex, Critical Facilities

by  
William J. Petak and Daniel J. Alesch



Technical Report MCEER-08-0014

April 30, 2008

## NOTICE

This report was prepared by the University of Southern California and the University of Wisconsin-Green Bay as a result of research sponsored by MCEER through a grant from the Earthquake Engineering Research Centers Program of the National Science Foundation under NSF award number EEC-9701471 and other sponsors. Neither MCEER, associates of MCEER, its sponsors, the University of Southern California, the University of Wisconsin-Green Bay, nor any person acting on their behalf:

- a. makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe upon privately owned rights; or
- b. assumes any liabilities of whatsoever kind with respect to the use of, or the damage resulting from the use of, any information, apparatus, method, or process disclosed in this report.

Any opinions, findings, and conclusions or recommendations expressed in this publication are those of the author(s) and do not necessarily reflect the views of MCEER, the National Science Foundation, or other sponsors.

**Structural and Nonstructural Earthquake Design:  
The Challenge of Integrating Specialty Areas in  
Designing Complex, Critical Facilities**

by

William J. Petak<sup>1</sup> and Daniel J. Alesch<sup>2</sup>

Publication Date: April 30, 2008

Submittal Date: December 4, 2007

Technical Report MCEER-08-0014

Task Number 10.2.5

NSF Master Contract Number EEC 9701471

- 1 Emeritus Professor, School of Public Policy, Planning and Development, University of Southern California
- 2 Emeritus Professor, Department of Public and Environmental Affairs, University of Wisconsin - Green Bay

MCEER

University at Buffalo, State University of New York

Red Jacket Quadrangle, Buffalo, NY 14261

Phone: (716) 645-3391; Fax (716) 645-3399

E-mail: [mceer@buffalo.edu](mailto:mceer@buffalo.edu); WWW Site: <http://mceer.buffalo.edu>

---

## **NTIS DISCLAIMER**

- ❖ This document has been reproduced from the best copy furnished by the sponsoring agency.


## Preface

The Multidisciplinary Center for Earthquake Engineering Research (MCEER) is a national center of excellence in advanced technology applications that is dedicated to the reduction of earthquake losses nationwide. Headquartered at the University at Buffalo, State University of New York, the Center was originally established by the National Science Foundation in 1986, as the National Center for Earthquake Engineering Research (NCEER).

Comprising a consortium of researchers from numerous disciplines and institutions throughout the United States, the Center's mission is to reduce earthquake losses through research and the application of advanced technologies that improve engineering, pre-earthquake planning and post-earthquake recovery strategies. Toward this end, the Center coordinates a nationwide program of multidisciplinary team research, education and outreach activities.

MCEER's research is conducted under the sponsorship of two major federal agencies: the National Science Foundation (NSF) and the Federal Highway Administration (FHWA), and the State of New York. Significant support is derived from the Federal Emergency Management Agency (FEMA), other state governments, academic institutions, foreign governments and private industry.

MCEER's NSF-sponsored research objectives are twofold: to increase resilience by developing seismic evaluation and rehabilitation strategies for the post-disaster facilities and systems (hospitals, electrical and water lifelines, and bridges and highways) that society expects to be operational following an earthquake; and to further enhance resilience by developing improved emergency management capabilities to ensure an effective response and recovery following the earthquake (see the figure below).



A cross-program activity focuses on the establishment of an effective experimental and analytical network to facilitate the exchange of information between researchers located in various institutions across the country. These are complemented by, and integrated with, other MCEER activities in education, outreach, technology transfer, and industry partnerships.

*This report explores the challenges faced by engineers and architects to integrate structural and nonstructural elements in the design of earthquake resistant buildings. The authors review the traditional roles and responsibilities of various participants in constructing a modern building, and explore impediments to incorporating nonstructural design into engineering practice. Several possible solutions are proposed, including the creation of a new profession called a “master builder” who would serve as a building systems integrator. However, there is currently no academic program to train this type of professional. Legislation such as California’s SB 1953, which brought the problems associated with integrating architecture, structural engineering, and the design and installation of nonstructural components of acute care hospitals into sharp focus, may provide some incentive to academic institutions to broaden current curriculums to be more in line with the needs of professional practice in this area.*

## ABSTRACT

Structural and nonstructural engineering and design often proceed independently of one another, even for complex structures intended for specialized use. This practice may have developed historically from the development of specialties within the architecture and engineering design industry, but the separation of structural and nonstructural engineering and design has become dysfunctional, particularly for critical, specialized facilities subject to the forces of an earthquake.

Buildings intended for complex, specialized use should no longer be conceptualized or designed apart from their intended operating environment, functions, and contents except at one's peril; neither structural nor nonstructural engineering and design should proceed apart from the other. Buildings are complex systems in which the performance of structural and nonstructural systems and components must be integrated with one another. The many components cannot be designed, installed, or operated in isolation from the rest of the building. The complexity of contemporary and anticipated technologies employed in creating integrated facilities increasingly demands more complete integration from concept to end use.

The issue is not a matter of a need for improved engineering knowledge: the need is for integrating structural and nonstructural system design. However, recognition is only the first step in bringing about better integration. Disciplinary practices, contracting procedures, and education programs must change to create a culture that demands improved system performance through better integration and practice.





## **ACKNOWLEDGMENTS**

This report was prepared under the auspices of the Multidisciplinary Center for Earthquake Engineering Research through a grant from the National Science Foundation Earthquake Engineering Research Centers Program. Opinions, findings, conclusions, or recommendations expressed in this publication do not necessarily reflect the view of the sponsors or the Research Foundation of the State University of New York.

The authors gratefully express their sincere appreciation to the many professional structural engineers, architects, and others who willingly shared their views of the difficulties associated with integrating structural and nonstructural engineering to enhance seismic safety.



## TABLE OF CONTENTS

SECTION	TITLE	PAGE
<b>1</b>	<b>THE PROBLEM.....</b>	<b>1</b>
<b>2</b>	<b>WHY IS IT THAT THE STRUCTURAL AND NONSTRUCTURAL SEISMIC DESIGN OF BUILDINGS IS NOT INTEGRATED ADEQUATELY? .....</b>	<b>9</b>
2.1	Traditional Roles and Responsibilities and the Increased Complexity of Buildings.....	9
2.2.	Economic Pressures in the Design and Construction Process .....	10
2.3	Traditional Roles Cloud Responsibility.....	10
2.4	Other Practical Concerns .....	13
<b>3</b>	<b>CONCLUSIONS FROM OUR RESEARCH.....</b>	<b>17</b>
3.1	Reframing the Problem.....	20
3.2	Pressure on Traditional Approaches and Processes.....	22
<b>4</b>	<b>NEW APPROACHES CHALLENGE THE TRADITIONAL PROCESS .....</b>	<b>25</b>
4.1	Systems Perspective and Performance Based Earthquake Engineering.....	25
4.2	Design Build Contracting — the Master Builder Concept.....	27
4.3	Systems Integration Tools and Approaches.....	28
<b>5</b>	<b>WHAT NEEDS TO BE DONE? .....</b>	<b>31</b>
<b>6</b>	<b>REFERENCES AND CITED MATERIALS.....</b>	<b>33</b>



## **SECTION 1**

### **THE PROBLEM**

It has become increasingly clear in meeting the demands of an earthquake environment that architectural design, structural engineering, and the design for installation of nonstructural elements in buildings cannot proceed independently from one another. Each of those activities has clear implications for the others, as well as for the overall resilience of the building system. For example, initial conceptual design decisions on a building project can do much to determine its ultimate seismic performance. Architectural decisions early in the design period may commit a project to a building configuration or design concept that makes effective lateral-force resistance difficult to achieve. Accordingly, close collaboration from the outset between the architect and structural engineer is understood to be highly desirable and, to a considerable extent, has become practice within the United States. Unfortunately, this has not been the case with the design and installation of nonstructural elements. Even though it is important to do so, there is often a lack of design integration of the structural engineering and the engineering of nonstructural elements. Design integration is important, because some techniques for installing nonstructural components can actually diminish structural integrity, while at the same time, structural engineers can create unnecessary problems for those charged with the engineering design of nonstructural components. And, as buildings become increasingly complex, integrating architectural design, structural engineering, and the design of mechanical, electrical, plumbing, and other nonstructural systems becomes increasingly important if a building is to perform as expected when subjected to seismic forces.

When building in areas subject to earthquakes, one must be concerned with the safety of persons both within the building and in its immediate environment, as well as the likelihood that the building will continue to provide for the performance of its functions following the earthquake. Functionality of buildings subjected to the extraordinary forces of earthquakes depends on not only how the structure itself performs, but also depends on how the nonstructural components of the building perform. Enormous progress has been made in structural engineering design in recent decades to enhance the resiliency of building structures to the forces

of earthquakes. These advances mean that building structures designed with today's engineering knowledge and standards are much more likely to survive modest and moderate seismic forces than buildings built only a few decades ago. However, requiring that a complex building system, such as a hospital, continue to support its pre-event functions immediately following an earthquake is a demanding standard. Functionality is highly dependent upon the performance of all systems and subsystems, in particular both the building structural system and the nonstructural elements and equipment installed in the building. The California legislation requiring retrofit of all hospitals built before 1973 (SB 1953) requires improvements in the functionality and performance of both structural and nonstructural elements of these older buildings.

Failure of nonstructural components of buildings in earthquakes can result in considerable deaths, injuries, and loss to building contents. Whittaker and Soong (2003) emphasize that nonstructural elements of buildings "are subjected to the building dynamic environment caused by, for example, an earthquake. Typical examples of nonstructural components include architectural partitions, piping systems, ceilings, building contents, mechanical and electrical equipment, and exterior cladding."

The importance of nonstructural component issues in seismic design and performance evaluation is now well recognized by researchers as well as practicing engineers. The subject received special attention after the San Fernando earthquake in 1971 when it became clear that damage to nonstructural components not only can result in major economic loss, but also can pose real threat to life safety. For example, an evaluation of various Veterans Administration hospitals following the San Fernando earthquake revealed that many facilities still structurally intact were no longer functional because of loss of essential equipment and supplies (Whittaker, A. S., and T. T. Soong, 2003).

Also following the 1971 earthquake in San Fernando, California, the U. S. Veterans Administration recognized the need to understand buildings as complex systems when they developed the guidelines for design of hospitals. In their guidelines they state: "There is nothing new about the notion that a building is a collection of systems: a structural system, a mechanical system, an electrical system, and so on." The report goes on to state that "Of particular interest is how the characteristics of each component directly or indirectly affect the performance of the

others and of the total building” (Joint Venture of Building Systems Development and Stone, Marraccini and Patterson, 1977).

Consequently, economic loss due to seismic nonstructural damage can also be considerable. A case in point is the seismic damage sustained by buildings during the 1994 Northridge earthquake. With the loss of approximately \$18.5 billion due to building damage, nonstructural damage accounted for about 50% of this total (Kircher, 2003).

Concern over the role of nonstructural systems and components in earthquake safety had existed for some time and the question of how to integrate the design of structural and nonstructural components of buildings to enhance seismic safety had been simmering in the background for some time. As noted above, it was brought to focus in California as State officials sought to implement the law known as SB 1953, the California statute that established performance goals and objectives for all acute care hospital buildings constructed prior to 1973.

SB 1953 states that retrofitted hospital buildings and newly designed and constructed acute care hospital buildings are to ensure prevention of structural collapse (life safety) as a minimum condition for functionality, and nonstructural elements and systems are to continue to function when subjected to earthquake forces in the building. This public policy requires appropriate attention be given to ensuring responsible structural and nonstructural design.

Prior to 1988, the Uniform Building Code (UBC) applied to all new construction in California. The code, however, did not provide adequate guidance on the seismic design requirements for nonstructural elements. The code simply required that nonstructural elements be designed in accordance with national design standards and did not establish specific design requirements for seismic environments. The California Office of the State Architect, responsible for regulating school building and hospital design in California, employed UBC standards. In about 1980 the Office of the State Architect did try to add nonstructural seismic design requirements for schools and hospitals in earthquake environments, but the effort did not come to fruition.

The 1988 UBC included a beginning framework in which a conscientious structural engineer could address nonstructural seismic requirements by requiring that seismic design

considerations be applied to nonstructural elements and systems. Work by the Building Seismic Safety Council (BSSC), a not-for-profit organization established by the National Institute of Building Sciences (NIBS), on how to promote building earthquake risk mitigation led to more detailed code requirements which were incorporated into the first edition of the International Building Code (IBC) in 2000.

In 2004, the Federal Emergency Management Agency (FEMA) recognizing the importance of both structural and nonstructural elements as critical to the performance of a building system stated:

Seismic considerations should apply to every building system, subsystem, and component, and the performance of each component or system is often interdependent. The traditional organization of the design team and the assignment of responsibilities to the architect, structural engineer, MEP (mechanical, electrical, and plumbing) consultants, and other specialty consultants (e.g., geotechnical engineer, curtain wall consultant, elevator consultant, or security consultant) is critically important to address cross-cutting seismic design issues or problems.” (FEMA, 2004)

As the servicing needs of contemporary buildings continue to increase, the impact of the MEP (mechanical, electrical, and plumbing systems) consultant’s work on seismic design becomes increasingly important. An example of this is the need for penetrations or blockouts in the structure to accommodate ductwork, piping, and equipment, which requires early design consideration. These penetrations are fundamental to the integration of the structural and mechanical system, and their size and location should be carefully worked out between the architect, structural, and mechanical engineers. There are many instance of damage to buildings in earthquakes caused by structural member penetrations that have not been adequately coordinated with the structural design (FEMA, 2004).

As noted, FEMA emphasized the need for the seismic design process to include every building system, subsystem, and component in enhancing seismic safety. It is important to note that seismic design for every nonstructural building system, subsystem, and component is not a straight forward matter of pointing to a building code as the solution to the problem. Nonstructural building systems, subsystems, and components can be classified into at least three general categories, each requiring special seismic design knowledge and skills:



1. Design of anchorage and bracing for “off-the-shelf” fabricated systems (e.g., HVAC),
2. Design of internally constructed support systems or subsystems (e.g., fire suppression systems) each designed to meet specific performance requirements, and
3. Manufactured systems, subsystems and components that must meet seismic performance qualification requirements.

In addition to the three general categories of nonstructural systems, subsystems and components, each building will contain many pieces of specialized equipment not physically attached to the building structure, but critical to the building’s functionality following an earthquake. The 2006 International Building Code is the most current code enforced through out the United States. The International Building Code references the design guideline document, Minimum Design Loads for Buildings and Other Structures, prepared by the American Society of Civil Engineers (ASCE 7-05).

ASCE 7-05 contains specific requirements for nonstructural components in essential facilities so that these components would maintain their function following design earthquake level events. In the past, the design of nonstructural components focused only on the design of anchorage and bracing. This is no longer the case. The ASCE 7-05 seismic provisions include seismic qualification requirements for critical active mechanical and electrical equipment by shake table testing or experience data. In addition, non-critical equipment is also permitted to satisfy seismic design requirements by testing or experience rather than by prescriptive requirements (this is referred to as alternate means). A shake table testing protocol (AC-156) has also been developed that is consistent with the ASCE 7-05 seismic provisions and many equipment suppliers are now in the process of qualifying their equipment to satisfy it. The combination of specific code requirements and alternate mean requirements and the existence of a standard acceptable test protocol has greatly increased the interest of suppliers in seismic testing of their products. (Bachman, 2007)

Effective January 1, 2008 the California Building Standards Board adopted the IBC as the governing code for California meaning the IBC is the model code for use in California.

Following legislative enactment of SB 1953, the California Office of Statewide Health Planning and Development (OSHPD) established retrofit regulations required for

implementation of the law. The regulations were to be based upon accepted, consensus-based standards for both structural and nonstructural design. OSHPD relied on guidelines published by the Federal Emergency Management Agency (FEMA). OSHPD's requirement that nonstructural performance be considered when retrofitting pre-1973 acute care hospital buildings was a major step leading to the requirement for integrating the seismic design of structural and nonstructural components in buildings. The same requirements are *currently required* on new hospital construction in California, with the State adoption of the IBC.

To ensure proper interpretation of the American Society of Civil Engineers ASCE 7-05, California's OSHPD has initiated a Code Application Notice which states that beginning 2008

every structure, and portion thereof, including nonstructural components that are permanently attached to structures and their supports and attachments, shall be designed and constructed to resist the effects of earthquake motions in accordance with ASCE 7. Editions of the California Building Code prior to 2007, based on the Uniform Building Code, had a direct correlation between the nonstructural component importance factor and building occupancy categories for essential facilities. The 2007 California Building Code, which is based on the 2006 International Building Code, refers to ASCE 7-05 for the component importance factor. All nonstructural components for OSHPD 1 facilities shall have an importance factor of 1.5, except when a justification by the architect or engineer of record in general responsible charge demonstrates that their failure will not impair the continued operation of the facility and which is accepted by OSHPD. Item 3, Section 13.1.3, ASCE 7-05 provides for flexibility in using a component importance factor lower than 1.5 for essential facilities provided that the component is not needed for continued operation or the component failure will not impair the continued operation of the OSHPD hospital facility. This Code Application Notice provides general guidelines for determining the component importance factor. (OSHPD, 2007)

Particularly in California, the question of who should be responsible for integrating structural and nonstructural seismic design has generated much discussion and confusion. The prospect for a simple, timely resolution of the issue seems unlikely. Structural engineers appear to be in general agreement that nonstructural elements are a key to building functionality following an earthquake. However, most of them seem to believe that structural engineering and nonstructural engineering are separate design tasks and the integration of structural and nonstructural design should not be viewed as the inherent responsibility of the structural

engineer. Despite the general perception of structural engineers, the State of California requirements set forth in the 2001 California Building Standards Administrative Code (Part 1, Title 24), also referred to as the California Building Code, sets forth specific duties and responsibilities governing the design of buildings requiring all engineering and analysis to be detailed on the building drawings governing the design and installation of nonstructural systems and components. Specifically, Code Section 4-217 (a) states that “The architect or registered engineer is responsible to the owner and to the enforcement agency to see that the completed work conforms in *every material respect* (emphasis added) to these regulations and the approved plans and specifications.” Code Section 4-217 (b) specifies that the project’s “architect or registered engineer shall prepare the plans, specifications, design computations and other data and shall prepare documents authorizing changes in the approved drawings and specifications when so directed by the owner or as required by *conditions on the project* (emphasis added).” (State of California, 2001)

With regard to nonstructural design, Code Section 4-218 states that “The architect, structural engineer or civil engineer in general responsible charge *retains overall responsibility* (emphasis added) for the mechanical and electrical portions of the work when the design responsibility for that work has been delegated and the plans have been prepared by registered mechanical and electrical engineers.” (State of California, 2001)

Therefore, the architect or registered engineer, defined here as the building designer, has the responsibility for both the structural and nonstructural seismic design for buildings and ensuring that the completed work conforms to the State’s codes and standards. The responsibility for nonstructural seismic design may not be explicitly considered a part of the contract for structural engineering work. In practice, the nonstructural engineering design work is generally done by a subcontractor who should have a sign-off by a registered engineer licensed in California. Typically, the structural engineer does not have control over the design of nonstructural elements and, unless the structural engineer directly supervised the nonstructural design work, the engineer is not able to sign and stamp a design drawing for nonstructural work. In practice, the structural engineer only “accepts” the nonstructural design work and puts a shop drawing stamp on the design drawings noting work done by the subcontractor. Problems arise when the nonstructural subcontractor (designer) follows national standards for installation of

nonstructural systems and components and includes the standard design details on how to brace or mount nonstructural elements that are spread throughout the building design drawings. Given the current understanding of a building as a complex system and the need for integration of structural engineering design and the design of nonstructural building components, and the evidence of significant shortcomings in integrating those activities, two questions come to mind. First, why is it that these important elements of building design are not more closely integrated? Second, what might be done to help ensure the integration and coordination of structural design and the design and implementation of nonstructural building components?

## SECTION 2

### WHY IS IT THAT THE STRUCTURAL AND NONSTRUCTURAL SEISMIC DESIGN OF BUILDINGS IS NOT INTEGRATED ADEQUATELY?

#### 2.1 Traditional Roles and Responsibilities and the Increased Complexity of Buildings

Over the past decades, building codes and requirements governing seismic design of buildings has become increasingly complicated resulting in design professionals becoming increasingly specialized, with each group focusing on a particular aspect of the building. As buildings became more specialized to house specific, often critical activities, the array of engineering professionals increased, with each becoming an important actor in the process. Historically, all this took place under the direction of an on-site architect. It is not uncommon to see many participants involved in the process, sometimes tripping over one another in an attempt to finish his or her part of the design of a building. Each seems to be busy sub-optimizing the process to his or her benefit without examining his or her contribution to the performance of the building system as a whole.

Increasing building complexity and the number and variety of subsystems that comprise them increasing substantially has made the process of integrating the seismic design of all those subsystems difficult, time-consuming, and, often, expensive. The demands of integration seem to have grown beyond the capability of traditional engineering professional roles and responsibilities, demanding new approaches. Further, it is frequently argued that large and complex buildings are each “one of a kind”, each designed and built and not necessarily replicated. Mass-produced products are integrated in engineering departments to keep assembly lines moving and the operation profitable. It is extremely time-consuming and costly to integrate all of the subsystem interfaces down to the last detail in a large, one of a kind building.

## **2.2. Economic Pressures in the Design and Construction Process**

The ideal is not always realized, often because of the exigencies of cost and the desire to maintain or enhance profit margins. In its 1991 report the California Seismic Safety Commission (SSC) recognized the problem. The Commission states that one “consideration arises from economic pressures in the design and construction process. In California this is a particular cause for concern, because of possible effects on the seismic resistance of structures.”

It needs to be more widely understood by owners that simply complying with minimum requirements of the Uniform Building Code may not result in an appropriate seismic design for all situations. Careful attention by qualified and experienced practitioners having a broad knowledge of seismic design is also essential . . . Economic constraints on design and construction practices may result in structures that comply with codes but are nevertheless susceptible to significant damage. They may cause many severe casualties when an earthquake occurs. Even if no lives are lost, poorly performing buildings and their contents can suffer major damage, which can be devastating to occupants, e.g., tenants or businesses forced to vacate or suspend operations.

In the prevailing circumstances, the fees public and private owners appear willing to pay for architectural engineering work are often insufficient to provide the levels of professional service needed for adequate attention to seismic resistance. Consequently, at the outset the buyer or owner should understand the relationship between design and construction costs, and the levels of quality control and building reliability being purchased with the fees budgeted.

While improving building performance is likely to mean some increase in construction and design costs, these added expenses may not be significantly more than those of a structure built to minimal seismic standards. Furthermore, typical kinds of earthquake damage are controllable for very little added expense. In short, owners’ decisions to go for the lowest fee in design contract negotiations may save little at the beginning, while proving very costly later in the event of a damaging earthquake (California Seismic Safety Commission, 1991).

## **2.3 Traditional Roles Cloud Responsibility**

Four major stakeholders involved in the traditional building design process seem likely candidates as the participants who should be responsible for ensuring that the integration of structural and nonstructural elements to enhance seismic safety. These are the building owner,

the architect, the structural engineer, and the set of contractors and subcontractors designing nonstructural components.

Ultimately, the person or organization contracting to have the structure designed and built might be considered the primary responsible party for ensuring seismic design integration of all the building components. Some owners build many buildings and are or should be experienced in ensuring integration. For others, however, contracting to have a building built is a one-time experience. They assume that those they hire to design and build the structure will ensure that the designs are appropriately integrated so as to achieve a building with seismic design integrity necessary to meet the requirements of all the applicable codes and meet the desired seismic performance requirements.

For some owners, cost is the primary consideration, but those who contract to have buildings built are not uniformly motivated by a single interest. Almost all have an interest in the final cost per square foot of building space, but not all building owners trade off cost per square foot equally against other features of the building. Some owners value safety, aesthetics, long economic life, system resilience, or other features more highly than others and, as a result, will accept an increase in cost per square foot to obtain a safer building, a more aesthetically appealing building, or to obtain more of some other valued feature. Only rarely, however, is a building owner prepared to spend more money per square foot without some assurance that the extra cost buys him or her something. Consequently, there is pressure to keep costs under control and most owners, while they will do whatever is required by code, are unlikely, on their own accord, to decide they ought to go beyond code requirements to ensure a higher level of seismic safety. Many may simply assume that the government codes embody the most current knowledge and best reasonable standards.

According to the 2001 California Building Code, seismic design is to be the responsibility of the building designer with responsibility for both the structural and nonstructural design for buildings and ensuring that the completed work conforms to the appropriate codes and standards and that overall building design is in accordance with the state's statutes and regulations governing the professional registration and certification of architects or engineers. However, it does not appear that this requirement has led to adequate oversight of

nonstructural seismic design. In practice, new building construction is generally under the direction and oversight of a project architect who is responsible for project management. Some would argue that the project architect should be responsible for ensuring that the overall design concept, structural engineering, and nonstructural engineering are fully integrated.

Architects, however, are rarely engineers. Typically, the architect is awarded a contract owner after which he or she contracts with a structural engineering firm to provide the design of the building's structure capable of withstanding some specified level of shaking and ground motion. Sometimes the structural engineer is designated as being responsible for ensuring that the seismic design for the nonstructural elements and systems within the building is appropriate for the design seismic environment. Rarely, however, are structural engineers experienced in specifying appropriate seismic design and installation of plumbing, heating, venting, electrical, and a half a dozen other nonstructural specialties. Further, when others design such subsystems, the work is generally not done under the supervision of a structural engineer and, consequently, the structural engineer is unable to certify to the adequacy of work and is unable to apply his or her professional engineer license stamp to certify that the design meets all appropriate codes and standards.

Structural engineers we interviewed indicated that they are often expected to take on responsibility for nonstructural engineering without sufficient or additional fee. Moreover, some structural engineers with whom we spoke indicated that they do not want to work on nonstructural seismic design problems. They want to work in their area of specialty—earthquake structural design—which they consider to be more challenging and interesting. A change in perception would presumably alleviate the situation, but such a change would require significant changes in emphasis in formal education and in peer expectations and reinforcement.

The engineers we interviewed generally believe that the project architect should be responsible for ensuring that the nonstructural components in the building design meet all required seismic design standards. They agree with the position taken by the Seismic Safety Commission in its 1991 report:



As prime design professionals, architects have a unique role in design and construction. The architect is often the only professional with an overall view of all aspects of the design and construction process. The architect serves the client, brings in the structural engineer and other engineering specialties, works closely with the contractor, and ideally, orchestrates the project to facilitate performance and achieve good results. Architects are therefore in a crucial position to influence the seismic safety of structures (Seismic Safety Commission, 1991).

Specifically, nonstructural engineering contractors should be held accountable for ensuring the adequacy of the seismic design of their specialty systems and components. After all, trade associations have defined standards for both design and installation of those systems and components. However, since only a few parts of the United States experience frequent earthquakes, national standards rarely address the special design requirements necessary to meet earthquake ground motions expected in those areas. Moreover, because a myriad of plumbing, electrical, heating, venting, air conditioning and other subsystems must be integrated within the structure, it may be unreasonable to assume that, without some overall experienced project management, all of those parts will perform properly in an earthquake environment without at least some of those installations resulting in dysfunctional consequences for others. Consequently, it appears that someone will have to be in charge with the task of ensuring adequate building system resilience in earthquake zones.

The challenge seems to be that none of the present actors in the complex building design and construction process seems to be in a particularly good position or adequately trained or compensated to take responsibility for ensuring that the building is conceptualized, designed, and built to be a complex, functioning and resilient system.

## **2.4 Other Practical Concerns**

**Fee structure.** Who should pay for nonstructural engineering design? Obviously, the building owner will bear the ultimate cost burden, but once fees have been negotiated, disputes about which professional group should bear the cost for nonstructural design and integration begins. Some structural engineers consider nonstructural design as a part of their responsibility, but, most nonstructural work is viewed by structural engineers as an add-on to structural work

without sufficient compensation. When required to do nonstructural engineering design, those we interviewed indicated that the work was often passed off to the junior engineering staff.

**Concerns About Liability.** A large gray zone exists in terms of responsibility. Is the electrical engineer responsible for the installation of electrical equipment? Is the mechanical engineer responsible for the installation and performance of mechanical equipment? Many are not experienced in design for a seismic environment and buy off the shelf equipment. Further, equipment manufacturers have generally shown little interest in voluntarily accommodating special nonstructural seismic design requirements. Structural engineers fear they may be held responsible if they design or change the mounting or attachments of nonstructural elements in an attempt to increase seismic performance if those elements fail in an earthquake. No one in the design and construction process is interested in taking on added liability.

As noted above, the seismic code requirements for seismic design for nonstructural components has been focused only on the design of anchorage and bracing. This led to concerns that the design engineer could be required to take on liability for nonstructural system performance beyond the requirement for anchorage and bracing, especially if building system functionality is the standard of performance. This concern may now be somewhat alleviated with the adoption of the IBC. The new IBC (with ASCE 7-05 by reference) provides for seismic performance qualification by the manufacturer of critical active mechanical and electrical equipment through shake table testing or with experience data.

**Codes.** Although nonstructural seismic requirements have been in building codes since the 1970's, with nonstructural performance expectations as part of the published code, specific performance objectives have been poorly defined. Generally the requirements have applied to components and systems representing only a small risk to life safety. Code design rules for the design earthquake imply that a) anchored components will where anchored, b) important "designated systems" will stay operational, and c) components subject to drift will experience only minimal damage. Previous codes did not make reference to performance objectives aimed at continuing functionality and minimizing economic losses. Since codes have not addressed the issue of nonstructural system seismic design and performance adequately, there is little basis for regulatory enforcement. It is expected that with nonstructural design requirements being added

to the 2006 International Building Code, there will be a basis for oversight of both structural and nonstructural design for new building projects.

**Business and Professions Codes.** Licensing establishes codes of conduct for various professions, establishing a basis for professional conduct and responsibility when doing work for which a license is required (e.g., a structural engineer is not permitted to certify a nonstructural design unless the structural engineer has directly supervised the work). This would seem to suggest that the professional engineers should work together with the architect as the “Building Designer” to make sure that design criteria developed by the structural engineer are used by the other professional engineers in their designs.



### **SECTION 3**

#### **CONCLUSIONS FROM OUR RESEARCH**

All buildings, especially hospital buildings and other critical facilities, are dependent upon the earthquake resistance of both structural and nonstructural elements and systems if they are to remain capable of performing their primary functions following an earthquake. Research following California earthquakes indicates that the risk of failure or significant damage of nonstructural elements and systems is higher than the risk of structural collapse during moderate earthquakes.

For many reasons, structural engineers do not appear to be particularly interested in and pay little attention to earthquake design of nonstructural elements and systems. The vulnerability (risk of failure) of nonstructural elements and systems is directly connected to the structural design performance of a building. That is, how a structural engineer approaches the challenge of designing a structure to withstand earthquake forces has direct implications for the design of the buildings nonstructural systems and components. For example, changes due to design in the dynamic response of the main structural frame of a building to earthquake caused ground shaking and acceleration may result in significant increased floor acceleration and, consequently, heavy loads placed on nonstructural elements.

It is clear that the professions involved in creating buildings have not fully resolved the issues associated with integrating building design, structural engineering, and nonstructural engineering and installation. It is equally clear that ensuring appropriate performance of both structural and nonstructural components essential for enhancing seismic safety and post-event functionality of critical facilities continues as a major challenge for the building profession.

Structural engineers with whom we spoke in the course of our research suggested several approaches to dealing with the need for greater integration of structural and nonstructural design.

One recurring suggestion is that those who administer the design and construction process should have responsibility for ensuring that nonstructural design meets the building performance requirements of the owner. It was stated that a new ‘discipline’ may be necessary

within the building profession to oversee the certification of equipment and then assure that equipment and systems (including but not limited to supports, anchorage and bracing) are designed, reviewed, and constructed in a manner that provides the required level of system reliability in meeting the demands caused by the design earthquake. Some suggested that the person to do this might be a structural engineer, provided he or she is compensated for the responsibility. Others suggested that it might be done by an architect who is sufficiently trained in that role. Others suggested that what the profession needs is a system integrator, a professional who has sufficient knowledge, skills and attributes to lead a group of individual professionals in achieving system level performance from a building when subjected to a seismic environment. All of our respondents agreed that people who can perform such a task are in short supply at this time.

Following that line of thinking, several respondents voiced the opinion that a new profession or discipline is needed for system integration. One called for the creation of a senior consultant position to cover “System Integration.” Others opined that creating a new professional will require the development of a position description detailing roles, responsibilities, and skill sets. Most agreed that there exists a need for a change in the culture of the design and build industry for buildings in earthquake country.

It was suggested by another person we interviewed that we examine university programs in Architectural Engineering. Architectural Engineering programs are designed to prepare students for professional work in the design and construction of buildings. Students focus on design principles and practice to gain a basic understanding of building systems by studying the technical and economic aspects of design and construction of buildings. Many programs make use of CAD systems. A web based survey revealed that approximately 18 – 20 universities in the USA have degree programs under the heading Architectural Engineering. Within California, only one university identifies a program in Architectural Engineering with its program focused on the structural engineering of buildings. Of those listed, the Pennsylvania State University, School of Engineering provides a program description that would appear to lead to development of the type of professional referred to above. Following is an excerpt from the Pennsylvania State University web site.

Architectural Engineering is the application of scientific and engineering principles to the design and construction of buildings and building systems, including topics from various disciplines, including architecture, structural engineering, mechanical engineering and electrical engineering. The program emphasizes the engineering aspects of the building design and construction process, while an architecture program concentrates on the aesthetics and the functional/ spatial layout of buildings. Contemporary buildings are designed by teams of professionals. These teams include designers with distinct responsibilities and expertise. Architects, engineers and other specialists work together to turn ideas into reality.

Architectural Engineering refers to the collective efforts of many engineering disciplines which are necessary to turn the architect's building concepts into reality. These disciplines include structural, building mechanical, electrical, lighting, fire protection and construction. The Architectural Engineering program at Penn State prepares engineers to meet these challenges. The architectural engineers are responsible for the different systems of building, structural, mechanical, electrical, etc. ([www.engr.psu.edu/ae/advising/prospective\\_faq.asp](http://www.engr.psu.edu/ae/advising/prospective_faq.asp)).

Other respondents looked at regulations as a likely solution. One respondent said, “I see certified equipment, standard details, etc. being used more and more to circumvent having to qualify every piece of equipment and /or its installation. It is done now. It will be done more in the future, even over the objections of equipment manufacturers who don't want to fuss with this seismic stuff just in California.”

The International Seismic Application Technology (ISAT) approach is being used by many of the structural engineers in the hospital design area. ISAT is an organization that specializes in addressing the seismic design for non structural elements in buildings. It creates designs for seismic bracing for mechanical, electrical, plumbing, and piping systems. The organization assists the industry's contractors, engineers, inspectors, and facility owners in using the ISAT approach code compliance. It has certainly facilitated hospital design and system integration in hospital construction and retrofit in California. The ISAT Design, Installation and Inspection Manual, OPA-0485, is considered the most comprehensive OSHPD pre-approval in existence. ISAT OPA-0485 pre-approval, combined with current OSHPD experience, appears to have been an effective tool in streamlining the OSHPD document review and plan approval process.

Another respondent echoed the belief that regulation and pre-approval is likely to contribute to improved integration of structural and nonstructural design. He stated, “I think we are headed for a requirement that all permanent building equipment and major medical equipment must be approved and certified by OSHPD prior to use. Such approval might be gained by analysis, by testing, or by experience data. There is a level of criticality where this may be warranted.. My worry is that the zealots will want us to design and test the drinking fountain. Or the light switch.”

A third set of ideas about how to better integrate structural and nonstructural design focused on the possible implications of innovations in the building industry. Some sophisticated owners are now asking for three dimensional computer assisted design models for their buildings.. This is leading to the use of “Building Information Models” and software and “Lean Construction” systems. Either may have significant potential for improving the practice of how issues associated with integrating nonstructural seismic design into the building system design are addressed. Others believe that the movement toward performance based engineering design will lead to addressing the problem because performance of nonstructural elements are key elements to building performance in term of reducing “deaths, dollars, and downtime.”

### **3.1 Reframing the Problem**

There is no doubt that better integration is needed between architecture, structural engineering, and the installers of nonstructural systems, subsystems and components. Post-earthquake analysis of structures drives home the point. Nor is there much doubt that it is necessary to approach buildings intended to house complex processes and critical services as systems, not just as assemblages of components.

To a considerable extent, the failure to achieve the desired integration of structural and nonstructural design in structures subject to earthquakes reflects and is reinforced by professional traditions and practice, and by engineering and architectural education and training. The shortcomings in integrating the component parts of buildings seems to reflect behavioral, organizational, and educational problems more than it does a lack of understanding about how to integrate all those component parts.



In our research and discussions with architects, structural engineers, and providers of nonstructural systems and components, most of the emphasis and discussion about this general problem is aimed at attempting to fix responsibility for integration on one or another of the actors in the process. Illustrative of the focus on the discussion on the appropriate locus of professional responsibility, a recent FEMA publication on Communicating with Owners and Managers of New Buildings on Earthquake Risk noted:

Protecting against nonstructural damage requires clear allocation of roles and responsibilities. An important question is: Is the structural design of mechanical equipment supports the responsibility of the equipment vendor, the mechanical engineer, or the structural engineer? Similarly, is the design of the connections for precast concrete cladding the responsibility of the precast element vendor or the building structural engineer? And, is the layout and design of bracing for ductwork the responsibility of the mechanical contractor or the building structural engineer? If these responsibilities are not called out at the outset of the job, the result will be disputes, extra costs, and potentially serious omissions (FEMA, 2004).

It seems clear that ensuring the seismic resilience of nonstructural components regularly falls through the cracks as buildings are designed and built. If it were to happen only occasionally, then one might conclude that it might occur because of oversight or incidental conflict or confusion over respective roles. Since it happens regularly, if not systematically, attempts to resolve, or at least understand, the phenomenon have focused on trying to ascertain which role in the process should be tagged with the responsibility. As might be expected, most in the various professions involved in the process indicate that those in another profession should bear the burden of responsibility. Our research suggests that neither architects nor structural engineers are particularly interested or well-equipped to address the seismic concerns associated with nonstructural design and installation issues. And, the myriad of nonstructural subsystem designers and installation subcontractors are unlikely to do much other than comply with equipment standards as referenced in the codes in the design and installation of their own products. This could change with a enforcement of the new IBC.

Based on information gathered from a review of the literature and interviews with architects, structural engineers, and nonstructural engineers, we concluded that successfully

implementing changes in the practice of architectural design, structural and nonstructural earthquake engineering requires new ways of thinking and working. The current approach to the problem — focusing on assigning responsibility — seems not to have resulted in significant changes in practice. We think that it would prove useful to reframe the problem.

We suggest that it may be more fruitful to examine the design and construction *process*, rather than the roles of various actors, to understand how to better integrate the essential roles in building design and construction. The following paragraphs summarize our understanding of the design and construction process as it relates to the immediate problem under consideration.

### **3.2 Pressure on Traditional Approaches and Processes**

Change usually comes about when there is significant and increasing discomfort between what is happening and what people expect or want to have happen. It appears to us that this will be the case in integrating architecture, structural engineering, and nonstructural component design and installation. There seems to be pressure for change from at least two sources.

One source of pressure for change is the dissatisfaction noted above by participants in the building design process as expressed by those we interviewed, in what we've read, and by those who spurred us to undertake this project. In terms of functionality, buildings are not being designed and built to be as resilient as they might be, not so much because money is not being spent on design, but because finished buildings are more an assemblage of parts than an integrated system. The dominant process being employed to create those structures is not resulting in integrated resilient systems. As a society, we are much better creating airplanes, automobiles, and washing machines as integrated systems than we are at creating buildings as integrated systems. The discontent among professionals seems to be growing, particularly in California and particularly because of the demands of SB 1953.

The more dominant and widespread force for change, however, appears to be the economics of the design and construction process. The dominant paradigm today is the “design-bid-build” model. It is a top-down process in which the building or facility is conceptualized and goes through a series of design iterations involving a large number of people and organizations specializing in the design of various subsystems of the facility. Subsequent to design, the project

is sent out for competitive bids. Typically, the bids are developed by general contractors, who draw upon a large number of subcontractor specialists, who then submit a package bid to the owner. After a bid is selected, construction begins.

Frankly, the traditional approach is both time-consuming and costly. This process, while it has endured for a long time, has several undesirable characteristics. First, it demands long lead times, resulting in design and construction timetables that are often significantly longer than they ought to be. Second, the various subcontractors tend to plan their work independently of one another, resulting not only in delays, but in limited integration of critical subsystems. Finally, the design-bid-build process seems to cost more than some alternative approaches.

The process of designing, constructing and managing buildings is fragmented. It involves many participants interacting in complex ways over a prolonged period of time. Currently, sequential communication among the participants is the norm. Consequently, while individual parts of the project may be optimized, the optimality of the overall project suffers. It is our view that the quality of the overall project can be significantly improved (in terms of time, money, and quality of design) if there was a tighter, non-sequential collaboration among the participants. Additional improvements will accrue if the participants were provided with discipline-specific design and evaluation tools, which assist them in performing their tasks (Kalay, *et.al*, 1998).

In response to the growing dissatisfaction with “design-bid-build” across both the manufacturing and the construction industries, new approaches are emerging that challenge the traditional approach. At this time, no one knows which of these approaches, if any, will become the dominant paradigm. It is a time characterized by innovation and experimentation. There is little doubt, however, that other approaches will continue to emerge as professionals attempt to devise more effective, efficient processes for creating buildings and facilities.



## SECTION 4

### NEW APPROACHES CHALLENGE THE TRADITIONAL PROCESS

A primary means for greater integration in design and construction is creating tighter coordination among the discrete engineering design activities conducted by different individuals, disciplines, or organizations, so that a unified building design and construction process is formed. When building design involves many systems and subsystems, there is a need for an approach that creates effective interfaces between the many component parts. Design integration can take place within a single organization or among collaborating organizations, as when various architecture, engineering, and analysis activities are synchronized into a building development process. The underlying theme is that of systems integration. The main argument is that systems designs are imperfectly linked and that the applications of new systems integration tools and processes can help bridge the respective subsystems and help ensure that building design leads to building system resilience, as well as shorter time periods from conception to use and lower total costs.

#### 4.1 Systems Perspective and Performance Based Earthquake Engineering

Historical applications of performance-based optimal design have ignored nonstructural components in the evaluation of performance. Although the process toward understanding nonstructural component performance was begun some time ago, significant improvements in understanding nonstructural component performance have been made only recently.

Buildings are composed of both structural and nonstructural systems. While damage to the structural system is the most important measure of building damage affecting casualties and catastrophic loss of life, damage to nonstructural systems and contents can result in significant economic and human loss through building-facility downtime, content damage, and injury or death. Typically the structural system represents about 25% of the building's worth (FEMA 2003). Relatively recent urban earthquakes proved that it is very important to consider nonstructural damage in the design phase rather than exclusively targeting structural performance. (Rojas, et al, 2007)

One approach to achieving greater systems integration and better building system performance at the same or lower cost within the seismic safety community is a combination of a systems perspective and performance based earthquake engineering. Performance based seismic engineering is a relatively new approach to designing buildings. It takes into account a desired level of structural performance given specified ground motion at a specific location and, inherently, takes a systems view of structural performance.

The Veterans Administration, following collapse of the Veterans Hospital in Sylmar during the 1971 San Fernando Earthquake, recognized the need for the system approach. It commissioned a report to address the need for system integration in the design and construction of new hospitals. In its 1977 report entitled Research Study Report Application of the Principles of Systems Integration to the Design of VA Hospital Facilities, the Veteran's Administration noted that "the clear need for a more rational approach to the design, construction and alteration of buildings has led to widespread interest in the concept of systems" and

There is nothing new about the notion that a building is a collection of systems: a structural system, a mechanical system, an electrical system, and so on. What has evolved more recently, however, is the conceptualization of the whole building as a system, and further, the total process of building production and utilization as a system demanding a much higher degree of internal coordination than has been achieved so far. This internal coordination, or integration, begins with an analysis of the building into its components and a study of how well each meets its intended function under real conditions. Of particular interest is how the characteristics of each component directly or indirectly affect the performance of the others and of the total building.

The report went on to capture the critical elements of the argument for greater integration of construction based on a systems perspective: "The systems approach is a strategy of problem definition and solution which emphasizes the interaction between problem elements and between the immediate problem and its larger context, and which specifically avoids traditional methods of independent or *ad hoc* treatment of the various elements."

Performance based seismic engineering has not yet become a dominant approach within the structural engineering profession, even in places like California that are seismically active.

Moreover, the approach focuses only on the design of structures. It does not address the problems of ensuring that design and construction are sufficiently integrated to ensure the desired level of seismic safety.

## **4.2 Design Build Contracting — the Master Builder Concept**

One of the approaches that appears to hold promise for facilitating greater integration from conception to completion and integration of structural, nonstructural, and overall design of facilities is the Design-Build model. According to the Design-Build Institute of America (2007), design-build is a “return to the time-honored approach of the Master Builder, where a single source has absolute accountability for both design and construction.” The Institute describes the process as offering “full accountability for architecture, engineering, and construction”.

Design-Build has been gaining popularity among building and facility owners who want to accelerate the schedule from concept to completion and who want to reduce contractual and management complexities and save money in the process. The notion is simple: the owner contracts with a single firm to design and build the facility, thus presumably ensuring complete integration of all systems and subsystems because that one firm is responsible completely for the project.

This approach is, as stated, not new. It is a new manifestation of an old tradition. It offers the clear potential for being a process that can ensure integration of component parts, but does not, of course, guarantee complete integration simply because it fixes responsibility. Much depends on how the process manifests itself within the individual firms. That, presumably, depends on the development of congruent training programs, professional standards, and a tradition of employing systems integration methods.

## **4.3 Systems Integration Tools and Approaches**

Several tools have emerged over the past few years that are congruent with and that facilitate both the Design-Build and performance based seismic engineering.

**Concurrent Engineering.** “Concurrent Engineering— which is sometimes called Simultaneous Engineering or Integrated Product Development (IPD) — was defined by the Institute for Defense Analysis (IDA) in its December 1988 report, *The Role of Concurrent Engineering in Weapons System Acquisition*, as a systematic approach to the integrated, concurrent design of products and their related processes, including manufacture and support. This approach is intended to cause the developers, from the outset, to consider all elements of the product life cycle from conception through disposal, including quality, cost, schedule, and user requirements” (Stark, 1998) .

Stark continues to explain that concurrent engineering is an attempt to overcome problems almost inherent in the traditional model in which from different departments work one after the other on successive phases of product development.

In traditional serial development, the product is first completely defined by the design engineering department, after which the manufacturing process is defined by the manufacturing engineering department, etc. Usually this is a slow, costly and low-quality approach, leading to a lot of engineering changes, production problems, product introduction delays, and a product that is less competitive than desired . . . Concurrent Engineering brings together multidisciplinary teams, in which product developers from different functions work together and in parallel from the start of a project with the intention of getting things right as quickly as possible, and as early as possible . . . A cross-functional team might contain representatives of different functions such as systems engineering, mechanical engineering, electrical engineering, systems producibility, fabrication producibility, quality, reliability and maintainability, testability, manufacturing, drafting and layout, and program management (Stark, 1998).

Concurrent engineering “is only now being carefully applied to the construction sector...It enables developers to consider all elements of a building or structure’s life cycle from the conception stage right through to disposal, and to include issues of quality, cost, schedule, and user requirements” (Anumba *et. al.*, 2006).

The concurrent engineering approach advocates the implementation of an interdisciplinary team approach to building design by encouraging collaborative decision making based upon team coordination and information sharing. This suggests that an interdisciplinary



approach might be achieved by bringing the owner, architect, structural engineer, mechanical, electrical, and other disciplined engineers, and major subcontractors and suppliers directly into the design and construction process.

**Lean Construction.** Lean construction is an adaptation to building design and construction of principles and practices developed in “lean manufacturing”. Unlike manufacturing, construction is a project based-production process. Lean construction is concerned with concurrent and continuous improvement throughout the design and construction process. It is essentially a management approach and an outgrowth of the Total Quality Management movement.

Lean construction is a “way to design production systems to minimize waste of materials, time, and effort in order to generate the maximum possible amount of value (Koskela, *et al.* 2002) ”. Designing a production system to achieve the stated ends is only possible through the collaboration of all project participants (owner, architect, engineers, builders, facility managers, and end-users) at early stages of the project. This goes beyond the contractual arrangement of the design-build paradigm, but is fully congruent with the Master Builder concept. “Essentially, Lean Construction recognizes that desired ends should affect the means selected to achieve these ends, and that available means will affect realized ends” (Lichtig 2005).

Lean construction typically does not include the front-end design tasks, so it would complement, rather than replace, concurrent engineering and other methods for integrating components of the building system prior to actual construction. Nonetheless, the idea of integrating all the actors during the construction process suggests that the basic premises are valuable in ensuring that integration during design extends through construction.

**Building Information Models (BIM).** BIM is an acronym for a class of three-dimensional computer-driven models that provide information about a building before, during, and after construction. The models typically include information about the site and the geometry, spatial relationships, and quantities and properties of building components. The models can, for example, include information on manufacturers' details of nonstructural building components. These models may be used to examine construction processes and facility

operation. The building information models model representations of the actual parts and pieces being used to build a building.

The models are currently used by some professionals engaged in building projects ranging from simple to extremely complex structures, even though they are relatively new and still being developed. One might foresee, however, their application as virtual information models that would facilitate concurrent engineering and integrated design of critical components of building facilities. If the process was adhered to throughout the project, the model of an individual building would identify eliminate disparities between “as designed” and “as being built” because changes would be incorporated in the model; design would presumably be continuous through the life of the project as modifications are deemed essential or desirable. The models would be employed, presumably, by the integrated design team of architects, structural engineers, mechanical engineers, electrical engineers, and representatives of a hundred or more specialized nonstructural component elements. The model would be used directly by those involved in construction and in managing construction and by the owner who, presumably, would have a model that represents the building “as built.”

Proponents of building information models claim that they can greatly reduce errors made by design team members and the construction team by detecting conflicts or clashes between design elements. With advances in computing and software, the approach should contribute significantly as a tool to facilitate integration of systems and subsystems.

## **SECTION 5**

### **WHAT NEEDS TO BE DONE?**

Current trends in the design and construction process suggest that a new profession is already emerging—that of building systems integrator. The new profession might be defined as the “master builder” or it may become a specialty within an existing field, such as architecture. There is little doubt, however, that the specialization will emerge and become defined and redefined with experience and research into building design and construction practices, not so much because it is driven by concerns about seismic safety, but because of concern about the amount of time needed from conception to use, about integrating construction activities, and about reducing costs.

Buildings intended for complex, specialized use can no longer be conceptualized apart from their intended function and their contents. They have truly become complex systems in which all the components must be integrated with one another— systems in which components can be designed, installed, or operated in isolation from the rest of the building only at one’s peril. The complexity of contemporary and anticipated technologies employed in creating integrated facilities will increasingly demand more complete integration from concept to end use.

The undergraduate and graduate education of architects, engineers, and others involved in the design and construction industry will have to change to adapt to the new realities of practice and, especially, the demands for effective and efficient interfaces between all the component parts of complex facilities. American higher education is organized in terms of disciplines that have been developed in silos and that reinforced a silo mentality because of tradition, accreditation requirements and because of the system of rewards created within those disciplines. Changes in the practices within academic institutions usually occur only painfully and slowly. Isolation and even arrogance within the disciplines often makes it difficult for practitioners, who are often in front of the universities because reality forces them to see across systems, to bring what they have learned to bear on educational curricula and teaching practice. Unfortunately, despite concern expressed by some universities and some attempts by federal agencies that fund

research, interdisciplinary education and multi-disciplinary approaches are still the exception and not the rule.

It may be that legislation such as SB 1953 —legislation that emerged from practitioners who were looking at buildings as systems—may be necessary simply to force professionals in building design and construction to view critical facilities as complex systems. This, in turn, may bring pressure on academic institutions and, gradually, lead them to reconsider what they teach and how they teach it. Certainly, the demands of SB 1953 have brought the problems associated with integrating architecture, structural engineering, and the design and installation of nonstructural components of acute care hospitals into sharp focus.

## SECTION 6 REFERENCES AND CITED MATERIALS

Anumba, Chimay J., John Kamara, Anne-Francoise Cutting-Decelle (eds), (2006). , *Concurrent Engineering in Construction Projects*. Taylor and Francis Group, Routledge, London.

Bachman, Robert (2007). *US Building Seismic Code Testing Requirements for Nonstructural Components*, Seismic Regulations and Challenges for Protecting Building Equipment, Components and Operations Symposium, University of Buffalo, NY

California Seismic Safety Commission (1991). *Architectural Practice and Earthquake Hazards* (SSC 91-10) Sacramento, CA

Design-Build Institute of America (2007). [www.dbia.org](http://www.dbia.org)

Federal Emergency Management Agency (2003). *Multi-Hazard Loss Estimation Methodology Earthquake Model: HAZUS-MH MRI*, Department of Homeland Security Emergency Preparedness Response Directorate, Washington, D.C.

Federal Emergency Management Agency ( 2004). *Communicating with Owners and Managers of New Buildings on Earthquake Risk*, Risk Management Series, Primer for Design Professionals. (FEMA 389), Washington, D.C.

Joint Venture of Building Systems Development and Stone, Marraccini and Patterson, (1977). *VA Hospital Building System, Research Study Report Application of the Principles of Systems Integration to the Design of VA Hospital Facilities, Research Study Report Project Number 99-R047*, Construction Veterans Administration Washington, D.C.

Kalay, Yehuda E., Lachmi Khemlani, and Jin Won Choi (1998). “An Integrated Model to Support Collaborative Multi-Disciplinary Design of Buildings.” *Automation in Construction*, Volume 7, Number 2, January 1998, pp. 177-188 (12).

Kircher, C. A. (2003), “It Makes Dollars and Cents to Improve Nonstructural System Performance” in *Proceedings of ATC 29-2 Seminar on Seismic Design, Performance, and Retrofit of Nonstructural Components in Critical Facilities*, Applied Technology Council, Redwood City, California.

Koskela, L. and Howell, G. (2002). “The Underlying Theory of Project Management is Obsolete.” *Proceedings of the PMI Research Conference*, 2002, Pg. 293-302.

Lichtig, W. (2005). "Ten Key Decisions to A Successful Construction Project." *American Bar Association, Forum on the Construction Industry*, September 29-30, 2005, Toronto, Canada.

Metri, B. A. (2005). "TQM Critical Success Factors for Construction Firms, Management," *Journal of Contemporary Management Issues*. Vol.10. No. 2. (2005.) pp. 61-72.

OSHPD. (2007). Code Application Notice Draft, File No. 2-1613A.1, January 1, 2008), State of California, Office of Statewide Health Planning and Development, Sacramento, California

Porter, Keith A. (2003). "An Overview of PEER's Performance-Based Earthquake Engineering Methodology," Ninth International Conference on Applications of Statistics and Probability in Civil Engineering (ICASP9), July 6-9, 2003, San Francisco.

Rojas, H., Pezeshk, S., Foley, C.M. (2007) "Performance-Based Optimization Considering Structural and Nonstructural Components", *Earthquake Spectra*, The Professional Journal of the Earthquake Engineering Research Institute, Volume 23, Number 3, August 2007.

State of California (2001). "California Building Standards Administrative Code, Title 24", Sacramento, California.

Stark, John, 1998, "A Few Words About Concurrent Engineering." John Stark Associates, Management Consultants, Web Site <http://www.johnstark.com/fwce.html>

Whittaker, A. S., and T. T. Soong (2003). "An Overview of Nonstructural Components Research at Three U.S. Earthquake Engineering Research Centers" in *Proceedings of ATC 29-2 Seminar on Seismic Design, Performance, and Retrofit of Nonstructural Components in Critical Facilities*, Applied Technology Council, Redwood City, California.

## MCEER Technical Reports

MCEER publishes technical reports on a variety of subjects written by authors funded through MCEER. These reports are available from both MCEER Publications and the National Technical Information Service (NTIS). Requests for reports should be directed to MCEER Publications, MCEER, University at Buffalo, State University of New York, Red Jacket Quadrangle, Buffalo, New York 14261. Reports can also be requested through NTIS, 5285 Port Royal Road, Springfield, Virginia 22161. NTIS accession numbers are shown in parenthesis, if available.

- NCEER-87-0001 "First-Year Program in Research, Education and Technology Transfer," 3/5/87, (PB88-134275, A04, MF-A01).
- NCEER-87-0002 "Experimental Evaluation of Instantaneous Optimal Algorithms for Structural Control," by R.C. Lin, T.T. Soong and A.M. Reinhorn, 4/20/87, (PB88-134341, A04, MF-A01).
- NCEER-87-0003 "Experimentation Using the Earthquake Simulation Facilities at University at Buffalo," by A.M. Reinhorn and R.L. Ketter, to be published.
- NCEER-87-0004 "The System Characteristics and Performance of a Shaking Table," by J.S. Hwang, K.C. Chang and G.C. Lee, 6/1/87, (PB88-134259, A03, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0005 "A Finite Element Formulation for Nonlinear Viscoplastic Material Using a Q Model," by O. Gyebe and G. Dasgupta, 11/2/87, (PB88-213764, A08, MF-A01).
- NCEER-87-0006 "Symbolic Manipulation Program (SMP) - Algebraic Codes for Two and Three Dimensional Finite Element Formulations," by X. Lee and G. Dasgupta, 11/9/87, (PB88-218522, A05, MF-A01).
- NCEER-87-0007 "Instantaneous Optimal Control Laws for Tall Buildings Under Seismic Excitations," by J.N. Yang, A. Akbarpour and P. Ghaemmaghami, 6/10/87, (PB88-134333, A06, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0008 "IDARC: Inelastic Damage Analysis of Reinforced Concrete Frame - Shear-Wall Structures," by Y.J. Park, A.M. Reinhorn and S.K. Kunnath, 7/20/87, (PB88-134325, A09, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0009 "Liquefaction Potential for New York State: A Preliminary Report on Sites in Manhattan and Buffalo," by M. Budhu, V. Vijayakumar, R.F. Giese and L. Baumgras, 8/31/87, (PB88-163704, A03, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0010 "Vertical and Torsional Vibration of Foundations in Inhomogeneous Media," by A.S. Veletsos and K.W. Dotson, 6/1/87, (PB88-134291, A03, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0011 "Seismic Probabilistic Risk Assessment and Seismic Margins Studies for Nuclear Power Plants," by Howard H.M. Hwang, 6/15/87, (PB88-134267, A03, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0012 "Parametric Studies of Frequency Response of Secondary Systems Under Ground-Acceleration Excitations," by Y. Yong and Y.K. Lin, 6/10/87, (PB88-134309, A03, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0013 "Frequency Response of Secondary Systems Under Seismic Excitation," by J.A. HoLung, J. Cai and Y.K. Lin, 7/31/87, (PB88-134317, A05, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0014 "Modelling Earthquake Ground Motions in Seismically Active Regions Using Parametric Time Series Methods," by G.W. Ellis and A.S. Cakmak, 8/25/87, (PB88-134283, A08, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0015 "Detection and Assessment of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 8/25/87, (PB88-163712, A05, MF-A01). This report is only available through NTIS (see address given above).

- NCEER-87-0016 "Pipeline Experiment at Parkfield, California," by J. Isenberg and E. Richardson, 9/15/87, (PB88-163720, A03, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0017 "Digital Simulation of Seismic Ground Motion," by M. Shinozuka, G. Deodatis and T. Harada, 8/31/87, (PB88-155197, A04, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0018 "Practical Considerations for Structural Control: System Uncertainty, System Time Delay and Truncation of Small Control Forces," J.N. Yang and A. Akbarpour, 8/10/87, (PB88-163738, A08, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0019 "Modal Analysis of Nonclassically Damped Structural Systems Using Canonical Transformation," by J.N. Yang, S. Sarkani and F.X. Long, 9/27/87, (PB88-187851, A04, MF-A01).
- NCEER-87-0020 "A Nonstationary Solution in Random Vibration Theory," by J.R. Red-Horse and P.D. Spanos, 11/3/87, (PB88-163746, A03, MF-A01).
- NCEER-87-0021 "Horizontal Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by A.S. Veletsos and K.W. Dotson, 10/15/87, (PB88-150859, A04, MF-A01).
- NCEER-87-0022 "Seismic Damage Assessment of Reinforced Concrete Members," by Y.S. Chung, C. Meyer and M. Shinozuka, 10/9/87, (PB88-150867, A05, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0023 "Active Structural Control in Civil Engineering," by T.T. Soong, 11/11/87, (PB88-187778, A03, MF-A01).
- NCEER-87-0024 "Vertical and Torsional Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by K.W. Dotson and A.S. Veletsos, 12/87, (PB88-187786, A03, MF-A01).
- NCEER-87-0025 "Proceedings from the Symposium on Seismic Hazards, Ground Motions, Soil-Liquefaction and Engineering Practice in Eastern North America," October 20-22, 1987, edited by K.H. Jacob, 12/87, (PB88-188115, A23, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0026 "Report on the Whittier-Narrows, California, Earthquake of October 1, 1987," by J. Pantelic and A. Reinhorn, 11/87, (PB88-187752, A03, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-87-0027 "Design of a Modular Program for Transient Nonlinear Analysis of Large 3-D Building Structures," by S. Srivastav and J.F. Abel, 12/30/87, (PB88-187950, A05, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-87-0028 "Second-Year Program in Research, Education and Technology Transfer," 3/8/88, (PB88-219480, A04, MF-A01).
- NCEER-88-0001 "Workshop on Seismic Computer Analysis and Design of Buildings With Interactive Graphics," by W. McGuire, J.F. Abel and C.H. Conley, 1/18/88, (PB88-187760, A03, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0002 "Optimal Control of Nonlinear Flexible Structures," by J.N. Yang, F.X. Long and D. Wong, 1/22/88, (PB88-213772, A06, MF-A01).
- NCEER-88-0003 "Substructuring Techniques in the Time Domain for Primary-Secondary Structural Systems," by G.D. Manolis and G. Juhn, 2/10/88, (PB88-213780, A04, MF-A01).
- NCEER-88-0004 "Iterative Seismic Analysis of Primary-Secondary Systems," by A. Singhal, L.D. Lutes and P.D. Spanos, 2/23/88, (PB88-213798, A04, MF-A01).
- NCEER-88-0005 "Stochastic Finite Element Expansion for Random Media," by P.D. Spanos and R. Ghanem, 3/14/88, (PB88-213806, A03, MF-A01).



- NCEER-88-0006 "Combining Structural Optimization and Structural Control," by F.Y. Cheng and C.P. Pantelides, 1/10/88, (PB88-213814, A05, MF-A01).
- NCEER-88-0007 "Seismic Performance Assessment of Code-Designed Structures," by H.H-M. Hwang, J-W. Jaw and H-J. Shau, 3/20/88, (PB88-219423, A04, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0008 "Reliability Analysis of Code-Designed Structures Under Natural Hazards," by H.H-M. Hwang, H. Ushiba and M. Shinozuka, 2/29/88, (PB88-229471, A07, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0009 "Seismic Fragility Analysis of Shear Wall Structures," by J-W Jaw and H.H-M. Hwang, 4/30/88, (PB89-102867, A04, MF-A01).
- NCEER-88-0010 "Base Isolation of a Multi-Story Building Under a Harmonic Ground Motion - A Comparison of Performances of Various Systems," by F-G Fan, G. Ahmadi and I.G. Tadjbakhsh, 5/18/88, (PB89-122238, A06, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0011 "Seismic Floor Response Spectra for a Combined System by Green's Functions," by F.M. Lavelle, L.A. Bergman and P.D. Spanos, 5/1/88, (PB89-102875, A03, MF-A01).
- NCEER-88-0012 "A New Solution Technique for Randomly Excited Hysteretic Structures," by G.Q. Cai and Y.K. Lin, 5/16/88, (PB89-102883, A03, MF-A01).
- NCEER-88-0013 "A Study of Radiation Damping and Soil-Structure Interaction Effects in the Centrifuge," by K. Weissman, supervised by J.H. Prevost, 5/24/88, (PB89-144703, A06, MF-A01).
- NCEER-88-0014 "Parameter Identification and Implementation of a Kinematic Plasticity Model for Frictional Soils," by J.H. Prevost and D.V. Griffiths, to be published.
- NCEER-88-0015 "Two- and Three- Dimensional Dynamic Finite Element Analyses of the Long Valley Dam," by D.V. Griffiths and J.H. Prevost, 6/17/88, (PB89-144711, A04, MF-A01).
- NCEER-88-0016 "Damage Assessment of Reinforced Concrete Structures in Eastern United States," by A.M. Reinhorn, M.J. Seidel, S.K. Kunnath and Y.J. Park, 6/15/88, (PB89-122220, A04, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0017 "Dynamic Compliance of Vertically Loaded Strip Foundations in Multilayered Viscoelastic Soils," by S. Ahmad and A.S.M. Israil, 6/17/88, (PB89-102891, A04, MF-A01).
- NCEER-88-0018 "An Experimental Study of Seismic Structural Response With Added Viscoelastic Dampers," by R.C. Lin, Z. Liang, T.T. Soong and R.H. Zhang, 6/30/88, (PB89-122212, A05, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-88-0019 "Experimental Investigation of Primary - Secondary System Interaction," by G.D. Manolis, G. Juhn and A.M. Reinhorn, 5/27/88, (PB89-122204, A04, MF-A01).
- NCEER-88-0020 "A Response Spectrum Approach For Analysis of Nonclassically Damped Structures," by J.N. Yang, S. Sarkani and F.X. Long, 4/22/88, (PB89-102909, A04, MF-A01).
- NCEER-88-0021 "Seismic Interaction of Structures and Soils: Stochastic Approach," by A.S. Veletsos and A.M. Prasad, 7/21/88, (PB89-122196, A04, MF-A01). This report is only available through NTIS (see address given above).
- NCEER-88-0022 "Identification of the Serviceability Limit State and Detection of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 6/15/88, (PB89-122188, A05, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-88-0023 "Multi-Hazard Risk Analysis: Case of a Simple Offshore Structure," by B.K. Bhartia and E.H. Vanmarcke, 7/21/88, (PB89-145213, A05, MF-A01).

- NCEER-88-0024 "Automated Seismic Design of Reinforced Concrete Buildings," by Y.S. Chung, C. Meyer and M. Shinozuka, 7/5/88, (PB89-122170, A06, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-88-0025 "Experimental Study of Active Control of MDOF Structures Under Seismic Excitations," by L.L. Chung, R.C. Lin, T.T. Soong and A.M. Reinhorn, 7/10/88, (PB89-122600, A04, MF-A01).
- NCEER-88-0026 "Earthquake Simulation Tests of a Low-Rise Metal Structure," by J.S. Hwang, K.C. Chang, G.C. Lee and R.L. Ketter, 8/1/88, (PB89-102917, A04, MF-A01).
- NCEER-88-0027 "Systems Study of Urban Response and Reconstruction Due to Catastrophic Earthquakes," by F. Kozin and H.K. Zhou, 9/22/88, (PB90-162348, A04, MF-A01).
- NCEER-88-0028 "Seismic Fragility Analysis of Plane Frame Structures," by H.H-M. Hwang and Y.K. Low, 7/31/88, (PB89-131445, A06, MF-A01).
- NCEER-88-0029 "Response Analysis of Stochastic Structures," by A. Kardara, C. Bucher and M. Shinozuka, 9/22/88, (PB89-174429, A04, MF-A01).
- NCEER-88-0030 "Nonnormal Accelerations Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 9/19/88, (PB89-131437, A04, MF-A01).
- NCEER-88-0031 "Design Approaches for Soil-Structure Interaction," by A.S. Veletsos, A.M. Prasad and Y. Tang, 12/30/88, (PB89-174437, A03, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-88-0032 "A Re-evaluation of Design Spectra for Seismic Damage Control," by C.J. Turkstra and A.G. Tallin, 11/7/88, (PB89-145221, A05, MF-A01).
- NCEER-88-0033 "The Behavior and Design of Noncontact Lap Splices Subjected to Repeated Inelastic Tensile Loading," by V.E. Sagan, P. Gergely and R.N. White, 12/8/88, (PB89-163737, A08, MF-A01).
- NCEER-88-0034 "Seismic Response of Pile Foundations," by S.M. Mamoon, P.K. Banerjee and S. Ahmad, 11/1/88, (PB89-145239, A04, MF-A01).
- NCEER-88-0035 "Modeling of R/C Building Structures With Flexible Floor Diaphragms (IDARC2)," by A.M. Reinhorn, S.K. Kunnath and N. Panahshahi, 9/7/88, (PB89-207153, A07, MF-A01).
- NCEER-88-0036 "Solution of the Dam-Reservoir Interaction Problem Using a Combination of FEM, BEM with Particular Integrals, Modal Analysis, and Substructuring," by C-S. Tsai, G.C. Lee and R.L. Ketter, 12/31/88, (PB89-207146, A04, MF-A01).
- NCEER-88-0037 "Optimal Placement of Actuators for Structural Control," by F.Y. Cheng and C.P. Pantelides, 8/15/88, (PB89-162846, A05, MF-A01).
- NCEER-88-0038 "Teflon Bearings in Aseismic Base Isolation: Experimental Studies and Mathematical Modeling," by A. Mokha, M.C. Constantinou and A.M. Reinhorn, 12/5/88, (PB89-218457, A10, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-88-0039 "Seismic Behavior of Flat Slab High-Rise Buildings in the New York City Area," by P. Weidlinger and M. Ettouney, 10/15/88, (PB90-145681, A04, MF-A01).
- NCEER-88-0040 "Evaluation of the Earthquake Resistance of Existing Buildings in New York City," by P. Weidlinger and M. Ettouney, 10/15/88, to be published.
- NCEER-88-0041 "Small-Scale Modeling Techniques for Reinforced Concrete Structures Subjected to Seismic Loads," by W. Kim, A. El-Attar and R.N. White, 11/22/88, (PB89-189625, A05, MF-A01).
- NCEER-88-0042 "Modeling Strong Ground Motion from Multiple Event Earthquakes," by G.W. Ellis and A.S. Cakmak, 10/15/88, (PB89-174445, A03, MF-A01).

- NCEER-88-0043 "Nonstationary Models of Seismic Ground Acceleration," by M. Grigoriu, S.E. Ruiz and E. Rosenblueth, 7/15/88, (PB89-189617, A04, MF-A01).
- NCEER-88-0044 "SARCF User's Guide: Seismic Analysis of Reinforced Concrete Frames," by Y.S. Chung, C. Meyer and M. Shinozuka, 11/9/88, (PB89-174452, A08, MF-A01).
- NCEER-88-0045 "First Expert Panel Meeting on Disaster Research and Planning," edited by J. Pantelic and J. Stoyke, 9/15/88, (PB89-174460, A05, MF-A01).
- NCEER-88-0046 "Preliminary Studies of the Effect of Degrading Infill Walls on the Nonlinear Seismic Response of Steel Frames," by C.Z. Chrysostomou, P. Gergely and J.F. Abel, 12/19/88, (PB89-208383, A05, MF-A01).
- NCEER-88-0047 "Reinforced Concrete Frame Component Testing Facility - Design, Construction, Instrumentation and Operation," by S.P. Pessiki, C. Conley, T. Bond, P. Gergely and R.N. White, 12/16/88, (PB89-174478, A04, MF-A01).
- NCEER-89-0001 "Effects of Protective Cushion and Soil Compliancy on the Response of Equipment Within a Seismically Excited Building," by J.A. HoLung, 2/16/89, (PB89-207179, A04, MF-A01).
- NCEER-89-0002 "Statistical Evaluation of Response Modification Factors for Reinforced Concrete Structures," by H.H-M. Hwang and J-W. Jaw, 2/17/89, (PB89-207187, A05, MF-A01).
- NCEER-89-0003 "Hysteretic Columns Under Random Excitation," by G-Q. Cai and Y.K. Lin, 1/9/89, (PB89-196513, A03, MF-A01).
- NCEER-89-0004 "Experimental Study of 'Elephant Foot Bulge' Instability of Thin-Walled Metal Tanks," by Z-H. Jia and R.L. Ketter, 2/22/89, (PB89-207195, A03, MF-A01).
- NCEER-89-0005 "Experiment on Performance of Buried Pipelines Across San Andreas Fault," by J. Isenberg, E. Richardson and T.D. O'Rourke, 3/10/89, (PB89-218440, A04, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-89-0006 "A Knowledge-Based Approach to Structural Design of Earthquake-Resistant Buildings," by M. Subramani, P. Gergely, C.H. Conley, J.F. Abel and A.H. Zaghaw, 1/15/89, (PB89-218465, A06, MF-A01).
- NCEER-89-0007 "Liquefaction Hazards and Their Effects on Buried Pipelines," by T.D. O'Rourke and P.A. Lane, 2/1/89, (PB89-218481, A09, MF-A01).
- NCEER-89-0008 "Fundamentals of System Identification in Structural Dynamics," by H. Imai, C-B. Yun, O. Maruyama and M. Shinozuka, 1/26/89, (PB89-207211, A04, MF-A01).
- NCEER-89-0009 "Effects of the 1985 Michoacan Earthquake on Water Systems and Other Buried Lifelines in Mexico," by A.G. Ayala and M.J. O'Rourke, 3/8/89, (PB89-207229, A06, MF-A01).
- NCEER-89-R010 "NCEER Bibliography of Earthquake Education Materials," by K.E.K. Ross, Second Revision, 9/1/89, (PB90-125352, A05, MF-A01). This report is replaced by NCEER-92-0018.
- NCEER-89-0011 "Inelastic Three-Dimensional Response Analysis of Reinforced Concrete Building Structures (IDARC-3D), Part I - Modeling," by S.K. Kunnath and A.M. Reinhorn, 4/17/89, (PB90-114612, A07, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-89-0012 "Recommended Modifications to ATC-14," by C.D. Poland and J.O. Malley, 4/12/89, (PB90-108648, A15, MF-A01).
- NCEER-89-0013 "Repair and Strengthening of Beam-to-Column Connections Subjected to Earthquake Loading," by M. Corazao and A.J. Durrani, 2/28/89, (PB90-109885, A06, MF-A01).
- NCEER-89-0014 "Program EXKAL2 for Identification of Structural Dynamic Systems," by O. Maruyama, C-B. Yun, M. Hoshiya and M. Shinozuka, 5/19/89, (PB90-109877, A09, MF-A01).

- NCEER-89-0015 "Response of Frames With Bolted Semi-Rigid Connections, Part I - Experimental Study and Analytical Predictions," by P.J. DiCorso, A.M. Reinhorn, J.R. Dickerson, J.B. Radzinski and W.L. Harper, 6/1/89, to be published.
- NCEER-89-0016 "ARMA Monte Carlo Simulation in Probabilistic Structural Analysis," by P.D. Spanos and M.P. Mignolet, 7/10/89, (PB90-109893, A03, MF-A01).
- NCEER-89-P017 "Preliminary Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 6/23/89, (PB90-108606, A03, MF-A01).
- NCEER-89-0017 "Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 12/31/89, (PB90-207895, A012, MF-A02). This report is available only through NTIS (see address given above).
- NCEER-89-0018 "Multidimensional Models of Hysteretic Material Behavior for Vibration Analysis of Shape Memory Energy Absorbing Devices, by E.J. Graesser and F.A. Cozzarelli, 6/7/89, (PB90-164146, A04, MF-A01).
- NCEER-89-0019 "Nonlinear Dynamic Analysis of Three-Dimensional Base Isolated Structures (3D-BASIS)," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 8/3/89, (PB90-161936, A06, MF-A01). This report has been replaced by NCEER-93-0011.
- NCEER-89-0020 "Structural Control Considering Time-Rate of Control Forces and Control Rate Constraints," by F.Y. Cheng and C.P. Pantelides, 8/3/89, (PB90-120445, A04, MF-A01).
- NCEER-89-0021 "Subsurface Conditions of Memphis and Shelby County," by K.W. Ng, T-S. Chang and H-H.M. Hwang, 7/26/89, (PB90-120437, A03, MF-A01).
- NCEER-89-0022 "Seismic Wave Propagation Effects on Straight Jointed Buried Pipelines," by K. Elhadi and M.J. O'Rourke, 8/24/89, (PB90-162322, A10, MF-A02).
- NCEER-89-0023 "Workshop on Serviceability Analysis of Water Delivery Systems," edited by M. Grigoriu, 3/6/89, (PB90-127424, A03, MF-A01).
- NCEER-89-0024 "Shaking Table Study of a 1/5 Scale Steel Frame Composed of Tapered Members," by K.C. Chang, J.S. Hwang and G.C. Lee, 9/18/89, (PB90-160169, A04, MF-A01).
- NCEER-89-0025 "DYNA1D: A Computer Program for Nonlinear Seismic Site Response Analysis - Technical Documentation," by Jean H. Prevost, 9/14/89, (PB90-161944, A07, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-89-0026 "1:4 Scale Model Studies of Active Tendon Systems and Active Mass Dampers for Aseismic Protection," by A.M. Reinhorn, T.T. Soong, R.C. Lin, Y.P. Yang, Y. Fukao, H. Abe and M. Nakai, 9/15/89, (PB90-173246, A10, MF-A02). This report is available only through NTIS (see address given above).
- NCEER-89-0027 "Scattering of Waves by Inclusions in a Nonhomogeneous Elastic Half Space Solved by Boundary Element Methods," by P.K. Hadley, A. Askar and A.S. Cakmak, 6/15/89, (PB90-145699, A07, MF-A01).
- NCEER-89-0028 "Statistical Evaluation of Deflection Amplification Factors for Reinforced Concrete Structures," by H.H.M. Hwang, J-W. Jaw and A.L. Ch'ng, 8/31/89, (PB90-164633, A05, MF-A01).
- NCEER-89-0029 "Bedrock Accelerations in Memphis Area Due to Large New Madrid Earthquakes," by H.H.M. Hwang, C.H.S. Chen and G. Yu, 11/7/89, (PB90-162330, A04, MF-A01).
- NCEER-89-0030 "Seismic Behavior and Response Sensitivity of Secondary Structural Systems," by Y.Q. Chen and T.T. Soong, 10/23/89, (PB90-164658, A08, MF-A01).
- NCEER-89-0031 "Random Vibration and Reliability Analysis of Primary-Secondary Structural Systems," by Y. Ibrahim, M. Grigoriu and T.T. Soong, 11/10/89, (PB90-161951, A04, MF-A01).

- NCEER-89-0032 "Proceedings from the Second U.S. - Japan Workshop on Liquefaction, Large Ground Deformation and Their Effects on Lifelines, September 26-29, 1989," Edited by T.D. O'Rourke and M. Hamada, 12/1/89, (PB90-209388, A22, MF-A03).
- NCEER-89-0033 "Deterministic Model for Seismic Damage Evaluation of Reinforced Concrete Structures," by J.M. Bracci, A.M. Reinhorn, J.B. Mander and S.K. Kunnath, 9/27/89, (PB91-108803, A06, MF-A01).
- NCEER-89-0034 "On the Relation Between Local and Global Damage Indices," by E. DiPasquale and A.S. Cakmak, 8/15/89, (PB90-173865, A05, MF-A01).
- NCEER-89-0035 "Cyclic Undrained Behavior of Nonplastic and Low Plasticity Silts," by A.J. Walker and H.E. Stewart, 7/26/89, (PB90-183518, A10, MF-A01).
- NCEER-89-0036 "Liquefaction Potential of Surficial Deposits in the City of Buffalo, New York," by M. Budhu, R. Giese and L. Baumgrass, 1/17/89, (PB90-208455, A04, MF-A01).
- NCEER-89-0037 "A Deterministic Assessment of Effects of Ground Motion Incoherence," by A.S. Veletsos and Y. Tang, 7/15/89, (PB90-164294, A03, MF-A01).
- NCEER-89-0038 "Workshop on Ground Motion Parameters for Seismic Hazard Mapping," July 17-18, 1989, edited by R.V. Whitman, 12/1/89, (PB90-173923, A04, MF-A01).
- NCEER-89-0039 "Seismic Effects on Elevated Transit Lines of the New York City Transit Authority," by C.J. Costantino, C.A. Miller and E. Heymsfield, 12/26/89, (PB90-207887, A06, MF-A01).
- NCEER-89-0040 "Centrifugal Modeling of Dynamic Soil-Structure Interaction," by K. Weissman, Supervised by J.H. Prevost, 5/10/89, (PB90-207879, A07, MF-A01).
- NCEER-89-0041 "Linearized Identification of Buildings With Cores for Seismic Vulnerability Assessment," by I-K. Ho and A.E. Aktan, 11/1/89, (PB90-251943, A07, MF-A01).
- NCEER-90-0001 "Geotechnical and Lifeline Aspects of the October 17, 1989 Loma Prieta Earthquake in San Francisco," by T.D. O'Rourke, H.E. Stewart, F.T. Blackburn and T.S. Dickerman, 1/90, (PB90-208596, A05, MF-A01).
- NCEER-90-0002 "Nonnormal Secondary Response Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 2/28/90, (PB90-251976, A07, MF-A01).
- NCEER-90-0003 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/16/90, (PB91-251984, A05, MF-A05). This report has been replaced by NCEER-92-0018.
- NCEER-90-0004 "Catalog of Strong Motion Stations in Eastern North America," by R.W. Busby, 4/3/90, (PB90-251984, A05, MF-A01).
- NCEER-90-0005 "NCEER Strong-Motion Data Base: A User Manual for the GeoBase Release (Version 1.0 for the Sun3)," by P. Friberg and K. Jacob, 3/31/90 (PB90-258062, A04, MF-A01).
- NCEER-90-0006 "Seismic Hazard Along a Crude Oil Pipeline in the Event of an 1811-1812 Type New Madrid Earthquake," by H.H.M. Hwang and C-H.S. Chen, 4/16/90, (PB90-258054, A04, MF-A01).
- NCEER-90-0007 "Site-Specific Response Spectra for Memphis Sheahan Pumping Station," by H.H.M. Hwang and C.S. Lee, 5/15/90, (PB91-108811, A05, MF-A01).
- NCEER-90-0008 "Pilot Study on Seismic Vulnerability of Crude Oil Transmission Systems," by T. Ariman, R. Dobry, M. Grigoriu, F. Kozin, M. O'Rourke, T. O'Rourke and M. Shinozuka, 5/25/90, (PB91-108837, A06, MF-A01).
- NCEER-90-0009 "A Program to Generate Site Dependent Time Histories: EQGEN," by G.W. Ellis, M. Srinivasan and A.S. Cakmak, 1/30/90, (PB91-108829, A04, MF-A01).
- NCEER-90-0010 "Active Isolation for Seismic Protection of Operating Rooms," by M.E. Talbott, Supervised by M. Shinozuka, 6/8/9, (PB91-110205, A05, MF-A01).

- NCEER-90-0011 "Program LINEARID for Identification of Linear Structural Dynamic Systems," by C-B. Yun and M. Shinozuka, 6/25/90, (PB91-110312, A08, MF-A01).
- NCEER-90-0012 "Two-Dimensional Two-Phase Elasto-Plastic Seismic Response of Earth Dams," by A.N. Yiagos, Supervised by J.H. Prevost, 6/20/90, (PB91-110197, A13, MF-A02).
- NCEER-90-0013 "Secondary Systems in Base-Isolated Structures: Experimental Investigation, Stochastic Response and Stochastic Sensitivity," by G.D. Manolis, G. Juhn, M.C. Constantinou and A.M. Reinhorn, 7/1/90, (PB91-110320, A08, MF-A01).
- NCEER-90-0014 "Seismic Behavior of Lightly-Reinforced Concrete Column and Beam-Column Joint Details," by S.P. Pessiki, C.H. Conley, P. Gergely and R.N. White, 8/22/90, (PB91-108795, A11, MF-A02).
- NCEER-90-0015 "Two Hybrid Control Systems for Building Structures Under Strong Earthquakes," by J.N. Yang and A. Daniellians, 6/29/90, (PB91-125393, A04, MF-A01).
- NCEER-90-0016 "Instantaneous Optimal Control with Acceleration and Velocity Feedback," by J.N. Yang and Z. Li, 6/29/90, (PB91-125401, A03, MF-A01).
- NCEER-90-0017 "Reconnaissance Report on the Northern Iran Earthquake of June 21, 1990," by M. Mehrain, 10/4/90, (PB91-125377, A03, MF-A01).
- NCEER-90-0018 "Evaluation of Liquefaction Potential in Memphis and Shelby County," by T.S. Chang, P.S. Tang, C.S. Lee and H. Hwang, 8/10/90, (PB91-125427, A09, MF-A01).
- NCEER-90-0019 "Experimental and Analytical Study of a Combined Sliding Disc Bearing and Helical Steel Spring Isolation System," by M.C. Constantinou, A.S. Mokha and A.M. Reinhorn, 10/4/90, (PB91-125385, A06, MF-A01). This report is available only through NTIS (see address given above).
- NCEER-90-0020 "Experimental Study and Analytical Prediction of Earthquake Response of a Sliding Isolation System with a Spherical Surface," by A.S. Mokha, M.C. Constantinou and A.M. Reinhorn, 10/11/90, (PB91-125419, A05, MF-A01).
- NCEER-90-0021 "Dynamic Interaction Factors for Floating Pile Groups," by G. Gazetas, K. Fan, A. Kaynia and E. Kausel, 9/10/90, (PB91-170381, A05, MF-A01).
- NCEER-90-0022 "Evaluation of Seismic Damage Indices for Reinforced Concrete Structures," by S. Rodriguez-Gomez and A.S. Cakmak, 9/30/90, PB91-171322, A06, MF-A01).
- NCEER-90-0023 "Study of Site Response at a Selected Memphis Site," by H. Desai, S. Ahmad, E.S. Gazetas and M.R. Oh, 10/11/90, (PB91-196857, A03, MF-A01).
- NCEER-90-0024 "A User's Guide to Strongmo: Version 1.0 of NCEER's Strong-Motion Data Access Tool for PCs and Terminals," by P.A. Friberg and C.A.T. Susch, 11/15/90, (PB91-171272, A03, MF-A01).
- NCEER-90-0025 "A Three-Dimensional Analytical Study of Spatial Variability of Seismic Ground Motions," by L-L. Hong and A.H.-S. Ang, 10/30/90, (PB91-170399, A09, MF-A01).
- NCEER-90-0026 "MUMOID User's Guide - A Program for the Identification of Modal Parameters," by S. Rodriguez-Gomez and E. DiPasquale, 9/30/90, (PB91-171298, A04, MF-A01).
- NCEER-90-0027 "SARCF-II User's Guide - Seismic Analysis of Reinforced Concrete Frames," by S. Rodriguez-Gomez, Y.S. Chung and C. Meyer, 9/30/90, (PB91-171280, A05, MF-A01).
- NCEER-90-0028 "Viscous Dampers: Testing, Modeling and Application in Vibration and Seismic Isolation," by N. Makris and M.C. Constantinou, 12/20/90 (PB91-190561, A06, MF-A01).
- NCEER-90-0029 "Soil Effects on Earthquake Ground Motions in the Memphis Area," by H. Hwang, C.S. Lee, K.W. Ng and T.S. Chang, 8/2/90, (PB91-190751, A05, MF-A01).

- NCEER-91-0001 "Proceedings from the Third Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction, December 17-19, 1990," edited by T.D. O'Rourke and M. Hamada, 2/1/91, (PB91-179259, A99, MF-A04).
- NCEER-91-0002 "Physical Space Solutions of Non-Proportionally Damped Systems," by M. Tong, Z. Liang and G.C. Lee, 1/15/91, (PB91-179242, A04, MF-A01).
- NCEER-91-0003 "Seismic Response of Single Piles and Pile Groups," by K. Fan and G. Gazetas, 1/10/91, (PB92-174994, A04, MF-A01).
- NCEER-91-0004 "Damping of Structures: Part 1 - Theory of Complex Damping," by Z. Liang and G. Lee, 10/10/91, (PB92-197235, A12, MF-A03).
- NCEER-91-0005 "3D-BASIS - Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures: Part II," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 2/28/91, (PB91-190553, A07, MF-A01). This report has been replaced by NCEER-93-0011.
- NCEER-91-0006 "A Multidimensional Hysteretic Model for Plasticity Deforming Metals in Energy Absorbing Devices," by E.J. Graesser and F.A. Cozzarelli, 4/9/91, (PB92-108364, A04, MF-A01).
- NCEER-91-0007 "A Framework for Customizable Knowledge-Based Expert Systems with an Application to a KBES for Evaluating the Seismic Resistance of Existing Buildings," by E.G. Ibarra-Anaya and S.J. Fennes, 4/9/91, (PB91-210930, A08, MF-A01).
- NCEER-91-0008 "Nonlinear Analysis of Steel Frames with Semi-Rigid Connections Using the Capacity Spectrum Method," by G.G. Deierlein, S-H. Hsieh, Y-J. Shen and J.F. Abel, 7/2/91, (PB92-113828, A05, MF-A01).
- NCEER-91-0009 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/30/91, (PB91-212142, A06, MF-A01). This report has been replaced by NCEER-92-0018.
- NCEER-91-0010 "Phase Wave Velocities and Displacement Phase Differences in a Harmonically Oscillating Pile," by N. Makris and G. Gazetas, 7/8/91, (PB92-108356, A04, MF-A01).
- NCEER-91-0011 "Dynamic Characteristics of a Full-Size Five-Story Steel Structure and a 2/5 Scale Model," by K.C. Chang, G.C. Yao, G.C. Lee, D.S. Hao and Y.C. Yeh," 7/2/91, (PB93-116648, A06, MF-A02).
- NCEER-91-0012 "Seismic Response of a 2/5 Scale Steel Structure with Added Viscoelastic Dampers," by K.C. Chang, T.T. Soong, S-T. Oh and M.L. Lai, 5/17/91, (PB92-110816, A05, MF-A01).
- NCEER-91-0013 "Earthquake Response of Retaining Walls; Full-Scale Testing and Computational Modeling," by S. Alampalli and A-W.M. Elgamel, 6/20/91, to be published.
- NCEER-91-0014 "3D-BASIS-M: Nonlinear Dynamic Analysis of Multiple Building Base Isolated Structures," by P.C. Tsopelas, S. Nagarajaiah, M.C. Constantinou and A.M. Reinhorn, 5/28/91, (PB92-113885, A09, MF-A02).
- NCEER-91-0015 "Evaluation of SEAOC Design Requirements for Sliding Isolated Structures," by D. Theodossiou and M.C. Constantinou, 6/10/91, (PB92-114602, A11, MF-A03).
- NCEER-91-0016 "Closed-Loop Modal Testing of a 27-Story Reinforced Concrete Flat Plate-Core Building," by H.R. Somaprasad, T. Toksoy, H. Yoshiyuki and A.E. Aktan, 7/15/91, (PB92-129980, A07, MF-A02).
- NCEER-91-0017 "Shake Table Test of a 1/6 Scale Two-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91, (PB92-222447, A06, MF-A02).
- NCEER-91-0018 "Shake Table Test of a 1/8 Scale Three-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91, (PB93-116630, A08, MF-A02).
- NCEER-91-0019 "Transfer Functions for Rigid Rectangular Foundations," by A.S. Veletsos, A.M. Prasad and W.H. Wu, 7/31/91, to be published.

- NCEER-91-0020 "Hybrid Control of Seismic-Excited Nonlinear and Inelastic Structural Systems," by J.N. Yang, Z. Li and A. Daniellians, 8/1/91, (PB92-143171, A06, MF-A02).
- NCEER-91-0021 "The NCEER-91 Earthquake Catalog: Improved Intensity-Based Magnitudes and Recurrence Relations for U.S. Earthquakes East of New Madrid," by L. Seeber and J.G. Armbruster, 8/28/91, (PB92-176742, A06, MF-A02).
- NCEER-91-0022 "Proceedings from the Implementation of Earthquake Planning and Education in Schools: The Need for Change - The Roles of the Changemakers," by K.E.K. Ross and F. Winslow, 7/23/91, (PB92-129998, A12, MF-A03).
- NCEER-91-0023 "A Study of Reliability-Based Criteria for Seismic Design of Reinforced Concrete Frame Buildings," by H.H.M. Hwang and H-M. Hsu, 8/10/91, (PB92-140235, A09, MF-A02).
- NCEER-91-0024 "Experimental Verification of a Number of Structural System Identification Algorithms," by R.G. Ghanem, H. Gavin and M. Shinozuka, 9/18/91, (PB92-176577, A18, MF-A04).
- NCEER-91-0025 "Probabilistic Evaluation of Liquefaction Potential," by H.H.M. Hwang and C.S. Lee, 11/25/91, (PB92-143429, A05, MF-A01).
- NCEER-91-0026 "Instantaneous Optimal Control for Linear, Nonlinear and Hysteretic Structures - Stable Controllers," by J.N. Yang and Z. Li, 11/15/91, (PB92-163807, A04, MF-A01).
- NCEER-91-0027 "Experimental and Theoretical Study of a Sliding Isolation System for Bridges," by M.C. Constantinou, A. Kartoum, A.M. Reinhorn and P. Bradford, 11/15/91, (PB92-176973, A10, MF-A03).
- NCEER-92-0001 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 1: Japanese Case Studies," Edited by M. Hamada and T. O'Rourke, 2/17/92, (PB92-197243, A18, MF-A04).
- NCEER-92-0002 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 2: United States Case Studies," Edited by T. O'Rourke and M. Hamada, 2/17/92, (PB92-197250, A20, MF-A04).
- NCEER-92-0003 "Issues in Earthquake Education," Edited by K. Ross, 2/3/92, (PB92-222389, A07, MF-A02).
- NCEER-92-0004 "Proceedings from the First U.S. - Japan Workshop on Earthquake Protective Systems for Bridges," Edited by I.G. Buckle, 2/4/92, (PB94-142239, A99, MF-A06).
- NCEER-92-0005 "Seismic Ground Motion from a Haskell-Type Source in a Multiple-Layered Half-Space," A.P. Theoharis, G. Deodatis and M. Shinozuka, 1/2/92, to be published.
- NCEER-92-0006 "Proceedings from the Site Effects Workshop," Edited by R. Whitman, 2/29/92, (PB92-197201, A04, MF-A01).
- NCEER-92-0007 "Engineering Evaluation of Permanent Ground Deformations Due to Seismically-Induced Liquefaction," by M.H. Baziar, R. Dobry and A-W.M. Elgamel, 3/24/92, (PB92-222421, A13, MF-A03).
- NCEER-92-0008 "A Procedure for the Seismic Evaluation of Buildings in the Central and Eastern United States," by C.D. Poland and J.O. Malley, 4/2/92, (PB92-222439, A20, MF-A04).
- NCEER-92-0009 "Experimental and Analytical Study of a Hybrid Isolation System Using Friction Controllable Sliding Bearings," by M.Q. Feng, S. Fujii and M. Shinozuka, 5/15/92, (PB93-150282, A06, MF-A02).
- NCEER-92-0010 "Seismic Resistance of Slab-Column Connections in Existing Non-Ductile Flat-Plate Buildings," by A.J. Durrani and Y. Du, 5/18/92, (PB93-116812, A06, MF-A02).
- NCEER-92-0011 "The Hysteretic and Dynamic Behavior of Brick Masonry Walls Upgraded by Ferrocement Coatings Under Cyclic Loading and Strong Simulated Ground Motion," by H. Lee and S.P. Prawl, 5/11/92, to be published.
- NCEER-92-0012 "Study of Wire Rope Systems for Seismic Protection of Equipment in Buildings," by G.F. Demetriades, M.C. Constantinou and A.M. Reinhorn, 5/20/92, (PB93-116655, A08, MF-A02).



- NCEER-92-0013 "Shape Memory Structural Dampers: Material Properties, Design and Seismic Testing," by P.R. Witting and F.A. Cozzarelli, 5/26/92, (PB93-116663, A05, MF-A01).
- NCEER-92-0014 "Longitudinal Permanent Ground Deformation Effects on Buried Continuous Pipelines," by M.J. O'Rourke, and C. Nordberg, 6/15/92, (PB93-116671, A08, MF-A02).
- NCEER-92-0015 "A Simulation Method for Stationary Gaussian Random Functions Based on the Sampling Theorem," by M. Grigoriu and S. Balopoulou, 6/11/92, (PB93-127496, A05, MF-A01).
- NCEER-92-0016 "Gravity-Load-Designed Reinforced Concrete Buildings: Seismic Evaluation of Existing Construction and Detailing Strategies for Improved Seismic Resistance," by G.W. Hoffmann, S.K. Kunnath, A.M. Reinhorn and J.B. Mander, 7/15/92, (PB94-142007, A08, MF-A02).
- NCEER-92-0017 "Observations on Water System and Pipeline Performance in the Limón Area of Costa Rica Due to the April 22, 1991 Earthquake," by M. O'Rourke and D. Ballantyne, 6/30/92, (PB93-126811, A06, MF-A02).
- NCEER-92-0018 "Fourth Edition of Earthquake Education Materials for Grades K-12," Edited by K.E.K. Ross, 8/10/92, (PB93-114023, A07, MF-A02).
- NCEER-92-0019 "Proceedings from the Fourth Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction," Edited by M. Hamada and T.D. O'Rourke, 8/12/92, (PB93-163939, A99, MF-E11).
- NCEER-92-0020 "Active Bracing System: A Full Scale Implementation of Active Control," by A.M. Reinhorn, T.T. Soong, R.C. Lin, M.A. Riley, Y.P. Wang, S. Aizawa and M. Higashino, 8/14/92, (PB93-127512, A06, MF-A02).
- NCEER-92-0021 "Empirical Analysis of Horizontal Ground Displacement Generated by Liquefaction-Induced Lateral Spreads," by S.F. Bartlett and T.L. Youd, 8/17/92, (PB93-188241, A06, MF-A02).
- NCEER-92-0022 "IDARC Version 3.0: Inelastic Damage Analysis of Reinforced Concrete Structures," by S.K. Kunnath, A.M. Reinhorn and R.F. Lobo, 8/31/92, (PB93-227502, A07, MF-A02).
- NCEER-92-0023 "A Semi-Empirical Analysis of Strong-Motion Peaks in Terms of Seismic Source, Propagation Path and Local Site Conditions, by M. Kamiyama, M.J. O'Rourke and R. Flores-Berrones, 9/9/92, (PB93-150266, A08, MF-A02).
- NCEER-92-0024 "Seismic Behavior of Reinforced Concrete Frame Structures with Nonductile Details, Part I: Summary of Experimental Findings of Full Scale Beam-Column Joint Tests," by A. Beres, R.N. White and P. Gergely, 9/30/92, (PB93-227783, A05, MF-A01).
- NCEER-92-0025 "Experimental Results of Repaired and Retrofitted Beam-Column Joint Tests in Lightly Reinforced Concrete Frame Buildings," by A. Beres, S. El-Borgi, R.N. White and P. Gergely, 10/29/92, (PB93-227791, A05, MF-A01).
- NCEER-92-0026 "A Generalization of Optimal Control Theory: Linear and Nonlinear Structures," by J.N. Yang, Z. Li and S. Vongchavalitkul, 11/2/92, (PB93-188621, A05, MF-A01).
- NCEER-92-0027 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part I - Design and Properties of a One-Third Scale Model Structure," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, (PB94-104502, A08, MF-A02).
- NCEER-92-0028 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part II - Experimental Performance of Subassemblages," by L.E. Aycaardi, J.B. Mander and A.M. Reinhorn, 12/1/92, (PB94-104510, A08, MF-A02).
- NCEER-92-0029 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part III - Experimental Performance and Analytical Study of a Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, (PB93-227528, A09, MF-A01).

- NCEER-92-0030 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part I - Experimental Performance of Retrofitted Subassemblages," by D. Choudhuri, J.B. Mander and A.M. Reinhorn, 12/8/92, (PB93-198307, A07, MF-A02).
- NCEER-92-0031 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part II - Experimental Performance and Analytical Study of a Retrofitted Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/8/92, (PB93-198315, A09, MF-A03).
- NCEER-92-0032 "Experimental and Analytical Investigation of Seismic Response of Structures with Supplemental Fluid Viscous Dampers," by M.C. Constantinou and M.D. Symans, 12/21/92, (PB93-191435, A10, MF-A03). This report is available only through NTIS (see address given above).
- NCEER-92-0033 "Reconnaissance Report on the Cairo, Egypt Earthquake of October 12, 1992," by M. Khater, 12/23/92, (PB93-188621, A03, MF-A01).
- NCEER-92-0034 "Low-Level Dynamic Characteristics of Four Tall Flat-Plate Buildings in New York City," by H. Gavin, S. Yuan, J. Grossman, E. Pekelis and K. Jacob, 12/28/92, (PB93-188217, A07, MF-A02).
- NCEER-93-0001 "An Experimental Study on the Seismic Performance of Brick-Infilled Steel Frames With and Without Retrofit," by J.B. Mander, B. Nair, K. Wojtkowski and J. Ma, 1/29/93, (PB93-227510, A07, MF-A02).
- NCEER-93-0002 "Social Accounting for Disaster Preparedness and Recovery Planning," by S. Cole, E. Pantoja and V. Razak, 2/22/93, (PB94-142114, A12, MF-A03).
- NCEER-93-0003 "Assessment of 1991 NEHRP Provisions for Nonstructural Components and Recommended Revisions," by T.T. Soong, G. Chen, Z. Wu, R-H. Zhang and M. Grigoriu, 3/1/93, (PB93-188639, A06, MF-A02).
- NCEER-93-0004 "Evaluation of Static and Response Spectrum Analysis Procedures of SEAOC/UBC for Seismic Isolated Structures," by C.W. Winters and M.C. Constantinou, 3/23/93, (PB93-198299, A10, MF-A03).
- NCEER-93-0005 "Earthquakes in the Northeast - Are We Ignoring the Hazard? A Workshop on Earthquake Science and Safety for Educators," edited by K.E.K. Ross, 4/2/93, (PB94-103066, A09, MF-A02).
- NCEER-93-0006 "Inelastic Response of Reinforced Concrete Structures with Viscoelastic Braces," by R.F. Lobo, J.M. Bracci, K.L. Shen, A.M. Reinhorn and T.T. Soong, 4/5/93, (PB93-227486, A05, MF-A02).
- NCEER-93-0007 "Seismic Testing of Installation Methods for Computers and Data Processing Equipment," by K. Kosar, T.T. Soong, K.L. Shen, J.A. HoLung and Y.K. Lin, 4/12/93, (PB93-198299, A07, MF-A02).
- NCEER-93-0008 "Retrofit of Reinforced Concrete Frames Using Added Dampers," by A. Reinhorn, M. Constantinou and C. Li, to be published.
- NCEER-93-0009 "Seismic Behavior and Design Guidelines for Steel Frame Structures with Added Viscoelastic Dampers," by K.C. Chang, M.L. Lai, T.T. Soong, D.S. Hao and Y.C. Yeh, 5/1/93, (PB94-141959, A07, MF-A02).
- NCEER-93-0010 "Seismic Performance of Shear-Critical Reinforced Concrete Bridge Piers," by J.B. Mander, S.M. Waheed, M.T.A. Chaudhary and S.S. Chen, 5/12/93, (PB93-227494, A08, MF-A02).
- NCEER-93-0011 "3D-BASIS-TABS: Computer Program for Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures," by S. Nagarajaiah, C. Li, A.M. Reinhorn and M.C. Constantinou, 8/2/93, (PB94-141819, A09, MF-A02).
- NCEER-93-0012 "Effects of Hydrocarbon Spills from an Oil Pipeline Break on Ground Water," by O.J. Helweg and H.H.M. Hwang, 8/3/93, (PB94-141942, A06, MF-A02).
- NCEER-93-0013 "Simplified Procedures for Seismic Design of Nonstructural Components and Assessment of Current Code Provisions," by M.P. Singh, L.E. Suarez, E.E. Matheu and G.O. Maldonado, 8/4/93, (PB94-141827, A09, MF-A02).
- NCEER-93-0014 "An Energy Approach to Seismic Analysis and Design of Secondary Systems," by G. Chen and T.T. Soong, 8/6/93, (PB94-142767, A11, MF-A03).

- NCEER-93-0015 "Proceedings from School Sites: Becoming Prepared for Earthquakes - Commemorating the Third Anniversary of the Loma Prieta Earthquake," Edited by F.E. Winslow and K.E.K. Ross, 8/16/93, (PB94-154275, A16, MF-A02).
- NCEER-93-0016 "Reconnaissance Report of Damage to Historic Monuments in Cairo, Egypt Following the October 12, 1992 Dahshur Earthquake," by D. Sykora, D. Look, G. Croci, E. Karaesmen and E. Karaesmen, 8/19/93, (PB94-142221, A08, MF-A02).
- NCEER-93-0017 "The Island of Guam Earthquake of August 8, 1993," by S.W. Swan and S.K. Harris, 9/30/93, (PB94-141843, A04, MF-A01).
- NCEER-93-0018 "Engineering Aspects of the October 12, 1992 Egyptian Earthquake," by A.W. Elgamal, M. Amer, K. Adalier and A. Abul-Fadl, 10/7/93, (PB94-141983, A05, MF-A01).
- NCEER-93-0019 "Development of an Earthquake Motion Simulator and its Application in Dynamic Centrifuge Testing," by I. Krstelj, Supervised by J.H. Prevost, 10/23/93, (PB94-181773, A-10, MF-A03).
- NCEER-93-0020 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a Friction Pendulum System (FPS)," by M.C. Constantinou, P. Tsopelas, Y-S. Kim and S. Okamoto, 11/1/93, (PB94-142775, A08, MF-A02).
- NCEER-93-0021 "Finite Element Modeling of Elastomeric Seismic Isolation Bearings," by L.J. Billings, Supervised by R. Shepherd, 11/8/93, to be published.
- NCEER-93-0022 "Seismic Vulnerability of Equipment in Critical Facilities: Life-Safety and Operational Consequences," by K. Porter, G.S. Johnson, M.M. Zadeh, C. Scawthorn and S. Eder, 11/24/93, (PB94-181765, A16, MF-A03).
- NCEER-93-0023 "Hokkaido Nansei-oki, Japan Earthquake of July 12, 1993, by P.I. Yanev and C.R. Scawthorn, 12/23/93, (PB94-181500, A07, MF-A01).
- NCEER-94-0001 "An Evaluation of Seismic Serviceability of Water Supply Networks with Application to the San Francisco Auxiliary Water Supply System," by I. Markov, Supervised by M. Grigoriu and T. O'Rourke, 1/21/94, (PB94-204013, A07, MF-A02).
- NCEER-94-0002 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of Systems Consisting of Sliding Bearings, Rubber Restoring Force Devices and Fluid Dampers," Volumes I and II, by P. Tsopelas, S. Okamoto, M.C. Constantinou, D. Ozaki and S. Fujii, 2/4/94, (PB94-181740, A09, MF-A02 and PB94-181757, A12, MF-A03).
- NCEER-94-0003 "A Markov Model for Local and Global Damage Indices in Seismic Analysis," by S. Rahman and M. Grigoriu, 2/18/94, (PB94-206000, A12, MF-A03).
- NCEER-94-0004 "Proceedings from the NCEER Workshop on Seismic Response of Masonry Infills," edited by D.P. Abrams, 3/1/94, (PB94-180783, A07, MF-A02).
- NCEER-94-0005 "The Northridge, California Earthquake of January 17, 1994: General Reconnaissance Report," edited by J.D. Goltz, 3/11/94, (PB94-193943, A10, MF-A03).
- NCEER-94-0006 "Seismic Energy Based Fatigue Damage Analysis of Bridge Columns: Part I - Evaluation of Seismic Capacity," by G.A. Chang and J.B. Mander, 3/14/94, (PB94-219185, A11, MF-A03).
- NCEER-94-0007 "Seismic Isolation of Multi-Story Frame Structures Using Spherical Sliding Isolation Systems," by T.M. Al-Hussaini, V.A. Zayas and M.C. Constantinou, 3/17/94, (PB94-193745, A09, MF-A02).
- NCEER-94-0008 "The Northridge, California Earthquake of January 17, 1994: Performance of Highway Bridges," edited by I.G. Buckle, 3/24/94, (PB94-193851, A06, MF-A02).
- NCEER-94-0009 "Proceedings of the Third U.S.-Japan Workshop on Earthquake Protective Systems for Bridges," edited by I.G. Buckle and I. Friedland, 3/31/94, (PB94-195815, A99, MF-A06).

- NCEER-94-0010 "3D-BASIS-ME: Computer Program for Nonlinear Dynamic Analysis of Seismically Isolated Single and Multiple Structures and Liquid Storage Tanks," by P.C. Tsopelas, M.C. Constantinou and A.M. Reinhorn, 4/12/94, (PB94-204922, A09, MF-A02).
- NCEER-94-0011 "The Northridge, California Earthquake of January 17, 1994: Performance of Gas Transmission Pipelines," by T.D. O'Rourke and M.C. Palmer, 5/16/94, (PB94-204989, A05, MF-A01).
- NCEER-94-0012 "Feasibility Study of Replacement Procedures and Earthquake Performance Related to Gas Transmission Pipelines," by T.D. O'Rourke and M.C. Palmer, 5/25/94, (PB94-206638, A09, MF-A02).
- NCEER-94-0013 "Seismic Energy Based Fatigue Damage Analysis of Bridge Columns: Part II - Evaluation of Seismic Demand," by G.A. Chang and J.B. Mander, 6/1/94, (PB95-18106, A08, MF-A02).
- NCEER-94-0014 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a System Consisting of Sliding Bearings and Fluid Restoring Force/Damping Devices," by P. Tsopelas and M.C. Constantinou, 6/13/94, (PB94-219144, A10, MF-A03).
- NCEER-94-0015 "Generation of Hazard-Consistent Fragility Curves for Seismic Loss Estimation Studies," by H. Hwang and J-R. Huo, 6/14/94, (PB95-181996, A09, MF-A02).
- NCEER-94-0016 "Seismic Study of Building Frames with Added Energy-Absorbing Devices," by W.S. Pong, C.S. Tsai and G.C. Lee, 6/20/94, (PB94-219136, A10, A03).
- NCEER-94-0017 "Sliding Mode Control for Seismic-Excited Linear and Nonlinear Civil Engineering Structures," by J. Yang, J. Wu, A. Agrawal and Z. Li, 6/21/94, (PB95-138483, A06, MF-A02).
- NCEER-94-0018 "3D-BASIS-TABS Version 2.0: Computer Program for Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures," by A.M. Reinhorn, S. Nagarajaiah, M.C. Constantinou, P. Tsopelas and R. Li, 6/22/94, (PB95-182176, A08, MF-A02).
- NCEER-94-0019 "Proceedings of the International Workshop on Civil Infrastructure Systems: Application of Intelligent Systems and Advanced Materials on Bridge Systems," Edited by G.C. Lee and K.C. Chang, 7/18/94, (PB95-252474, A20, MF-A04).
- NCEER-94-0020 "Study of Seismic Isolation Systems for Computer Floors," by V. Lambrou and M.C. Constantinou, 7/19/94, (PB95-138533, A10, MF-A03).
- NCEER-94-0021 "Proceedings of the U.S.-Italian Workshop on Guidelines for Seismic Evaluation and Rehabilitation of Unreinforced Masonry Buildings," Edited by D.P. Abrams and G.M. Calvi, 7/20/94, (PB95-138749, A13, MF-A03).
- NCEER-94-0022 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a System Consisting of Lubricated PTFE Sliding Bearings and Mild Steel Dampers," by P. Tsopelas and M.C. Constantinou, 7/22/94, (PB95-182184, A08, MF-A02).
- NCEER-94-0023 "Development of Reliability-Based Design Criteria for Buildings Under Seismic Load," by Y.K. Wen, H. Hwang and M. Shinozuka, 8/1/94, (PB95-211934, A08, MF-A02).
- NCEER-94-0024 "Experimental Verification of Acceleration Feedback Control Strategies for an Active Tendon System," by S.J. Dyke, B.F. Spencer, Jr., P. Quast, M.K. Sain, D.C. Kaspari, Jr. and T.T. Soong, 8/29/94, (PB95-212320, A05, MF-A01).
- NCEER-94-0025 "Seismic Retrofitting Manual for Highway Bridges," Edited by I.G. Buckle and I.F. Friedland, published by the Federal Highway Administration (PB95-212676, A15, MF-A03).
- NCEER-94-0026 "Proceedings from the Fifth U.S.-Japan Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures Against Soil Liquefaction," Edited by T.D. O'Rourke and M. Hamada, 11/7/94, (PB95-220802, A99, MF-E08).

- NCEER-95-0001 “Experimental and Analytical Investigation of Seismic Retrofit of Structures with Supplemental Damping: Part 1 - Fluid Viscous Damping Devices,” by A.M. Reinhorn, C. Li and M.C. Constantinou, 1/3/95, (PB95-266599, A09, MF-A02).
- NCEER-95-0002 “Experimental and Analytical Study of Low-Cycle Fatigue Behavior of Semi-Rigid Top-And-Seat Angle Connections,” by G. Pekcan, J.B. Mander and S.S. Chen, 1/5/95, (PB95-220042, A07, MF-A02).
- NCEER-95-0003 “NCEER-ATC Joint Study on Fragility of Buildings,” by T. Anagnos, C. Rojahn and A.S. Kiremidjian, 1/20/95, (PB95-220026, A06, MF-A02).
- NCEER-95-0004 “Nonlinear Control Algorithms for Peak Response Reduction,” by Z. Wu, T.T. Soong, V. Gattulli and R.C. Lin, 2/16/95, (PB95-220349, A05, MF-A01).
- NCEER-95-0005 “Pipeline Replacement Feasibility Study: A Methodology for Minimizing Seismic and Corrosion Risks to Underground Natural Gas Pipelines,” by R.T. Eguchi, H.A. Seligson and D.G. Honegger, 3/2/95, (PB95-252326, A06, MF-A02).
- NCEER-95-0006 “Evaluation of Seismic Performance of an 11-Story Frame Building During the 1994 Northridge Earthquake,” by F. Naeim, R. DiSulio, K. Benuska, A. Reinhorn and C. Li, to be published.
- NCEER-95-0007 “Prioritization of Bridges for Seismic Retrofitting,” by N. Basöz and A.S. Kiremidjian, 4/24/95, (PB95-252300, A08, MF-A02).
- NCEER-95-0008 “Method for Developing Motion Damage Relationships for Reinforced Concrete Frames,” by A. Singhal and A.S. Kiremidjian, 5/11/95, (PB95-266607, A06, MF-A02).
- NCEER-95-0009 “Experimental and Analytical Investigation of Seismic Retrofit of Structures with Supplemental Damping: Part II - Friction Devices,” by C. Li and A.M. Reinhorn, 7/6/95, (PB96-128087, A11, MF-A03).
- NCEER-95-0010 “Experimental Performance and Analytical Study of a Non-Ductile Reinforced Concrete Frame Structure Retrofitted with Elastomeric Spring Dampers,” by G. Pekcan, J.B. Mander and S.S. Chen, 7/14/95, (PB96-137161, A08, MF-A02).
- NCEER-95-0011 “Development and Experimental Study of Semi-Active Fluid Damping Devices for Seismic Protection of Structures,” by M.D. Symans and M.C. Constantinou, 8/3/95, (PB96-136940, A23, MF-A04).
- NCEER-95-0012 “Real-Time Structural Parameter Modification (RSPM): Development of Innervated Structures,” by Z. Liang, M. Tong and G.C. Lee, 4/11/95, (PB96-137153, A06, MF-A01).
- NCEER-95-0013 “Experimental and Analytical Investigation of Seismic Retrofit of Structures with Supplemental Damping: Part III - Viscous Damping Walls,” by A.M. Reinhorn and C. Li, 10/1/95, (PB96-176409, A11, MF-A03).
- NCEER-95-0014 “Seismic Fragility Analysis of Equipment and Structures in a Memphis Electric Substation,” by J-R. Huo and H.H.M. Hwang, 8/10/95, (PB96-128087, A09, MF-A02).
- NCEER-95-0015 “The Hanshin-Awaji Earthquake of January 17, 1995: Performance of Lifelines,” Edited by M. Shinozuka, 11/3/95, (PB96-176383, A15, MF-A03).
- NCEER-95-0016 “Highway Culvert Performance During Earthquakes,” by T.L. Youd and C.J. Beckman, available as NCEER-96-0015.
- NCEER-95-0017 “The Hanshin-Awaji Earthquake of January 17, 1995: Performance of Highway Bridges,” Edited by I.G. Buckle, 12/1/95, to be published.
- NCEER-95-0018 “Modeling of Masonry Infill Panels for Structural Analysis,” by A.M. Reinhorn, A. Madan, R.E. Valles, Y. Reichmann and J.B. Mander, 12/8/95, (PB97-110886, MF-A01, A06).
- NCEER-95-0019 “Optimal Polynomial Control for Linear and Nonlinear Structures,” by A.K. Agrawal and J.N. Yang, 12/11/95, (PB96-168737, A07, MF-A02).

- NCEER-95-0020 "Retrofit of Non-Ductile Reinforced Concrete Frames Using Friction Dampers," by R.S. Rao, P. Gergely and R.N. White, 12/22/95, (PB97-133508, A10, MF-A02).
- NCEER-95-0021 "Parametric Results for Seismic Response of Pile-Supported Bridge Bents," by G. Mylonakis, A. Nikolaou and G. Gazetas, 12/22/95, (PB97-100242, A12, MF-A03).
- NCEER-95-0022 "Kinematic Bending Moments in Seismically Stressed Piles," by A. Nikolaou, G. Mylonakis and G. Gazetas, 12/23/95, (PB97-113914, MF-A03, A13).
- NCEER-96-0001 "Dynamic Response of Unreinforced Masonry Buildings with Flexible Diaphragms," by A.C. Costley and D.P. Abrams, 10/10/96, (PB97-133573, MF-A03, A15).
- NCEER-96-0002 "State of the Art Review: Foundations and Retaining Structures," by I. Po Lam, to be published.
- NCEER-96-0003 "Ductility of Rectangular Reinforced Concrete Bridge Columns with Moderate Confinement," by N. Wehbe, M. Saiidi, D. Sanders and B. Douglas, 11/7/96, (PB97-133557, A06, MF-A02).
- NCEER-96-0004 "Proceedings of the Long-Span Bridge Seismic Research Workshop," edited by I.G. Buckle and I.M. Friedland, to be published.
- NCEER-96-0005 "Establish Representative Pier Types for Comprehensive Study: Eastern United States," by J. Kulicki and Z. Prucz, 5/28/96, (PB98-119217, A07, MF-A02).
- NCEER-96-0006 "Establish Representative Pier Types for Comprehensive Study: Western United States," by R. Imbsen, R.A. Schamber and T.A. Osterkamp, 5/28/96, (PB98-118607, A07, MF-A02).
- NCEER-96-0007 "Nonlinear Control Techniques for Dynamical Systems with Uncertain Parameters," by R.G. Ghanem and M.I. Bujakov, 5/27/96, (PB97-100259, A17, MF-A03).
- NCEER-96-0008 "Seismic Evaluation of a 30-Year Old Non-Ductile Highway Bridge Pier and Its Retrofit," by J.B. Mander, B. Mahmoodzadegan, S. Bhadra and S.S. Chen, 5/31/96, (PB97-110902, MF-A03, A10).
- NCEER-96-0009 "Seismic Performance of a Model Reinforced Concrete Bridge Pier Before and After Retrofit," by J.B. Mander, J.H. Kim and C.A. Ligozio, 5/31/96, (PB97-110910, MF-A02, A10).
- NCEER-96-0010 "IDARC2D Version 4.0: A Computer Program for the Inelastic Damage Analysis of Buildings," by R.E. Valles, A.M. Reinhorn, S.K. Kunnath, C. Li and A. Madan, 6/3/96, (PB97-100234, A17, MF-A03).
- NCEER-96-0011 "Estimation of the Economic Impact of Multiple Lifeline Disruption: Memphis Light, Gas and Water Division Case Study," by S.E. Chang, H.A. Seligson and R.T. Eguchi, 8/16/96, (PB97-133490, A11, MF-A03).
- NCEER-96-0012 "Proceedings from the Sixth Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures Against Soil Liquefaction, Edited by M. Hamada and T. O'Rourke, 9/11/96, (PB97-133581, A99, MF-A06).
- NCEER-96-0013 "Chemical Hazards, Mitigation and Preparedness in Areas of High Seismic Risk: A Methodology for Estimating the Risk of Post-Earthquake Hazardous Materials Release," by H.A. Seligson, R.T. Eguchi, K.J. Tierney and K. Richmond, 11/7/96, (PB97-133565, MF-A02, A08).
- NCEER-96-0014 "Response of Steel Bridge Bearings to Reversed Cyclic Loading," by J.B. Mander, D-K. Kim, S.S. Chen and G.J. Premus, 11/13/96, (PB97-140735, A12, MF-A03).
- NCEER-96-0015 "Highway Culvert Performance During Past Earthquakes," by T.L. Youd and C.J. Beckman, 11/25/96, (PB97-133532, A06, MF-A01).
- NCEER-97-0001 "Evaluation, Prevention and Mitigation of Pounding Effects in Building Structures," by R.E. Valles and A.M. Reinhorn, 2/20/97, (PB97-159552, A14, MF-A03).
- NCEER-97-0002 "Seismic Design Criteria for Bridges and Other Highway Structures," by C. Rojahn, R. Mayes, D.G. Anderson, J. Clark, J.H. Hom, R.V. Nutt and M.J. O'Rourke, 4/30/97, (PB97-194658, A06, MF-A03).

- NCEER-97-0003 "Proceedings of the U.S.-Italian Workshop on Seismic Evaluation and Retrofit," Edited by D.P. Abrams and G.M. Calvi, 3/19/97, (PB97-194666, A13, MF-A03).
- NCEER-97-0004 "Investigation of Seismic Response of Buildings with Linear and Nonlinear Fluid Viscous Dampers," by A.A. Seleemah and M.C. Constantinou, 5/21/97, (PB98-109002, A15, MF-A03).
- NCEER-97-0005 "Proceedings of the Workshop on Earthquake Engineering Frontiers in Transportation Facilities," edited by G.C. Lee and I.M. Friedland, 8/29/97, (PB98-128911, A25, MR-A04).
- NCEER-97-0006 "Cumulative Seismic Damage of Reinforced Concrete Bridge Piers," by S.K. Kunnath, A. El-Bahy, A. Taylor and W. Stone, 9/2/97, (PB98-108814, A11, MF-A03).
- NCEER-97-0007 "Structural Details to Accommodate Seismic Movements of Highway Bridges and Retaining Walls," by R.A. Imbsen, R.A. Schamber, E. Thorkildsen, A. Kartoum, B.T. Martin, T.N. Rosser and J.M. Kulicki, 9/3/97, (PB98-108996, A09, MF-A02).
- NCEER-97-0008 "A Method for Earthquake Motion-Damage Relationships with Application to Reinforced Concrete Frames," by A. Singhal and A.S. Kiremidjian, 9/10/97, (PB98-108988, A13, MF-A03).
- NCEER-97-0009 "Seismic Analysis and Design of Bridge Abutments Considering Sliding and Rotation," by K. Fishman and R. Richards, Jr., 9/15/97, (PB98-108897, A06, MF-A02).
- NCEER-97-0010 "Proceedings of the FHWA/NCEER Workshop on the National Representation of Seismic Ground Motion for New and Existing Highway Facilities," edited by I.M. Friedland, M.S. Power and R.L. Mayes, 9/22/97, (PB98-128903, A21, MF-A04).
- NCEER-97-0011 "Seismic Analysis for Design or Retrofit of Gravity Bridge Abutments," by K.L. Fishman, R. Richards, Jr. and R.C. Divito, 10/2/97, (PB98-128937, A08, MF-A02).
- NCEER-97-0012 "Evaluation of Simplified Methods of Analysis for Yielding Structures," by P. Tsopelas, M.C. Constantinou, C.A. Kircher and A.S. Whittaker, 10/31/97, (PB98-128929, A10, MF-A03).
- NCEER-97-0013 "Seismic Design of Bridge Columns Based on Control and Repairability of Damage," by C-T. Cheng and J.B. Mander, 12/8/97, (PB98-144249, A11, MF-A03).
- NCEER-97-0014 "Seismic Resistance of Bridge Piers Based on Damage Avoidance Design," by J.B. Mander and C-T. Cheng, 12/10/97, (PB98-144223, A09, MF-A02).
- NCEER-97-0015 "Seismic Response of Nominally Symmetric Systems with Strength Uncertainty," by S. Balopoulou and M. Grigoriu, 12/23/97, (PB98-153422, A11, MF-A03).
- NCEER-97-0016 "Evaluation of Seismic Retrofit Methods for Reinforced Concrete Bridge Columns," by T.J. Wipf, F.W. Klaiber and F.M. Russo, 12/28/97, (PB98-144215, A12, MF-A03).
- NCEER-97-0017 "Seismic Fragility of Existing Conventional Reinforced Concrete Highway Bridges," by C.L. Mullen and A.S. Cakmak, 12/30/97, (PB98-153406, A08, MF-A02).
- NCEER-97-0018 "Loss Assessment of Memphis Buildings," edited by D.P. Abrams and M. Shinozuka, 12/31/97, (PB98-144231, A13, MF-A03).
- NCEER-97-0019 "Seismic Evaluation of Frames with Infill Walls Using Quasi-static Experiments," by K.M. Mosalam, R.N. White and P. Gergely, 12/31/97, (PB98-153455, A07, MF-A02).
- NCEER-97-0020 "Seismic Evaluation of Frames with Infill Walls Using Pseudo-dynamic Experiments," by K.M. Mosalam, R.N. White and P. Gergely, 12/31/97, (PB98-153430, A07, MF-A02).
- NCEER-97-0021 "Computational Strategies for Frames with Infill Walls: Discrete and Smeared Crack Analyses and Seismic Fragility," by K.M. Mosalam, R.N. White and P. Gergely, 12/31/97, (PB98-153414, A10, MF-A02).

- NCEER-97-0022 "Proceedings of the NCEER Workshop on Evaluation of Liquefaction Resistance of Soils," edited by T.L. Youd and I.M. Idriss, 12/31/97, (PB98-155617, A15, MF-A03).
- MCEER-98-0001 "Extraction of Nonlinear Hysteretic Properties of Seismically Isolated Bridges from Quick-Release Field Tests," by Q. Chen, B.M. Douglas, E.M. Maragakis and I.G. Buckle, 5/26/98, (PB99-118838, A06, MF-A01).
- MCEER-98-0002 "Methodologies for Evaluating the Importance of Highway Bridges," by A. Thomas, S. Eshenaur and J. Kulicki, 5/29/98, (PB99-118846, A10, MF-A02).
- MCEER-98-0003 "Capacity Design of Bridge Piers and the Analysis of Overstrength," by J.B. Mander, A. Dutta and P. Goel, 6/1/98, (PB99-118853, A09, MF-A02).
- MCEER-98-0004 "Evaluation of Bridge Damage Data from the Loma Prieta and Northridge, California Earthquakes," by N. Basoz and A. Kiremidjian, 6/2/98, (PB99-118861, A15, MF-A03).
- MCEER-98-0005 "Screening Guide for Rapid Assessment of Liquefaction Hazard at Highway Bridge Sites," by T. L. Youd, 6/16/98, (PB99-118879, A06, not available on microfiche).
- MCEER-98-0006 "Structural Steel and Steel/Concrete Interface Details for Bridges," by P. Ritchie, N. Kauh and J. Kulicki, 7/13/98, (PB99-118945, A06, MF-A01).
- MCEER-98-0007 "Capacity Design and Fatigue Analysis of Confined Concrete Columns," by A. Dutta and J.B. Mander, 7/14/98, (PB99-118960, A14, MF-A03).
- MCEER-98-0008 "Proceedings of the Workshop on Performance Criteria for Telecommunication Services Under Earthquake Conditions," edited by A.J. Schiff, 7/15/98, (PB99-118952, A08, MF-A02).
- MCEER-98-0009 "Fatigue Analysis of Unconfined Concrete Columns," by J.B. Mander, A. Dutta and J.H. Kim, 9/12/98, (PB99-123655, A10, MF-A02).
- MCEER-98-0010 "Centrifuge Modeling of Cyclic Lateral Response of Pile-Cap Systems and Seat-Type Abutments in Dry Sands," by A.D. Gadre and R. Dobry, 10/2/98, (PB99-123606, A13, MF-A03).
- MCEER-98-0011 "IDARC-BRIDGE: A Computational Platform for Seismic Damage Assessment of Bridge Structures," by A.M. Reinhorn, V. Simeonov, G. Mylonakis and Y. Reichman, 10/2/98, (PB99-162919, A15, MF-A03).
- MCEER-98-0012 "Experimental Investigation of the Dynamic Response of Two Bridges Before and After Retrofitting with Elastomeric Bearings," by D.A. Wendichansky, S.S. Chen and J.B. Mander, 10/2/98, (PB99-162927, A15, MF-A03).
- MCEER-98-0013 "Design Procedures for Hinge Restrainers and Hinge Sear Width for Multiple-Frame Bridges," by R. Des Roches and G.L. Fenves, 11/3/98, (PB99-140477, A13, MF-A03).
- MCEER-98-0014 "Response Modification Factors for Seismically Isolated Bridges," by M.C. Constantinou and J.K. Quarshie, 11/3/98, (PB99-140485, A14, MF-A03).
- MCEER-98-0015 "Proceedings of the U.S.-Italy Workshop on Seismic Protective Systems for Bridges," edited by I.M. Friedland and M.C. Constantinou, 11/3/98, (PB2000-101711, A22, MF-A04).
- MCEER-98-0016 "Appropriate Seismic Reliability for Critical Equipment Systems: Recommendations Based on Regional Analysis of Financial and Life Loss," by K. Porter, C. Scawthorn, C. Taylor and N. Blais, 11/10/98, (PB99-157265, A08, MF-A02).
- MCEER-98-0017 "Proceedings of the U.S. Japan Joint Seminar on Civil Infrastructure Systems Research," edited by M. Shinozuka and A. Rose, 11/12/98, (PB99-156713, A16, MF-A03).
- MCEER-98-0018 "Modeling of Pile Footings and Drilled Shafts for Seismic Design," by I. PoLam, M. Kapuskar and D. Chaudhuri, 12/21/98, (PB99-157257, A09, MF-A02).



- MCEER-99-0001 "Seismic Evaluation of a Masonry Infilled Reinforced Concrete Frame by Pseudodynamic Testing," by S.G. Buonopane and R.N. White, 2/16/99, (PB99-162851, A09, MF-A02).
- MCEER-99-0002 "Response History Analysis of Structures with Seismic Isolation and Energy Dissipation Systems: Verification Examples for Program SAP2000," by J. Scheller and M.C. Constantinou, 2/22/99, (PB99-162869, A08, MF-A02).
- MCEER-99-0003 "Experimental Study on the Seismic Design and Retrofit of Bridge Columns Including Axial Load Effects," by A. Dutta, T. Kokorina and J.B. Mander, 2/22/99, (PB99-162877, A09, MF-A02).
- MCEER-99-0004 "Experimental Study of Bridge Elastomeric and Other Isolation and Energy Dissipation Systems with Emphasis on Uplift Prevention and High Velocity Near-source Seismic Excitation," by A. Kasalanati and M. C. Constantinou, 2/26/99, (PB99-162885, A12, MF-A03).
- MCEER-99-0005 "Truss Modeling of Reinforced Concrete Shear-flexure Behavior," by J.H. Kim and J.B. Mander, 3/8/99, (PB99-163693, A12, MF-A03).
- MCEER-99-0006 "Experimental Investigation and Computational Modeling of Seismic Response of a 1:4 Scale Model Steel Structure with a Load Balancing Supplemental Damping System," by G. Pekcan, J.B. Mander and S.S. Chen, 4/2/99, (PB99-162893, A11, MF-A03).
- MCEER-99-0007 "Effect of Vertical Ground Motions on the Structural Response of Highway Bridges," by M.R. Button, C.J. Cronin and R.L. Mayes, 4/10/99, (PB2000-101411, A10, MF-A03).
- MCEER-99-0008 "Seismic Reliability Assessment of Critical Facilities: A Handbook, Supporting Documentation, and Model Code Provisions," by G.S. Johnson, R.E. Sheppard, M.D. Quilici, S.J. Eder and C.R. Scawthorn, 4/12/99, (PB2000-101701, A18, MF-A04).
- MCEER-99-0009 "Impact Assessment of Selected MCEER Highway Project Research on the Seismic Design of Highway Structures," by C. Rojahn, R. Mayes, D.G. Anderson, J.H. Clark, D'Appolonia Engineering, S. Gloyd and R.V. Nutt, 4/14/99, (PB99-162901, A10, MF-A02).
- MCEER-99-0010 "Site Factors and Site Categories in Seismic Codes," by R. Dobry, R. Ramos and M.S. Power, 7/19/99, (PB2000-101705, A08, MF-A02).
- MCEER-99-0011 "Restraint Design Procedures for Multi-Span Simply-Supported Bridges," by M.J. Randall, M. Saiidi, E. Maragakis and T. Isakovic, 7/20/99, (PB2000-101702, A10, MF-A02).
- MCEER-99-0012 "Property Modification Factors for Seismic Isolation Bearings," by M.C. Constantinou, P. Tsopelas, A. Kasalanati and E. Wolff, 7/20/99, (PB2000-103387, A11, MF-A03).
- MCEER-99-0013 "Critical Seismic Issues for Existing Steel Bridges," by P. Ritchie, N. Kauh and J. Kulicki, 7/20/99, (PB2000-101697, A09, MF-A02).
- MCEER-99-0014 "Nonstructural Damage Database," by A. Kao, T.T. Soong and A. Vender, 7/24/99, (PB2000-101407, A06, MF-A01).
- MCEER-99-0015 "Guide to Remedial Measures for Liquefaction Mitigation at Existing Highway Bridge Sites," by H.G. Cooke and J. K. Mitchell, 7/26/99, (PB2000-101703, A11, MF-A03).
- MCEER-99-0016 "Proceedings of the MCEER Workshop on Ground Motion Methodologies for the Eastern United States," edited by N. Abrahamson and A. Becker, 8/11/99, (PB2000-103385, A07, MF-A02).
- MCEER-99-0017 "Quindío, Colombia Earthquake of January 25, 1999: Reconnaissance Report," by A.P. Asfura and P.J. Flores, 10/4/99, (PB2000-106893, A06, MF-A01).
- MCEER-99-0018 "Hysteretic Models for Cyclic Behavior of Deteriorating Inelastic Structures," by M.V. Sivaselvan and A.M. Reinhorn, 11/5/99, (PB2000-103386, A08, MF-A02).

- MCEER-99-0019 "Proceedings of the 7<sup>th</sup> U.S.- Japan Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures Against Soil Liquefaction," edited by T.D. O'Rourke, J.P. Bardet and M. Hamada, 11/19/99, (PB2000-103354, A99, MF-A06).
- MCEER-99-0020 "Development of Measurement Capability for Micro-Vibration Evaluations with Application to Chip Fabrication Facilities," by G.C. Lee, Z. Liang, J.W. Song, J.D. Shen and W.C. Liu, 12/1/99, (PB2000-105993, A08, MF-A02).
- MCEER-99-0021 "Design and Retrofit Methodology for Building Structures with Supplemental Energy Dissipating Systems," by G. Pekcan, J.B. Mander and S.S. Chen, 12/31/99, (PB2000-105994, A11, MF-A03).
- MCEER-00-0001 "The Marmara, Turkey Earthquake of August 17, 1999: Reconnaissance Report," edited by C. Scawthorn; with major contributions by M. Bruneau, R. Eguchi, T. Holzer, G. Johnson, J. Mander, J. Mitchell, W. Mitchell, A. Papageorgiou, C. Scaethorn, and G. Webb, 3/23/00, (PB2000-106200, A11, MF-A03).
- MCEER-00-0002 "Proceedings of the MCEER Workshop for Seismic Hazard Mitigation of Health Care Facilities," edited by G.C. Lee, M. Ettouney, M. Grigoriu, J. Hauer and J. Nigg, 3/29/00, (PB2000-106892, A08, MF-A02).
- MCEER-00-0003 "The Chi-Chi, Taiwan Earthquake of September 21, 1999: Reconnaissance Report," edited by G.C. Lee and C.H. Loh, with major contributions by G.C. Lee, M. Bruneau, I.G. Buckle, S.E. Chang, P.J. Flores, T.D. O'Rourke, M. Shinozuka, T.T. Soong, C-H. Loh, K-C. Chang, Z-J. Chen, J-S. Hwang, M-L. Lin, G-Y. Liu, K-C. Tsai, G.C. Yao and C-L. Yen, 4/30/00, (PB2001-100980, A10, MF-A02).
- MCEER-00-0004 "Seismic Retrofit of End-Sway Frames of Steel Deck-Truss Bridges with a Supplemental Tendon System: Experimental and Analytical Investigation," by G. Pekcan, J.B. Mander and S.S. Chen, 7/1/00, (PB2001-100982, A10, MF-A02).
- MCEER-00-0005 "Sliding Fragility of Unrestrained Equipment in Critical Facilities," by W.H. Chong and T.T. Soong, 7/5/00, (PB2001-100983, A08, MF-A02).
- MCEER-00-0006 "Seismic Response of Reinforced Concrete Bridge Pier Walls in the Weak Direction," by N. Abo-Shadi, M. Saiidi and D. Sanders, 7/17/00, (PB2001-100981, A17, MF-A03).
- MCEER-00-0007 "Low-Cycle Fatigue Behavior of Longitudinal Reinforcement in Reinforced Concrete Bridge Columns," by J. Brown and S.K. Kunnath, 7/23/00, (PB2001-104392, A08, MF-A02).
- MCEER-00-0008 "Soil Structure Interaction of Bridges for Seismic Analysis," I. PoLam and H. Law, 9/25/00, (PB2001-105397, A08, MF-A02).
- MCEER-00-0009 "Proceedings of the First MCEER Workshop on Mitigation of Earthquake Disaster by Advanced Technologies (MEDAT-1), edited by M. Shinozuka, D.J. Inman and T.D. O'Rourke, 11/10/00, (PB2001-105399, A14, MF-A03).
- MCEER-00-0010 "Development and Evaluation of Simplified Procedures for Analysis and Design of Buildings with Passive Energy Dissipation Systems, Revision 01," by O.M. Ramirez, M.C. Constantinou, C.A. Kircher, A.S. Whittaker, M.W. Johnson, J.D. Gomez and C. Chrysostomou, 11/16/01, (PB2001-105523, A23, MF-A04).
- MCEER-00-0011 "Dynamic Soil-Foundation-Structure Interaction Analyses of Large Caissons," by C-Y. Chang, C-M. Mok, Z-L. Wang, R. Settgast, F. Waggoner, M.A. Ketchum, H.M. Gonnermann and C-C. Chin, 12/30/00, (PB2001-104373, A07, MF-A02).
- MCEER-00-0012 "Experimental Evaluation of Seismic Performance of Bridge Restrainers," by A.G. Vlassis, E.M. Maragakis and M. Saiid Saiidi, 12/30/00, (PB2001-104354, A09, MF-A02).
- MCEER-00-0013 "Effect of Spatial Variation of Ground Motion on Highway Structures," by M. Shinozuka, V. Saxena and G. Deodatis, 12/31/00, (PB2001-108755, A13, MF-A03).
- MCEER-00-0014 "A Risk-Based Methodology for Assessing the Seismic Performance of Highway Systems," by S.D. Werner, C.E. Taylor, J.E. Moore, II, J.S. Walton and S. Cho, 12/31/00, (PB2001-108756, A14, MF-A03).

- MCEER-01-0001 “Experimental Investigation of P-Delta Effects to Collapse During Earthquakes,” by D. Vian and M. Bruneau, 6/25/01, (PB2002-100534, A17, MF-A03).
- MCEER-01-0002 “Proceedings of the Second MCEER Workshop on Mitigation of Earthquake Disaster by Advanced Technologies (MEDAT-2),” edited by M. Bruneau and D.J. Inman, 7/23/01, (PB2002-100434, A16, MF-A03).
- MCEER-01-0003 “Sensitivity Analysis of Dynamic Systems Subjected to Seismic Loads,” by C. Roth and M. Grigoriu, 9/18/01, (PB2003-100884, A12, MF-A03).
- MCEER-01-0004 “Overcoming Obstacles to Implementing Earthquake Hazard Mitigation Policies: Stage 1 Report,” by D.J. Alesch and W.J. Petak, 12/17/01, (PB2002-107949, A07, MF-A02).
- MCEER-01-0005 “Updating Real-Time Earthquake Loss Estimates: Methods, Problems and Insights,” by C.E. Taylor, S.E. Chang and R.T. Eguchi, 12/17/01, (PB2002-107948, A05, MF-A01).
- MCEER-01-0006 “Experimental Investigation and Retrofit of Steel Pile Foundations and Pile Bents Under Cyclic Lateral Loadings,” by A. Shama, J. Mander, B. Blabac and S. Chen, 12/31/01, (PB2002-107950, A13, MF-A03).
- MCEER-02-0001 “Assessment of Performance of Bolu Viaduct in the 1999 Duzce Earthquake in Turkey” by P.C. Roussis, M.C. Constantinou, M. Erdik, E. Durukal and M. Dicleli, 5/8/02, (PB2003-100883, A08, MF-A02).
- MCEER-02-0002 “Seismic Behavior of Rail Counterweight Systems of Elevators in Buildings,” by M.P. Singh, Rildova and L.E. Suarez, 5/27/02. (PB2003-100882, A11, MF-A03).
- MCEER-02-0003 “Development of Analysis and Design Procedures for Spread Footings,” by G. Mylonakis, G. Gazetas, S. Nikolaou and A. Chauncey, 10/02/02, (PB2004-101636, A13, MF-A03, CD-A13).
- MCEER-02-0004 “Bare-Earth Algorithms for Use with SAR and LIDAR Digital Elevation Models,” by C.K. Huyck, R.T. Eguchi and B. Houshmand, 10/16/02, (PB2004-101637, A07, CD-A07).
- MCEER-02-0005 “Review of Energy Dissipation of Compression Members in Concentrically Braced Frames,” by K.Lee and M. Bruneau, 10/18/02, (PB2004-101638, A10, CD-A10).
- MCEER-03-0001 “Experimental Investigation of Light-Gauge Steel Plate Shear Walls for the Seismic Retrofit of Buildings” by J. Berman and M. Bruneau, 5/2/03, (PB2004-101622, A10, MF-A03, CD-A10).
- MCEER-03-0002 “Statistical Analysis of Fragility Curves,” by M. Shinozuka, M.Q. Feng, H. Kim, T. Uzawa and T. Ueda, 6/16/03, (PB2004-101849, A09, CD-A09).
- MCEER-03-0003 “Proceedings of the Eighth U.S.-Japan Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures Against Liquefaction,” edited by M. Hamada, J.P. Bardet and T.D. O’Rourke, 6/30/03, (PB2004-104386, A99, CD-A99).
- MCEER-03-0004 “Proceedings of the PRC-US Workshop on Seismic Analysis and Design of Special Bridges,” edited by L.C. Fan and G.C. Lee, 7/15/03, (PB2004-104387, A14, CD-A14).
- MCEER-03-0005 “Urban Disaster Recovery: A Framework and Simulation Model,” by S.B. Miles and S.E. Chang, 7/25/03, (PB2004-104388, A07, CD-A07).
- MCEER-03-0006 “Behavior of Underground Piping Joints Due to Static and Dynamic Loading,” by R.D. Meis, M. Maragakis and R. Siddharthan, 11/17/03, (PB2005-102194, A13, MF-A03, CD-A00).
- MCEER-04-0001 “Experimental Study of Seismic Isolation Systems with Emphasis on Secondary System Response and Verification of Accuracy of Dynamic Response History Analysis Methods,” by E. Wolff and M. Constantinou, 1/16/04 (PB2005-102195, A99, MF-E08, CD-A00).
- MCEER-04-0002 “Tension, Compression and Cyclic Testing of Engineered Cementitious Composite Materials,” by K. Kesner and S.L. Billington, 3/1/04, (PB2005-102196, A08, CD-A08).

- MCEER-04-0003 “Cyclic Testing of Braces Laterally Restrained by Steel Studs to Enhance Performance During Earthquakes,” by O.C. Celik, J.W. Berman and M. Bruneau, 3/16/04, (PB2005-102197, A13, MF-A03, CD-A00).
- MCEER-04-0004 “Methodologies for Post Earthquake Building Damage Detection Using SAR and Optical Remote Sensing: Application to the August 17, 1999 Marmara, Turkey Earthquake,” by C.K. Huyck, B.J. Adams, S. Cho, R.T. Eguchi, B. Mansouri and B. Houshmand, 6/15/04, (PB2005-104888, A10, CD-A00).
- MCEER-04-0005 “Nonlinear Structural Analysis Towards Collapse Simulation: A Dynamical Systems Approach,” by M.V. Sivaselvan and A.M. Reinhorn, 6/16/04, (PB2005-104889, A11, MF-A03, CD-A00).
- MCEER-04-0006 “Proceedings of the Second PRC-US Workshop on Seismic Analysis and Design of Special Bridges,” edited by G.C. Lee and L.C. Fan, 6/25/04, (PB2005-104890, A16, CD-A00).
- MCEER-04-0007 “Seismic Vulnerability Evaluation of Axially Loaded Steel Built-up Laced Members,” by K. Lee and M. Bruneau, 6/30/04, (PB2005-104891, A16, CD-A00).
- MCEER-04-0008 “Evaluation of Accuracy of Simplified Methods of Analysis and Design of Buildings with Damping Systems for Near-Fault and for Soft-Soil Seismic Motions,” by E.A. Pavlou and M.C. Constantinou, 8/16/04, (PB2005-104892, A08, MF-A02, CD-A00).
- MCEER-04-0009 “Assessment of Geotechnical Issues in Acute Care Facilities in California,” by M. Lew, T.D. O’Rourke, R. Dobry and M. Koch, 9/15/04, (PB2005-104893, A08, CD-A00).
- MCEER-04-0010 “Scissor-Jack-Damper Energy Dissipation System,” by A.N. Sigaher-Boyle and M.C. Constantinou, 12/1/04 (PB2005-108221).
- MCEER-04-0011 “Seismic Retrofit of Bridge Steel Truss Piers Using a Controlled Rocking Approach,” by M. Pollino and M. Bruneau, 12/20/04 (PB2006-105795).
- MCEER-05-0001 “Experimental and Analytical Studies of Structures Seismically Isolated with an Uplift-Restraint Isolation System,” by P.C. Roussis and M.C. Constantinou, 1/10/05 (PB2005-108222).
- MCEER-05-0002 “A Versatile Experimentation Model for Study of Structures Near Collapse Applied to Seismic Evaluation of Irregular Structures,” by D. Kusumastuti, A.M. Reinhorn and A. Rutenberg, 3/31/05 (PB2006-101523).
- MCEER-05-0003 “Proceedings of the Third PRC-US Workshop on Seismic Analysis and Design of Special Bridges,” edited by L.C. Fan and G.C. Lee, 4/20/05, (PB2006-105796).
- MCEER-05-0004 “Approaches for the Seismic Retrofit of Braced Steel Bridge Piers and Proof-of-Concept Testing of an Eccentrically Braced Frame with Tubular Link,” by J.W. Berman and M. Bruneau, 4/21/05 (PB2006-101524).
- MCEER-05-0005 “Simulation of Strong Ground Motions for Seismic Fragility Evaluation of Nonstructural Components in Hospitals,” by A. Wanitkorkul and A. Filiatrault, 5/26/05 (PB2006-500027).
- MCEER-05-0006 “Seismic Safety in California Hospitals: Assessing an Attempt to Accelerate the Replacement or Seismic Retrofit of Older Hospital Facilities,” by D.J. Alesch, L.A. Arendt and W.J. Petak, 6/6/05 (PB2006-105794).
- MCEER-05-0007 “Development of Seismic Strengthening and Retrofit Strategies for Critical Facilities Using Engineered Cementitious Composite Materials,” by K. Kesner and S.L. Billington, 8/29/05 (PB2006-111701).
- MCEER-05-0008 “Experimental and Analytical Studies of Base Isolation Systems for Seismic Protection of Power Transformers,” by N. Murota, M.Q. Feng and G-Y. Liu, 9/30/05 (PB2006-111702).
- MCEER-05-0009 “3D-BASIS-ME-MB: Computer Program for Nonlinear Dynamic Analysis of Seismically Isolated Structures,” by P.C. Tsopelas, P.C. Roussis, M.C. Constantinou, R. Buchanan and A.M. Reinhorn, 10/3/05 (PB2006-111703).
- MCEER-05-0010 “Steel Plate Shear Walls for Seismic Design and Retrofit of Building Structures,” by D. Vian and M. Bruneau, 12/15/05 (PB2006-111704).

- MCEER-05-0011 "The Performance-Based Design Paradigm," by M.J. Astrella and A. Whittaker, 12/15/05 (PB2006-111705).
- MCEER-06-0001 "Seismic Fragility of Suspended Ceiling Systems," H. Badillo-Almaraz, A.S. Whittaker, A.M. Reinhorn and G.P. Cimellaro, 2/4/06 (PB2006-111706).
- MCEER-06-0002 "Multi-Dimensional Fragility of Structures," by G.P. Cimellaro, A.M. Reinhorn and M. Bruneau, 3/1/06 (PB2007-106974, A09, MF-A02, CD A00).
- MCEER-06-0003 "Built-Up Shear Links as Energy Dissipators for Seismic Protection of Bridges," by P. Dusicka, A.M. Itani and I.G. Buckle, 3/15/06 (PB2006-111708).
- MCEER-06-0004 "Analytical Investigation of the Structural Fuse Concept," by R.E. Vargas and M. Bruneau, 3/16/06 (PB2006-111709).
- MCEER-06-0005 "Experimental Investigation of the Structural Fuse Concept," by R.E. Vargas and M. Bruneau, 3/17/06 (PB2006-111710).
- MCEER-06-0006 "Further Development of Tubular Eccentrically Braced Frame Links for the Seismic Retrofit of Braced Steel Truss Bridge Piers," by J.W. Berman and M. Bruneau, 3/27/06 (PB2007-105147).
- MCEER-06-0007 "REDARS Validation Report," by S. Cho, C.K. Huyck, S. Ghosh and R.T. Eguchi, 8/8/06 (PB2007-106983).
- MCEER-06-0008 "Review of Current NDE Technologies for Post-Earthquake Assessment of Retrofitted Bridge Columns," by J.W. Song, Z. Liang and G.C. Lee, 8/21/06 (PB2007-106984).
- MCEER-06-0009 "Liquefaction Remediation in Silty Soils Using Dynamic Compaction and Stone Columns," by S. Thevanayagam, G.R. Martin, R. Nashed, T. Shenthan, T. Kanagalingam and N. Ecemis, 8/28/06 (PB2007-106985).
- MCEER-06-0010 "Conceptual Design and Experimental Investigation of Polymer Matrix Composite Infill Panels for Seismic Retrofitting," by W. Jung, M. Chiewanichakorn and A.J. Aref, 9/21/06 (PB2007-106986).
- MCEER-06-0011 "A Study of the Coupled Horizontal-Vertical Behavior of Elastomeric and Lead-Rubber Seismic Isolation Bearings," by G.P. Warn and A.S. Whittaker, 9/22/06 (PB2007-108679).
- MCEER-06-0012 "Proceedings of the Fourth PRC-US Workshop on Seismic Analysis and Design of Special Bridges: Advancing Bridge Technologies in Research, Design, Construction and Preservation," Edited by L.C. Fan, G.C. Lee and L. Ziang, 10/12/06 (PB2007-109042).
- MCEER-06-0013 "Cyclic Response and Low Cycle Fatigue Characteristics of Plate Steels," by P. Dusicka, A.M. Itani and I.G. Buckle, 11/1/06 06 (PB2007-106987).
- MCEER-06-0014 "Proceedings of the Second US-Taiwan Bridge Engineering Workshop," edited by W.P. Yen, J. Shen, J-Y. Chen and M. Wang, 11/15/06 (PB2008-500041).
- MCEER-06-0015 "User Manual and Technical Documentation for the REDARS<sup>TM</sup> Import Wizard," by S. Cho, S. Ghosh, C.K. Huyck and S.D. Werner, 11/30/06 (PB2007-114766).
- MCEER-06-0016 "Hazard Mitigation Strategy and Monitoring Technologies for Urban and Infrastructure Public Buildings: Proceedings of the China-US Workshops," edited by X.Y. Zhou, A.L. Zhang, G.C. Lee and M. Tong, 12/12/06 (PB2008-500018).
- MCEER-07-0001 "Static and Kinetic Coefficients of Friction for Rigid Blocks," by C. Kafali, S. Fathali, M. Grigoriu and A.S. Whittaker, 3/20/07 (PB2007-114767).
- MCEER-07-0002 "Hazard Mitigation Investment Decision Making: Organizational Response to Legislative Mandate," by L.A. Arendt, D.J. Alesch and W.J. Petak, 4/9/07 (PB2007-114768).
- MCEER-07-0003 "Seismic Behavior of Bidirectional-Resistant Ductile End Diaphragms with Unbonded Braces in Straight or Skewed Steel Bridges," by O. Celik and M. Bruneau, 4/11/07 (PB2008-105141).


- MCEER-07-0004 “Modeling Pile Behavior in Large Pile Groups Under Lateral Loading,” by A.M. Dodds and G.R. Martin, 4/16/07(PB2008-105142).
- MCEER-07-0005 “Experimental Investigation of Blast Performance of Seismically Resistant Concrete-Filled Steel Tube Bridge Piers,” by S. Fujikura, M. Bruneau and D. Lopez-Garcia, 4/20/07 (PB2008-105143).
- MCEER-07-0006 “Seismic Analysis of Conventional and Isolated Liquefied Natural Gas Tanks Using Mechanical Analogs,” by I.P. Christovasilis and A.S. Whittaker, 5/1/07.
- MCEER-07-0007 “Experimental Seismic Performance Evaluation of Isolation/Restraint Systems for Mechanical Equipment – Part 1: Heavy Equipment Study,” by S. Fathali and A. Filiatrault, 6/6/07 (PB2008-105144).
- MCEER-07-0008 “Seismic Vulnerability of Timber Bridges and Timber Substructures,” by A.A. Sharma, J.B. Mander, I.M. Friedland and D.R. Allicock, 6/7/07 (PB2008-105145).
- MCEER-07-0009 “Experimental and Analytical Study of the XY-Friction Pendulum (XY-FP) Bearing for Bridge Applications,” by C.C. Marin-Artieda, A.S. Whittaker and M.C. Constantinou, 6/7/07 (PB2008-105191).
- MCEER-07-0010 “Proceedings of the PRC-US Earthquake Engineering Forum for Young Researchers,” Edited by G.C. Lee and X.Z. Qi, 6/8/07.
- MCEER-07-0011 “Design Recommendations for Perforated Steel Plate Shear Walls,” by R. Purba and M. Bruneau, 6/18/07, (PB2008-105192).
- MCEER-07-0012 “Performance of Seismic Isolation Hardware Under Service and Seismic Loading,” by M.C. Constantinou, A.S. Whittaker, Y. Kalpakidis, D.M. Fenz and G.P. Warn, 8/27/07, (PB2008-105193).
- MCEER-07-0013 “Experimental Evaluation of the Seismic Performance of Hospital Piping Subassemblies,” by E.R. Goodwin, E. Maragakis and A.M. Itani, 9/4/07, (PB2008-105194).
- MCEER-07-0014 “A Simulation Model of Urban Disaster Recovery and Resilience: Implementation for the 1994 Northridge Earthquake,” by S. Miles and S.E. Chang, 9/7/07, (PB2008-106426).
- MCEER-07-0015 “Statistical and Mechanistic Fragility Analysis of Concrete Bridges,” by M. Shinozuka, S. Banerjee and S-H. Kim, 9/10/07, (PB2008-106427).
- MCEER-07-0016 “Three-Dimensional Modeling of Inelastic Buckling in Frame Structures,” by M. Schachter and AM. Reinhorn, 9/13/07, (PB2008-108125).
- MCEER-07-0017 “Modeling of Seismic Wave Scattering on Pile Groups and Caissons,” by I. Po Lam, H. Law and C.T. Yang, 9/17/07 (PB2008-108150).
- MCEER-07-0018 “Bridge Foundations: Modeling Large Pile Groups and Caissons for Seismic Design,” by I. Po Lam, H. Law and G.R. Martin (Coordinating Author), 12/1/07 (PB2008-111190).
- MCEER-07-0019 “Principles and Performance of Roller Seismic Isolation Bearings for Highway Bridges,” by G.C. Lee, Y.C. Ou, Z. Liang, T.C. Niu and J. Song, 12/10/07.
- MCEER-07-0020 “Centrifuge Modeling of Permeability and Pinning Reinforcement Effects on Pile Response to Lateral Spreading,” by L.L Gonzalez-Lagos, T. Abdoun and R. Dobry, 12/10/07 (PB2008-111191).
- MCEER-07-0021 “Damage to the Highway System from the Pisco, Perú Earthquake of August 15, 2007,” by J.S. O’Connor, L. Mesa and M. Nykamp, 12/10/07, (PB2008-108126).
- MCEER-07-0022 “Experimental Seismic Performance Evaluation of Isolation/Restraint Systems for Mechanical Equipment – Part 2: Light Equipment Study,” by S. Fathali and A. Filiatrault, 12/13/07 (PB2008-111192).
- MCEER-07-0023 “Fragility Considerations in Highway Bridge Design,” by M. Shinozuka, S. Banerjee and S.H. Kim, 12/14/07 (PB2008-111193).

- MCEER-07-0024 “Performance Estimates for Seismically Isolated Bridges,” by G.P. Warn and A.S. Whittaker, 12/30/07 (PB2008-112230).
- MCEER-08-0001 “Seismic Performance of Steel Girder Bridge Superstructures with Conventional Cross Frames,” by L.P. Carden, A.M. Itani and I.G. Buckle, 1/7/08, (PB2008-112231).
- MCEER-08-0002 “Seismic Performance of Steel Girder Bridge Superstructures with Ductile End Cross Frames with Seismic Isolators,” by L.P. Carden, A.M. Itani and I.G. Buckle, 1/7/08 (PB2008-112232).
- MCEER-08-0003 “Analytical and Experimental Investigation of a Controlled Rocking Approach for Seismic Protection of Bridge Steel Truss Piers,” by M. Pollino and M. Bruneau, 1/21/08 (PB2008-112233).
- MCEER-08-0004 “Linking Lifeline Infrastructure Performance and Community Disaster Resilience: Models and Multi-Stakeholder Processes,” by S.E. Chang, C. Pasion, K. Tatebe and R. Ahmad, 3/3/08 (PB2008-112234).
- MCEER-08-0005 “Modal Analysis of Generally Damped Linear Structures Subjected to Seismic Excitations,” by J. Song, Y-L. Chu, Z. Liang and G.C. Lee, 3/4/08 (PB2009-102311).
- MCEER-08-0006 “System Performance Under Multi-Hazard Environments,” by C. Kafali and M. Grigoriu, 3/4/08 (PB2008-112235).
- MCEER-08-0007 “Mechanical Behavior of Multi-Spherical Sliding Bearings,” by D.M. Fenz and M.C. Constantinou, 3/6/08 (PB2008-112236).
- MCEER-08-0008 “Post-Earthquake Restoration of the Los Angeles Water Supply System,” by T.H.P. Tabucchi and R.A. Davidson, 3/7/08 (PB2008-112237).
- MCEER-08-0009 “Fragility Analysis of Water Supply Systems,” by A. Jacobson and M. Grigoriu, 3/10/08.
- MCEER-08-0010 “Experimental Investigation of Full-Scale Two-Story Steel Plate Shear Walls with Reduced Beam Section Connections,” by B. Qu, M. Bruneau, C-H. Lin and K-C. Tsai, 3/17/08.
- MCEER-08-0011 “Seismic Evaluation and Rehabilitation of Critical Components of Electrical Power Systems,” S. Ersoy, B. Feizi, A. Ashrafi and M. Ala Saadeghvaziri, 3/17/08.
- MCEER-08-0012 “Seismic Behavior and Design of Boundary Frame Members of Steel Plate Shear Walls,” by B. Qu and M. Bruneau, 4/26/08.
- MCEER-08-0013 “Development and Appraisal of a Numerical Cyclic Loading Protocol for Quantifying Building System Performance,” by A. Filiatrault, A. Wanitkorkul and M. Constantinou, 4/27/08.
- MCEER-08-0014 “Structural and Nonstructural Earthquake Design: The Challenge of Integrating Specialty Areas in Designing Complex, Critical Facilities,” by W.J. Petak and D.J. Alesch, 4/30/08.










**EARTHQUAKE ENGINEERING TO EXTREME EVENTS**

University at Buffalo, The State University of New York  
Red Jacket Quadrangle ■ Buffalo, New York 14261  
Phone: (716) 645-3391 ■ Fax: (716) 645-3399  
E-mail: [mceer@buffalo.edu](mailto:mceer@buffalo.edu) ■ WWW Site <http://mceer.buffalo.edu>



University at Buffalo *The State University of New York*

ISSN 1520-295X