

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE May 1992	3. REPORT TYPE AND DATES COVERED Final Report	
4. TITLE AND SUBTITLE Investigation of Cause and Effects of Fires Following the Loma Prieta Earthquake			5. FUNDING NUMBERS BCS-9003557	
6. AUTHOR(S) Jamshid Mohammadi, Sam Alayasin, and D.N. Bak				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Illinois Institute of Technology Department of Civil Engineering Chicago, IL 60616			8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Division of Industrial Science and Technological Innovation (ISTI) Directorate of Scientific, Technological, and International Affairs (STIA) National Science Foundation, Washington, DC 20550			10. SPONSORING/MONITORING AGENCY REPORT NUMBER NSFENG-92007	
11. SUPPLEMENTARY NOTES Prepared under grant awarded to the Illinois Institute of Technology, Chicago, IL; appears as item IIT-CE-92-01, Structural Engineering Series				
12a. DISTRIBUTION/AVAILABILITY STATEMENT			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) This study investigated the causes and effects of the 41 San Francisco fires following the October 1989 Loma Prieta earthquake, and examined the risks for future post-earthquake fire in this city. Using data gathered from fire departments and other sources, the authors found that these fires were due to damages to electrical wiring or electrical equipment, overturned or disrupted appliances, and several isolated causes. For each fire, they examined the classification type, intensity of ground motion, soil type, and type of structure burned, and with this information constructed a risk model for simulating initiation of other potential post-earthquake residential fires. Employing event trees and other models for gas and electrical fire initiation, in conjunction with probabilities associated with various earthquake ground acceleration levels, the authors computed the probabilities for future occurrences. The study noted that such information can provide the basis for earthquake preparedness, such as in helping to plan fire fighting strategies, alternative transportation routes, shelter and hospital services, evacuation procedures, and also aid in assessing which residential services and/or equipment are needed to reduce risk in localities vulnerable to earthquakes.				
14. SUBJECT TERMS Earthquake Fire Mitigation			15. NUMBER OF PAGES 781	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT UL	

Illinois Institute of Technology

Chicago, Illinois 60616



**Department of Civil Engineering
Armour College of Engineering**

**IIT-CE-92-01
STRUCTURAL ENGINEERING SERIES**

**INVESTIGATION OF CAUSE AND EFFECTS OF
FIRES FOLLOWING THE LOMA PRIETA
EARTHQUAKE**

BY

JAMSHID MOHAMMADI

SAM ALYASIN

D. N. BAK

**A Report to the
NATIONAL SCIENCE FOUNDATION
Research Grant BCS-9003557**

MAY, 1992

REPRODUCED BY
U.S. DEPARTMENT OF COMMERCE
NATIONAL TECHNICAL INFORMATION SERVICE
SPRINGFIELD, VA 22161



**IIT-CE-92-01
STRUCTURAL ENGINEERING SERIES**

**INVESTIGATION OF CAUSE AND EFFECTS OF
FIRES FOLLOWING THE LOMA PRIETA
EARTHQUAKE**

BY

JAMSHID MOHAMMADI

SAM ALYASIN

D. N. BAK

**A Report to the
NATIONAL SCIENCE FOUNDATION
Research Grant BCS-9003557**

MAY, 1992

ABSTRACT

The objective of this study was to investigate the cause and effects of fires following the October 17, 1989 Loma Prieta Earthquake. The study also examined the potential risks of post-earthquake fire hazard in San Francisco. The Fire Incident Reports from local fire departments were obtained and reviewed. The number of fires following the Loma Prieta Earthquake versus the type of soil in the area, the population density of the region, and the types of fires in terms of their severity was analyzed. The causes of fires were studied and classified. A variety of causes were identified. It was found that of the 41 fires in San Francisco 14 were due to electric wiring and equipment, 11 were the result of stoves (gas/electric), 2 from water heaters, and from other gas appliances. The rest of the fires were due to other causes. Using an event tree analysis, occurrence of gas and electric wires were modeled. The risk associated with various events following an earthquake that may lead to a fire were quantified using simulation analysis (where possible), and available data. The results were then used to estimate the probability of post-earthquake fire occurrence in single family residential buildings. These results were depicted in the form of risk contour maps for a repeat of the Loma Prieta event in the city of San Francisco.

DISCLAIMER

This Material is based upon work supported by the National Science Foundation under award number BCS-9003557 to the Illinois Institute of Technology. Any opinions, findings, conclusions, or recommendations expressed in this publication are those of the authors and do not necessarily reflect the views of the National Science Foundation.

ACKNOWLEDGEMENTS

This report is based on the Master of Science thesis of Sam Alyasin. The writers wish to express their appreciation to Chief Dennis Callahan of the San Francisco Fire Department for the fire data and his guidance. The study was supported by the National Science Foundation through the Research Grant BCS-9003557 to the Department of Civil Engineering of the Illinois Institute of Technology.

TABLE OF CONTENTS

	Page
ACKNOWLEDGEMENT	iii
TABLE OF CONTENTS	iv
LIST OF TABLES	vi
LIST OF FIGURES	viii
CHAPTER	
I. BACKGROUND	1
1.1 Introductory Remarks	1
1.2 Fires Following Past Earthquakes	4
1.3 Causes of Post-Earthquake Fires.	7
1.4 Available Models on Fire Hazard Estimation	9
1.5 The Loma Prieta Event.	12
1.6 Contents of This Report.	14
II. EVALUATION OF CAUSES AND EFFECTS OF FIRES FOLLOWING THE LOMA PRIETA EARTHQUAKE	15
2.1 Introductory Remarks	15
2.2 The Loma Prieta Earthquake -- Fire Incidents.	16
2.3 Causes of Fires.	17
2.4 Types of Fires	18
2.5 Investigation of Fires in San Francisco.	18
2.6 Fires in Other Areas	35
2.7 Concluding Remarks	36
III. SEQUENCE OF EVENTS IN POST-EARTHQUAKE FIRES.	39
3.1 Introductory Remarks	39
3.2 Sequence of Events in Gas-Related Fires.	40
3.3 Sequence of Events in an Electric Fire	45
IV. RISK QUANTIFICATION.	50
4.1 Leak Probability of Gas Systems.	50
4.1.1 Effect of Higher Acceleration on Risk of Leak in Interior Gas Pipeline Systems.	58
4.2 Risk Associated with Appliance Failure	58
4.2.1 Appliance Without Straps	60
4.2.2 Appliance With Straps.	69
4.3 Risk of Fire in Electrical Distribution System	76
4.3.1 Estimated Risk in Routine (Non-Earthquake) Condition	79

CHAPTER	Page
4.3.2 Effect of Earthquake on the Risk of Fire	85
V. ESTIMATION OF PROBABILITY OF POST-EARTHQUAKE FIRES.	92
5.1 Introductory Remarks	92
5.2 Seismic Risk of San Francisco.	92
5.3 Events Following Gas Leaks	95
5.4 Events Following a Disturbance in the Electrical Distribution System	97
5.5 Probability of Post-Earthquake Fires for San Francisco.	99
5.6 Types of Fires	106
5.7 Fire Risk Contours for a Repeat of the Loma Prieta Earthquake	108
VI. SUMMARY AND CONCLUSIONS.	114
6.1 Summary and Conclusions.	114
6.2 Recommendations for Further Studies.	120
VII. BIBLIOGRAPHY.	122
VIII. APPENDIX	
A. The Modified Mercalli Intensity Scale.	125
B. Sample Computations for Probability of Fire	130
C. Fire Incident Reports for the City of San Francisco (Oct. 17-20) -- San Francisco Fire Department.	133

LIST OF TABLES

TABLE		Page
1.1	Statistics of Earthquake-Related Fires for Several Earthquakes in the U.S..	2
2.1	Number of Fires by Area.	19
2.2	Location of Fires in San Francisco	20
2.3	San Francisco's Fires by Type.	21
2.4	Classification of San Francisco's Fires by Cause . .	24
2.5	Number of Fires vs. Ground Acceleration.	27
2.6	Number of Fires vs. Ground Acceleration and Soil Types.	27
2.7	Number of Fires vs. Population per District in San Francisco.	33
2.8	Soil-Type Index vs. Number of Fires in San Francisco	34
4.1	Probability of Leak at Various Piping System Components	52
4.2	Maximum Principle Stresses (psi) at Pipe Joints for 1g Normalized Record of the Loma Prieta Earthquake	59
4.3	Values of Stress σ_1 (psi) for 0.1g Amplitude	68
4.4	Summary of Failure Probabilities pf_1 and pf_2	72
4.5	Summary of Leak Probabilities for Various Heaters. .	73
4.6	Capacity of the Strap.	75
4.7	Probability of Failure of Strap.	77
4.8	Probability of Failure of Heater with Strap.	78
4.9	Statistics of Electrical Fires (Data from NFPA 1986)	80
4.10	Percentage of Electrical Distribution System Fires vs. Age of Dwelling in 149 Fires (Smith and McCoskrie, 1990)	81
4.11	Failure Modes Involved in Residential Electrical Distribution System Fires Based on 149 Fires (Smith and McCoskrie, 1990).	83

TABLE	Page
4.12 San Francisco Fire Statistics (San Francisco Fire Department, 1991).	84
4.13 Acceleration and Duration of Various Earthquakes Used in Electric Distribution Simulations.	89
4.14 Risk of Electric Fires for Various Accelerations	91
5.1 Estimation of Annual Probability of Acceleration Exceedence for San Francisco	94
5.2 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type A Gas Appliances and/or Gas Pipe).	102
5.3 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type B Gas Appliances and/or Gas Pipe).	103
5.4 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type C Gas Appliances and/or Gas Pipe).	104
5.5 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type D Gas Appliances and/or Gas Pipe).	105
5.6 Estimated Probability of Earthquake-Related Fires in San Francisco (Fires Caused by Electrical Problems).	107

LIST OF FIGURES

FIGURE		Page
1.1	Fires Following Some Major North American Earthquakes.	5
1.2	Time Histories for the Loma Prieta Earthquake of 1989	13
2.1	Location of San Francisco Fires.	23
2.2	Percentage Distribution of the San Francisco Fires by Cause	25
2.3	Various Soil Types in San Francisco.	29
2.4	Population Density of San Francisco.	31
3.1	Sequence of Events in a Gas-Related Fire	42
3.2	Sequence of Events in an Electrical Fire	48
4.1	Interior Gas Piping System Configurations Used in the Dynamic Analyses	54
4.2	Modified Mercalli Intensity (MMI) vs. Ground acceleration in g's.	57
4.3	Four Typical Water Heaters Used in Single Family Dwellings.	61
4.4	Unstrapped Water Heater, (a) Typical Water Heater, (b) Idealization for Dynamic Analysis, (c) Failure Paths.	62
4.5	Leak Probabilities for Unstrapped Water Heaters. . .	70
4.6	Strapped Water Heater, (a) Typical Water Heater, (b) Idealization for Dynamic Analysis.	71
4.7	Failure Probabilities for Water Heaters with Straps. . .	88
4.8	Wiring Configuration Used for Dynamic Analysis . . .	89
5.1	Graphical Presentation of Events Following a Leak Detection.	98
5.2	Risk Map for a Repeat of Loma Prieta for Unstrapped Water Heater	109

FIGURE		Page
5.3	Risk Map for a Repeat of Loma Prieta for strapped Water Heater	110
5.4	Risk Map for a Repeat of Loma Prieta for electrical Distribution Systems	111

CHAPTER I
BACKGROUND

1.1 Introductory Remarks

The majority of research conducted on fires following earthquakes has been carried out in both Japan and the United States. An abridged review of past studies conducted on the subject is presented in this chapter, with the notion that the models developed may translate well into our investigation of the fires following earthquakes.

Urban post-earthquake fires are serious problems that have the potential to cause immense losses in terms of life and property. Almost all recent earthquakes in Japan and the U.S. have caused fires in both residential and commercial areas. In Japan fires were reported following 1923 Kanto, 1948 Fukui, 1964 Niigata, 1968 Tokachi-oki, 1978 Miyagiken-oki, and the 1983 Nihonkai-chubu earthquakes. Similarly American earthquakes of modern times have resulted in numerous fires. Table 1.1 summarizes the statistics of fire occurrences for several major U.S. earthquakes (Scawthorn 1986).

Despite their great damage potentials and importance in structural engineering and risk management, post-earthquake fires have not been fully investigated. Studies of post-earthquake fires have been in most part concentrated on:

(i) Investigation of fire incidents and, to certain extent, cause of post-earthquake fires.

Table 1.1 Statistics of Earthquake-Related Fires for Several Fires in the U.S.

Event	Date	Number of Fires	MMI	Magnitude
San Francisco	1906	58	VII 1/2-IX	8.3
Santa Barbara	1926	1	VIII 1/2	6.2
Long Beach	1933	13	IX	6.3
San Francisco	1957	1	VI 1/2	5.3
Alaska	1964	7	X	8.4
Puget Sound	1965	1	VII 1/2	5.6
San Fernando	1971	109	VII - IX	6.6
Coalingo	1983	1	VIII	6.7
Morgan Hill	1984	6	V 1/2 - VII	6.2
Whittier-Narrows	1987	6	VIII	5.9
Loma Prieta	1989	67	VI - VII	6.9

(ii) Modeling of fire spread in urban areas.

The latter, however, has been very limited and mainly conducted in Japan.

The statistics presented in Table 1.1 and reports of post-earthquake fires in most Japanese earthquakes (Scawthorn 1987) suggest that post earthquake fire hazard remains as a serious threat and a potential problem in many seismic areas in the United States. The problem is even more critical in urban areas where wood is a primary construction material. Furthermore, the post-earthquake hazard is specially critical because despite other earthquake-initiated hazards (e.g. structural collapse) that are normally drastically reduced when the earthquake stops, post-earthquake fire hazard continues even up to several days after the main event. For example it is not unusual for a gas-related fire to occur one or two days after an earthquake due to undetected gas leaks caused by the earthquake.

In this chapter an overview of past studies on earthquake fire hazard is presented. The review specifically focuses on:

- Fires following past earthquakes.
- Causes of post-earthquake fires.
- Available models on fire hazard estimation and evaluation.
- Fire investigation after the Loma Prieta earthquake of 1989

1.2 Fires Following Past Earthquakes

An investigation of fires after many earthquakes has been done by Scawthorn (1981,1985,1986,1988); Table 1.1 presents a summary. Additional such studies have been also conducted by others; Schiff (1988), Steinbrugge et al.(1973). Based on statistics of Table 1.1 , the number of fires occurring following some of North America's major earthquakes is summarized in Fig. 1.1. Although this figure does not display a definite trend in occurrence of fires following earthquakes, it serves as a reminder of post-earthquake fires' immense hazard potentials. A review of data presented here points to the fact that even with great technological advances in safety of utilities, such as gas and electrical distribution systems, large spread fires such as the 109 cases reported following the 1971 San Fernando earthquake, and the 41 fires reported in the city of San Francisco as a result of the Loma Prieta earthquake of 1989, are to be expected.

Considering the rapid growth of cities and quick pace of urbanization of small towns in the seismically high risk areas of the United States (such as California) in the past century, risk of widespread fires and conflagrations has drastically increased. Steinbrugge et al. (1973) discuss numerous problems involved with emergency response following earthquakes in a report on the San Fernando earthquake. This earthquake affected the city of Los Angeles, the Los Angeles County, San Fernando, Pasadena, Glendale, and Burbank. As a result of the earthquake, numerous gas and electrical fires occurred on the




Figure 1.1. Fires Following Some Major North American Earthquakes

day of the event and several days after it. Potential problems in dealing with post-earthquake fires range from damage to lifelines, such as damage to utilities, to damage to emergency response systems. This report specifically points to:

- disruption of public telephone communications
- damage to gas and electric supply facilities
- damage and obstruction of roads and highways
- overloading of emergency communications
- structural collapse or severe damage to some fire stations, fire fighting equipment, and hospitals

Such events hamper emergency response and rescue efforts, thus increasing the probability of conflagration of fires which would otherwise be controllable.

Further examination of data in Table 1.1 reveals that in almost all cases fires occur following earthquakes with intensities above VI on the MMI scale (see Appendix A). The largest concentration of post-earthquake fires is seen in the upper intensity ranges. Although no specific trend in the number of fires versus MMI can be seen from this data it is evident that the number of post-earthquake fires increases with an increase in the magnitude of the ground motion. It is however emphasized that there are other factors, such as population and the type of soil in the affected sites, that influence the number of fires.

The 1989 data mainly shows fires initiated by the Loma Prieta earthquake. This data is discussed in detail in Chapter

II of this report.

1.3 Causes of Post-Earthquake Fires

Fires following the Santa Cruz (Loma Prieta) earthquake are an indication of the diversity in the possible sources of fire in an urban area. Reports from the area fire departments list gas leaks, electrical wiring problems, overturned water heaters, overturned hot plates, and candles as major causes of fire. Stussman and Kosowatz (1989) report a fire that leveled a block in the Marina district of San Francisco as a result of a single broken gas distribution pipe.

Post-earthquake gas leaks are a primary source of fires in urban areas. Various researchers, Schiff (1985,1988); Scawthorn et al. (1985); Longinow, Mohammadi, and Williams (1989); Longinow et al. (1990) have investigated different aspects of gas system response.

In his investigation of lifelines' performance in the Morgan Hill Earthquake, Schiff (1985) concluded that most of the failure in gas systems had occurred beyond the service connections. In his report he estimates 1400 gas leaks beyond the service lines. Several of these leaks caused fires. Scawthorn et al. (1985) confirms Schiff's findings in a detailed review of the fire related events during and after the Morgan Hill earthquake. A major part of these studies also dealt with mitigation efforts and actions taken by support personnel dealing with leaks and resulting fires.

Study of gas system failure and its consequences following

an earthquake has provided a useful database for new research. Longinow, Mohammadi, and Williams (1989) developed methods for estimating risks associated with residential and commercial interior piping systems failures and analyzed the potential risks in interior gas piping systems of selected low and high-rise buildings. Expert opinion polls, collection of experimentally derived performance data, and literature search were used to gather data on gas leaks. Mean probability and standard deviations of each data group were calculated and using information on consequences of these leaks fault and event tree risk analyses were performed on a selected group of buildings. The event tree analysis lead to an estimation of a measure of damage caused by different levels of gas leaks and an understanding of the risk involved in different types of piping systems and their components.

Longinow et al. (1990) studied the effects of seismic forces on interior gas piping systems. Using simulation analyses the potential damaging effects of earthquake forces on the interior piping system was determined by computing stresses developed in various components of the piping systems. Different modes of failure in gas piping systems were identified as buckling, local yielding, and loosening of joints which could all result in leaks and consequently fire. Furthermore, employing reports on the Whittier-Narrows and San Fernando earthquakes a causal chain of events was introduced to explain the reason for relatively few numbers of gas related fires given the large number of reported leaks. The

authors also support previous findings that the higher incidents of electrical fires in the San-Fernando earthquake was the result of the spontaneity of occurrence of such fires in contrast to the dramatic chain of events needed for a gas fire to initiate.

Smith and McCorskie (1990) studied causes of wiring fires in residential buildings. Although in their study they did not directly investigate the effects of earthquakes on residential wiring, by pin pointing trouble spots in residential wiring and categorizing different modes of failure they provide a good understanding of the modes that may be critical in case of an earthquake. They site such specific problems as friction wear of cables, loosening of aluminum conductor connections at service panels, and point to the most frequent problem cited as "loose connections." It is emphasized that the risk of failure of connectors can be multiplied by cyclic movements such as those experienced in an earthquake.

1.4 Available Models on Fire Hazard Estimation

An in depth study of post-earthquake fire hazards which would lead to development of a model simulating initiation and spread of fires in urban areas would rely on a good statistical base encompassing aspects such as types of fires, intensity of the ground motion and soil type at the site of fire, and type and location of the structure. Employing such data any trends in occurrence of post-earthquake fires could

be identified. An understanding of these trends, in conjunction with a probabilistic study of the causal chain of events necessary for the fire spread in the structures, would provide for formulation of a procedure to be used in mitigating the risk of post-earthquake fires.

A primary work important to the direction of this study was the methodology developed by the URS corporation (1988) for estimating the risk of earthquake induced gas fires in residential housing. In order to estimate the probability of ignitions and flashovers following an earthquake, the method incorporated the Whittier-Narrows earthquake data as well as expert opinion and analytical studies. The collected data included damage to residential gas systems, United States Geological Survey isoseismals for the 1987 Whittier Narrows earthquake, distributions of residential gas appliances, distribution of different gas space heaters, distribution of pilots and IIDs (intermittent ignition devices) in residential gas components, and fire incident reports for the city of Los Angeles. Using the MMI scale, the effects of ground motions on gas burning appliances and their circumstances along with other potential causes of fire were investigated. A time-based event tree was developed to explain the causal chain of events from the time an earthquake occurs to the possible fires. The event tree contained five nodes with the earthquake occurrence as the initiating event, followed by component failure, ignition, availability of fuels, flashover and fire spread, and ending with categorizing the fire types.

Conditional probabilities were calculated for every branch of the tree by equating the conditional probability of every event along the tree to the product of the conditional probabilities of the preceding branches to that event. These conditional probabilities were based on analytical studies of the response of gas appliances to ground shaking and expert opinion questionnaires. Using a Bayesian updating method the Whittier-Narrows earthquake data was also combined with the analytical and expert opinion data. This study led to the development of a computer program which can estimate the maximum probable number of fires due to damages to gas systems by an earthquake.

Scawthorn (1987) introduces an alternate method for computer simulation of fire outbreaks following earthquakes. Four important aspects in computer modeling of post-earthquake fires; namely, intensity, ignitions, fire spread, and fire service operations are introduced and discussed.

Relations for fire growth in urban areas considering wind speed and direction as well as building density, materials, and time of occurrence have been taken into consideration. The problem of fire department response is also introduced, and using a time line scheme possible response scenarios and delays have been considered. The computer program was then tested by applying the model to the city of San Francisco for an earthquake with an 8.3 magnitude and number of initial fire outbreaks was estimated.

Other models for fire spread in urban areas such as " the

stochastic model for fire spread in urban areas based on fire brands effect" by Itoigawa and Tsukagoshi (1988), and Mizuno's (1978) method of correlating building collapses and ignitions have also been reported. These models, however; do not consider the risk of post-earthquake fire for a specific residential unit due to such factors as gas leaks, electric wiring problems, etc.

1.5 The Loma Prieta Event

Since the attempt here is not only to develop a general model for analysis of the risk of post-earthquake fires but also to corroborate the findings with actual statistics obtained from the Loma Prieta earthquake, it is in order to study the quake itself and the damages caused by it.

The Loma Prieta earthquake occurred at 5:04 p.m. local time on October 17th, 1989 as a result of a slippage of some 40 km of the San Andreas fault producing an estimated average surface wave magnitude of 7.1 on the Richter scale measured by the USGS. Its epicenter was located in the Santa Cruz mountains, 16 km North-East of Santa Cruz and 30 km South of San Jose. The quake resulted in widespread losses of life and property. The toll was reported as 62 deaths, Nearly 3800 injured, in excess of 7500 homeless, and property damages of \$5.6 billion dollars. Additionally in San Francisco alone 41 fires were reported. Figure 1.2 shows the ground motion records of the earthquake obtained from NISEE (National Information Service for Earthquake Engineering).






Figure 1.2. Time Histories for the Loma Prieta Earthquake of 1989

The Marina District of San Francisco was one of the hardest hit areas by the earthquake as a result of a significant ground motion amplification with intensity estimations of as much as 0.35 g's. In addition to the heavy structural damages in this area, an intense post-earthquake fire also completely destroyed one block of buildings in the Marina district. Such incidents demonstrate the urgency and the great need for comprehensive planning and hazard mitigation programs.

1.6 Contents of This Report

Chapter II presents a comprehensive evaluation of causes and effects of the Loma Prieta earthquake. Models for the sequence of events in a post-earthquake fire are described in Chapter III. In Chapter IV, risks of gas and electric-related fires are quantified. Chapter V focuses on estimating the risk of fires for San Francisco. Conclusions and Recommendations for additional studies are presented in Chapter VII.

CHAPTER II
EVALUATION OF CAUSES AND EFFECTS OF
FIRES FOLLOWING THE LOMA PRIETA EARTHQUAKE

2.1 Introductory Remarks

One of the most dramatic scenes after the earthquake on October 17, 1989 was the fire in the Marina District. As people viewed this event live on television, it appeared to many that the fire was one of the most severe consequences of the earthquake in terms of its destructiveness. Despite this dramatic event, the number of fires following the earthquake was relatively low for an earthquake with 7.1 Richters in magnitude and with about 0.3g maximum ground acceleration hitting some very populated areas. Several factors contributed to the relatively low number of fires. These are:

- Nearly zero wind speed in affected areas.
- Relatively short duration of the earthquake (about 40 seconds).
- Awareness on the part of fire departments in San Francisco and other localities on the potential fire hazard, quick response by fire departments to the emergency calls and well-managed fire fighting efforts.

An investigation into the origin and effect of the fires occurring after the earthquake is important especially for the purpose of preparedness for future earthquakes and risk mitigation. Presented in this section are: (i) a brief

description of the characteristics of the earthquake as it pertains to post-earthquake fires and fire fighting activities; (ii) a review of the numbers, locations, cause and effects of fires following the earthquake; and (iii) an analysis of the reported fires in terms of such parameters as site ground accelerations, types of soil and population concentration in affected areas.

2.2 The Loma Prieta Earthquake -- Fire Incidents

The event is considered as the most far-reaching and intense earthquake in California since the 1906 San Francisco earthquake and conflagration. Between 5:04 p.m. (when the earthquake occurred) and midnight on October 17, 1989, over 500 incidents were dispatched by the Communication Center of the San Francisco Fire Department alone. Due to the intensity of damage as a result of the earthquake, fire units, that were called upon to respond to emergencies, were often flagged down by citizens on the street for help. Accordingly, any one dispatch easily turned into three to four incidents according to the San Francisco Fire Department (SFFD) records. It is reported that telephone calls were being received at a rate of 500 to 600 per hour and that about 80% of the responses made by SFFD units on October 17 were to check on hazardous conditions such as natural gas leaks, falling chimneys and structural damage (SFFD Contacts 1990-1992).

The SFFD's first call was for a four-story 21-unit apartment building that collapsed. While responding to the

emergency at this location, fire fighters at the scene noticed the fire in the Marina District, several block away at Beach and Divisadero. Fire fighters responded to this fire and arrived at the scene at about 5:45 p.m. As a result of exposure to this fire, several other buildings in the area also caught on fire. The description of these and other fires is presented later.

The number of fires in the affected areas following the earthquake is summarized in Table 1.1. Most fires occurred on October 17 immediately after the earthquake. Additional fires also occurred on October 18, 19, and 20 (fire accident reports are provided in Appendix C).

2.3 Causes of Fires

A variety of reasons caused fires following the earthquakes. These causes are categorized in the following four groups:

- Gas leaks due to failure of pipes (interior or exterior gas mains) or gas appliances. Appliance failure is due to sliding or overturning of, for example, a water heater.
- Electrical system distribution problems or electrical appliance failure. Wiring problems are associated with overloaded cables and cords and electric shorts at joints, receptacles, etc.
- Flammable material spills.

- Overturning of burning candles, table lamps, gas grills, etc.

2.4 Types of Fires

For the purpose of this study, fires are categorized into four types. Each type is identified using fire department reports. This categorization is entirely based on the available data and can be changed subjectively.

Type 1. Fire only spreads into the immediate area around its point of origin.

Type 2. Fire catches on an ignitable material in the room of origin, spreads all over the room; however, it is only confined to the room of origin.

Type 3. Fire catches on an ignitable material in the room of origin, spreads all over the room and throughout the building.

Type 4. This type has the same characteristics as Type 3; however, it also spreads to adjacent buildings.

2.5 Investigation of Fires in San Francisco

As described in Table 2.1, 41 fires occurred in San Francisco. A complete listing of the locations of these fires is provided in Table 2.2, using the data acquired from SFFD. The four fire categories were used to determine the number of fires in terms of their severity. Additionally, Table 2.3 presents a distribution of fires versus their types and Figure

Table 2.1 Number of Fires by Area

Area	No. of Fires
San Francisco	41*
Berkeley	1
Santa Cruz County	20
Watsonville	3
Santa Clara County	1
Nisene Marks State Park	1

*Twenty-seven (27) fires occurred within seven hours after the earthquake; seventeen of which immediately after the earthquake.

Table 2.2 Locations of Fires in San Francisco


Location	Date	Origin
354 Byxbee St.	10-17-89	Electrical failure
350 Byxbee St.	10-17-89	Exposure to above
150 Font Blvd.	10-17-89	Electric lamp
69 Castenada Ave.	10-17-89	Gas explosion
3701 Divisadero St.	10-17-89	Not known
3717-19 Divisadero St.	10-17-89	Exposure to above
3723-25 Divisadero St.	10-17-89	Exposure to above
3729-35 Divisadero St.	10-17-89	Exposure to above
3735-37 Divisadero St.	10-17-89	Exposure to above
2130 Beach St.	10-17-89	Exposure to above
2136-38 Beach St.	10-17-89	Exposure to above
3739 Loyola Terrace	10-17-89	Stove
445 Bayshore Blvd.	10-17-89	Generator
428 Grove St.	10-17-89	Generator
965 Chenery St.	10-17-89	Candle
3999 Noriega St.	10-17-89	Stove
630/632 Cole St.	10-17-89	Wiring
1138 Valencia St.	10-18-89	Coffee pot
2095 Hayes St.	10-18-89	Hot plate
1954 McAllister St.	10-18-89	Stove
3867 Jackson St.	10-18-89	Lamp
1256 6th St.	10-18-89	Stove
300 16th St.	10-18-89	Stove
5 Galilee	10-18-89	Stove
754 Grant st.	10-18-89	Candle
818 30th Ave.	10-18-89	Stove
1020 Larkin St.	10-18-89	Barbecue
1308 Larkin St.	10-18-89	Candle
1 Daniel Burnham Court	10-18-89	Barbecue
1040 Bush St. #303	10-18-89	Candle
74 New Montgomery St.	10-19-89	Wiring
74 New Montgomery St.	10-19-89	Wiring
241 6th St. #231	10-19-89	Lamp
237 Post St.	10-19-89	Wiring
989 Post St.	10-19-89	Generator
1950 Stockton St.	10-19-89	Water heater
172 6th Ave. #401	10-19-89	Stove
1040 Sutter St. #62	10-19-89	Stove
5 George St.	10-20-89	Stove
299 Peru Ave.	10-20-89	Stove
48 Waller St.	10-20-89	Water heater

Table 2.3 San Francisco's Fires by Type

Location	Type
354 Byxbee St.	4
350 Byxbee St.	3
150 Font Blvd.	2
69 Castenada Ave.	1
3701 Divisadero St.	4
3717-19 Divisadero St.	4
3723-25 Divisadero St.	4
3729-35 Divisadero St.	1
3735-37 Divisadero St.	3
2130 Beach St.	4
2136-38 Beach St.	3
3739 Loyola Terrace	2
445 Bayshore Blvd.	1
428 Grove St.	2
965 Chenery St.	1
3999 Noriega St.	2
630/632 Cole St.	4
1138 Valencia St.	3
2095 Hayes St.	3
1954 McAllister St.	1
3867 Jackson St.	2
1256 6th St.	1
300 16th St.	1
5 Galilee	1
754 Grant st.	1
818 30th Ave.	1
1020 Larkin St.	1
1308 Larkin St.	2
1 Daniel Burnham Court	1
1040 Bush St. #303	2
74 New Montgomery St.	2
74 New Montgomery St.	1
241 6th St. #231	1
237 Post St.	1
989 Post St.	1
1950 Stockton St.	1
172 6th Ave. #401	1
1040 Sutter St. #62	1
5 George St.	3
299 Peru Ave.	1
48 Waller St.	2

2.1 depicts these fires on the San Francisco map. Shown on the map are also stations from which the earthquake ground acceleration data was recorded. In terms of causes, the fires were arranged in groups and the percentage of total number of fire in each group is summarized in Table 2.4. These percentages are also graphed in Fig. 2.2.

The largest fire started in the densely populated Marina District. This fire originated in a four-story wood-frame building at the corner of Divisadero and Beach St. The building was built in the 1920's. It contained 21 apartments and a parking garage on the ground floor. As a result of the earthquake, the two lower floors collapsed and the top floors leaned out for several feet. The cause of this fire is unknown; but it is believed to have originated at the rear of the building. Fire fighters arrived at the scene at approximately 5:45 p.m. The first engine connecting to a high pressure hydrant directly in front of the building found it to have no water pressure. Shortly after an explosion shook the building. Flames shot 100 feet into the air and the building wall fell onto the hydrant. The engine was then immediately repositioned across the street and continued to operate on the fire. Several exposed buildings were also ignited; fortunately, water was found and relayed from both a more distant hydrant and a lagoon at the Palace of Fine Arts. However, the attempt by a pumper to draft from the Marina Lagoon was unsuccessful due to low tide. To complicate matters several more explosions then occurred and the affected



- FIRE
- READING AT THE GROUND MOTION MONITORING STATION

Figure 2.1. Location of San Francisco's Fires

Table 2.4 Classification of San Francisco's Fires by Cause

No. of Fires	% of Total	Cause
6	14.62	Electric wiring
8	19.51	Electric equipment
11	26.83	Stove (gas/electric)
7	17.00	Not known
1	2.44	Gas explosion
2	4.87	Water heater
2	4.87	Other gas appliances
4	9.76	Miscellaneous




Figure 2.2. Percentage Distribution of the San Francisco Fires by Cause

buildings collapsed destroying a number of hose sections. At this time additional water had become available from the San Francisco Bay at the Marina Waterfront only two blocks away. Fire ground commanders called for the fireboat *Phoenix* and the portable water hose tenders. The fireboat and three hose tenders arrived at 6:00 and crews set up four major runs (a total of 6,000 feet) of 5-inch hose between the fire and the boat using nine portable hydrant. At least 10 engines were operating on the fire at this time. Water from the boat had a positive effect, and this fire was under control by about 8:00 p.m. Before all fire operations were concluded in the Marina District, the boat pumped 6,000 gpm for more than 18 hours (information excerpted from FEMA 1991).

Significance of Ground Acceleration -- Ground accelerations were only recorded at a few stations in San Francisco. These accelerations have been estimated and reported for the Marina District in (Shakal 1989). This information has been added to the measured values at the stations appearing on Fig. 2.1. Using linear interpolation, the ground accelerations at the location of the 41 fires in San Francisco were then estimated. Table 2.5 presents the number of fires and their types versus the ground acceleration in units of g. Although no strong correlation between the total number of fires and ground acceleration is obtained, the data in Table 2.5 does indicate a correlation between the number of Types 3 and 4 fires (combined) and the ground

Table 2.5 Number of Fires vs Ground Acceleration

Acceleration (g)	Type 1	Type 2	Type 3	Type 4	Total
0.05-0.10	2	1			3
0.11-0.15	13	6	3	3	25
0.16-0.20	4	1			5
0.21-0.30			3	5	8

Table 2.6 Number of Fires vs Ground Acceleration and Soil Types

Acceleration (g)	SB	USB	US	M&F	Total
0.05-0.10			3		3
0.11-0.15			2	23	25
0.16-0.20			5		5
0.21-0.30			3	5	8

SB: Stable Bedrock
 USB: Unstable Bedrock
 US: Unconsolidated Soil
 M&F: Mud and Fill

acceleration. Furthermore, the largest number of Type 4 fires occurred in the areas with relatively high ground acceleration. These fires, a total of 5, were all in San Francisco's Marina District - a highly populated area where numerous buildings were severely damaged.

Significance of the Type of Soil -- An examination of soil types reveals that the affected areas are mainly made up of four major types. These are:

1. Stable bedrock (SB). Ground shaking is not increased; ground failure is unlikely.
2. Unstable bedrock (UB). Ground shaking is slightly increased; this type is prone to land slides if present on steep slopes that are decomposed or water saturated.
3. Unconsolidated soil (US). Ground shaking is increased especially if is made of thick layers that are water saturated.
4. Mud and fill (M&F). Ground shaking is strongly increased; this type is prone to ground failure including liquefaction.

Figure 2.3 shows the 41 fires and their locations in reference to these four soil types.

The earthquake shock transmitted to the areas with unconsolidated soil and mud and fill is expected to be strongly amplified; whereas, the shock in unstable bedrock is only slightly amplified and in stable bedrock is not





Figure 2.3. Various Soil Types in San Francisco

amplified. Accordingly, because of a greater potential for building and lifelines damage in areas with unconsolidated soil or mud and fill, more number of fires are expected in these areas. An investigation of the 41 reported fires indicated that most fires (33 out of 41) occurred at sites on unconsolidated soil, 5 at sites on mud and fill, and the rest on stable bedrock. (see Table 2.6).

In regard to the large number of fires reported at sites on unconsolidated soil, the vastness of coverage of this soil type, compared with others, may be an important factor. Areas along the San Francisco Bay area are mainly mud and fill. However only a few fires were reported in these areas. This is attributed to the relatively less concentration of housing units (which means less population concentration) in these areas.

Significance of Population Density -- The city of San Francisco, excluding Presidio, has been divided into ten fire battalion districts by SFFD (see Fig. 2.4). Each district has been appointed mass care and casualty care facilities. At the time of the earthquake, San Francisco had 500 fire fighters. In response to a recall broadcast over radio and television, 651 members returned to duty to respond to emergency calls from all districts.

Using the ten districts as the basis for a geographical break down of the city, area, population, population density and the number of fires in each district are summarized in



POPULATION DENSITY (PEOPLE / 1000 S.F.)



Figure 2.4. Population Density of San Francisco

Table 2.7. Reviewing the data in Table 2.7, it is observed that more fires occurred in Districts 1, 2, 4, 5, 7 and 8. Furthermore by examining Figures 2.3 and 2.4, it becomes evident that over 51% of fires occurred in Districts 1, 2, 4 and 5 covering 20% of the total area. These serve to point to the fact that the population density of an area is a major factor in the number of potential post-earthquake fires. With no other factor considered, a correlation coefficient $r=0.65$ between the number of fires and population density was obtained.

In order to incorporate both the type of soil and the population intensity in the analysis of fires, a "soil type index" is introduced. The index signifies the effect of soil type in magnifying the ground acceleration at a given site. First a numerical value ranging between 1 to 4 is assigned to each soil type. This numerical value will be referred to as the "amplification capability value." A value equal to 1 means no appreciable amplification of ground acceleration occurs; whereas, a value of 4 indicates that a strong amplification is possible and expected. Within each district, surface areas covering each of the four types of soils are measured and multiplied by their respective amplification capability values (1 to 4) and summed up. The soil type index for the district is an average value obtained by dividing the sum by the total coverage area of the district. The results appear in Table 2.8. For all indices greater than 2.7 (this value is used as a cut-off), a multiple correlation analysis

Table 2.7 Number of Fires vs Population per District in San Francisco

Dist.	Area (Sq mile)	Population	Population Density*	No. of Fires
1	2.568	64,000	0.894	6
2	2.202	53,000	0.863	3
3	2.652	23,000	0.311	1
4	2.594	77,000	1.064	10
5	2.826	70,000	0.889	6
6	4.335	90,000	0.745	1
7	5.440	80,000	0.527	5
8	11.176	103,000	0.331	5
9	8.291	78,000	0.337	2
10	8.024	77,000	0.344	2

*Per 1,000 Sq. feet

between the number of fires, soil type index and population density indicates $r=0.87$. This emphasizes the significance of the combined soil type and population density in number of fires. The importance of these factors in earthquake preparedness and development of appropriate post-earthquake fire risk maps is explained later.

2.6 Fires in Other Areas

Aside from San Francisco, fires were also reported in Berkeley, Santa Cruz, Santa Clara and Watsonville. Berkeley had a major fire in an auto-service building. The fire started from the ignition of spilled solvents and required the response of the entire fire department (FEMA 1991).

Santa Cruz County had a total of 20 fires. The City of Santa Cruz had only one residential structure destroyed by fire. At the time of the fire department arrival, the structure was fully involved. The cause of this fire is reported as a main gas leak. Furthermore, a wildfire at Niesene Marks State Park in Santa Cruz was reported to have started due to the earthquake. The California Department of Forestry and Fire Protection responded to this fire, limiting it to 50 acres in a major effort involving engines crews and aircraft (FEMA 1991).

In Watsonville, one single-family dwelling and two mobile homes were destroyed due to fire. Difficulty due to broken water mains was also reported in Watsonville.

In Santa Clara County, a residential fire was reported. This fire started due to a ruptured propane tank. The community also lost its water distribution system. The water had to be provided from the community swimming pool.

2.7 Concluding Remarks

Although the number of fires were rather small considering the relatively large magnitude and intensity of this earthquake, nevertheless fire was considered to be a major problem especially in San Francisco. Furthermore, fires following the Loma Prieta Earthquake did confirm that:

- There is a potential for casualty and property loss due to post-earthquake fires,
- There exists a risk associated with residential fires following a major earthquake, and
- An effort should be devoted to estimate this risk and plan for risk mitigation.

A large number of reported fires were initiated at residential buildings. These fires required a major fire fighting effort at a time that the fire department personnel were much needed for rescue efforts involving other earthquake-related incidents. In some cases (e.g., Berkeley) the fire required the response of the entire fire department. It is also noted that water needed for fire fighting activity was not easily available due to broken water mains and low water pressures. For example in the Marina District, loss of pressure was especially critical. Damage to the municipal

water supply system in the Marina District cut off alternative sources of pipeline water and caused delay in fire fighting activities. This clearly indicates that any effort to mitigate the risk of such future fires should not be limited to development of estimates for the probability of fire but should also consider the availability of alternative sources that can quickly be utilized to detain a potential fire. This becomes especially critical at populated areas. One major consideration is to identify alternative sources to obtain water needed for fire fighting activities.

An investigation of cause of fires following the Loma Prieta earthquake revealed a variety of reasons that can cause fire after any future earthquake. As such, development of a systematic analytical approach to estimate the risk of fire following a probable earthquake becomes quite complicated. At best, any attempt to develop methods to estimate the risk can only include a limited number of fire causes. Analytical methods to estimate the probability of fire for such causes as leaks in gas distribution systems, failure of gas appliances, and electrical distribution system problems can be developed only within certain limitations. In most cases, such analytical methods need to be complemented by historic data from past occurrences or judgmental data obtained from experts. Although such models may only cover a portion of all causes, they are, nevertheless, helpful to identify the magnitude of the risk involved in post-earthquake fires. Such models are especially helpful in investigation of

effectiveness of pre-earthquake planning risk mitigation. For example, the effectiveness of securing water heaters to walls using straps can be evaluated in terms of the reduction in the probability of overturning or sliding.

Chapter III

SEQUENCE OF EVENTS IN POST-EARTHQUAKE FIRES

3.1 Introductory Remarks

A systematic formulation of the sequence of events that lead to a post-earthquake fire is only possible by adopting certain assumptions, approximations and restrictions. This is due mainly to the variety of factors that contribute to post-earthquake fires. An investigation of causes of fire in several past earthquakes and especially in the 1989 Loma Prieta earthquake (see Chapter II) reveals the following reasons for fires:

- Electrical distribution system problems such as friction wear of cables and cords, loose connections, etc.
- Gas leaks due to pipe failure, sliding, or overturning of gas-fired appliances mainly water heaters.
- Flammable materials spills.
- Overturning of burning candles, table lamps, gas grills, etc.

Although these causes seem to be reasonably well-defined and easy to model, in reality each post-earthquake fire represents a unique event following a series of other events that are very much dependent upon the surrounding environment and existing circumstances. A somewhat generic approach in modeling the sequence of events in a post earthquake fire can be done only with certain limitations and approximations. Even so, the modeling cannot be accurately performed for such

casual causes as, for example, flammable materials spills, overturning of burning candles, and burning cigarettes discarded by people in the state of panic. For more systematic causes, such as gas leaks and electrical problems in distribution systems, the modeling is more straightforward and involves activation of specific events that can be modeled using an event tree analysis (Ang and Tang, 1984). In the following sections, the sequence of events in the case of gas- and electric-related fires is explained. Event tree models are presented in terms of events that lead to a fire. The probabilities of these events is described in Chapter IV. Quantification of estimates for the risk of fire are obtained and presented in Chapter V.

3.2 Sequence of Events in Gas-Related Fires

The chain of events that may lead to a gas-related fire is summarized below:

- Following an earthquake, overstress in the piping system components or an overturning or sliding of an appliance (water heater) occurs.
- Leak develops.
- Leak is undetected; and gas is accumulated in an enclosed area.
- Gas density in the air reaches an ignitable level.
- An ignition sources is activated.

This chain of events often stops at the fourth or fifth level. In a dwelling equipped with an automatic seismic shut-

off valve, the above chain of events can practically stop at the second level. It is also noted that if the house is equipped with a sprinkler system, the above sequence of events may stop short of a fire. If a right condition persists and the above chain of events is followed to the end without any interruption, a fire will develop. The right condition means development of a leak in an area susceptible to gas accumulation and fire. An investigation into the 1987 Whittier Narrows earthquake (Schiff, 1988) revealed that about 75% of gas leaks occurred at appliances (primarily at water heaters). Similar results were also noted after the San Fernando earthquake of 1971. Water heaters are normally installed in basements, garages and enclosed areas where potential combustible materials (old furniture, papers, gasoline cans, etc.) are stored. The fact that a greater percentage of leaks occur at water heaters suggests that certain precautions (e.g., using straps to secure heaters) can be helpful in mitigating the risk.

A graphic presentation of the chain of events that may lead to a gas-related fire following a probable earthquake is given in Fig. 3.1 using the "event tree" scheme. It is assumed that there is no sprinkler system in the house. This, of course, will lead to more conservative probability estimates for post-earthquake fires. The starting event (A) is an earthquake of a given intensity (in terms of MMI or ground acceleration). This is followed by various levels of "follow-up" events which ultimately lead to a fire. Within




Figure 3.1. Sequence of Events in a Gas-Related Fire

each group of follow-up events, two or more mutually exclusive and collectively exhaustive events appear in the tree. Immediately following the earthquake, there may be leaks in the system (Event B). This can be the result of piping system and/or appliance failure (failure means over stress in piping system components or overturning/sliding of an appliance). The next level contains events D and \bar{D} (\bar{D} is the complementary event of D). These events represent leak being detected or remained undetected, respectively. The sequence is then continued at next level which contains the event of having an ignition source active in the area (Event E). Upon occurrence of E, there will be a fire.

Four types of fires are designated as C_1 , C_2 , C_3 and C_4 which represent the "consequences" in the tree. The description of each type of fire is explained below:

- Type 1 Fire spreads only into the immediate area around its point of origin.
- Type 2 Fire catches on to a combustible material in the room of origin, spreads all over the room; however, it is only confined to the room of origin.
- Type 3 Fire catches on to a combustible material in the room of origin, spreads all over the room and throughout the building.
- Type 4 This is a Type 3 fire that also spreads to the adjacent buildings.

Development of a specific type of fire among the four types described above depends on the location of the fire,

availability of combustible materials in the area where fire starts and fire fighting efforts. Types 3 and 4 are much less expected than Types 1 and 2 mainly due to quick response time by fire departments.

The probability of occurrence of the consequences (i.e., fires) in the tree of Fig. 3.1 can be obtained using the conditional probability formulation (Ang and Tang, 1984). For a consequence such as C_i ($i=1,2,3,4$), the probability $P(C_i)$ is written as follows:

$$P(C_i) = P(C_i|E)P(E|D)P(D|B)P(B|A)P(A) \quad (3.1a)$$

if leak is detected.

$$P(C_i) = P(C_i|E)P(E|F)P(F|\bar{D})P(\bar{D}|B)P(B|A)P(A) \quad (3.1b)$$

if leak is not detected.

It is noted that events \bar{B} , \bar{E} and \bar{F} do not participate in the sequence of fire development. The two $P(C_i)$'s are then added, to consider the fact that there are two possible branches leading to a fire. Furthermore, it is emphasized that the tree in Fig. 3.1 is only intended to show the flow of events. A conditional probability in Eqs. 3.1 describes the occurrence of an event followed by another event. This means the two events may not necessarily be dependent. Thus the term "conditional" as used here only describes the order of events in the tree as this is needed to lead to a fire.

Estimation of $P(C_i)$ requires that all probabilities involved in Eqs. 3.1 be quantified. Mathematical modeling can be employed to quantify some of these probabilities. For example, as described in Chapter IV, an appliance failure

probability can be estimated by modeling the motion of the appliance subjected to a known earthquake record (e.g., the 1989 Loma Prieta earthquake record) and investigating the possibilities of overturning or sliding. The probability of an earthquake of a given intensity (Event A in the tree), can be obtained using one of several available seismic risk analysis models (e.g., Cornell, 1968; Derkiureghian and Ang, 1977; Mohammadi and Suen, 1991).

In case where mathematical modeling are not possible, the needed probability values can be obtained by extrapolating available data that are used for representing ordinary (i.e., non-earthquake) conditions. The probability of leak development in interior piping systems under normal operative conditions has been established by Longinow, et al (1989). An earthquake can increase this probability in the sense that it will trigger certain parameters that are known to be effective in promoting leak in a piping system. One such factor is the stress generated at joints and fittings in the system. The extrapolation of probability of leak in the system accounting for the earthquake effect can be done based on the stress level induced in piping system components. This is explained in Chapter IV.

3.3 Sequence of Events in an Electric Fire

Current research results indicate that there are numerous causes for fires initiated in electrical distribution systems and/or electric appliances operating under normal (i.e., non-

earthquake) conditions. Potential fire causes, among others, are ground fault, improper installation, equipment overload, loose connections, worn-out wires and electrical components, etc. Smith and McCoskry (1990) report on causes of fires in electrical distributions system in residential units. A typical electrical distribution system constitutes the following components:

- Branch circuit wiring
- Receptacle outlet and switches
- Cords and plugs
- Fixtures and lamps
- Transformers

A detailed description of distribution of electric fires among these components and various categories of fire causes as summarized by the Fire Protection Handbook published by the National Fire Protection Association, NFPA (1986) is presented in Chapter IV. In the event of an earthquake, the electrical distribution system is especially critical because the ground shaking can trigger displacements of electrical components and friction of wiring and cords against each other. Such phenomena will increase the risk of fire. However, development of a comprehensive model for the behavior of an electrical distribution system as a means to estimate the risk of fire is quite challenging. The probability of fire development depends on a variety of factors including the design of the system, the age of the electric components, installation practice, existence of faulty wiring, overloaded

components, etc. In this section, the sequence of events that may lead to an electric fire is explained. The risk of fire due to an earthquake is estimated by extrapolating the risk representing the ordinary (non-seismic) condition as described in Chapter IV.

The sequence of events in an electric fire is shown in the event tree of Fig. 3.2. The tree is intended to demonstrate the role of key parameters that may accelerate the risk of fire when an earthquake occurs. As seen in Fig. 3.2, upon occurrence of an earthquake of given intensity (Event A), the first follow-up event is designated as development of a disturbance in the electrical distribution system (Event B). The disturbance comprises the occurrence of one or more of the following events:

- Excessive friction in electrical wires and cords with one another especially at joints, connections, receptacles and switches.
- Electrical shorts at connections and joints due to severe structural vibrations.
- Electrical problems arising from swinging lamps and other suspended fixtures.
- Electrical problems and overload at extension cords, cables, and receptacles due to overturning and sliding of electric appliances and equipment.

Generally, upon occurrence of one or more of these disturbances, the risk of fire is expected to increase. The extent to which the risk increases depends primarily on the




Figure 3.2. Sequence of Events in an Electrical Fire

intensity of the earthquake and the design and age of the electrical distribution system. The risk is also triggered by the follow-up events D_1 , D_2 , D_3 , and E . Events D_1 , D_2 , and D_3 describe what can occur as a result of partial, full or no electricity cut-off due to either an internal control switch or the area black out. The former has a greater chance to occur. Event E (and its complementary) describe the effect of the duration of the ground shaking. The longer duration has a greater effect on development of an electric fire in the sense that it causes a longer exposure time for wires and cords to engage in friction and for swinging fixtures to get the momentum needed for them to develop an electrical problem.

The consequences are again fire types 1-4. The probability of a sequence C_i is obtained through the following equations:

$$P(C_i) = P(C_i|E)P(E) + P(C_i|\bar{E})P(\bar{E}) \quad (3.2a)$$

$$P(E) = \sum_{j=1,3} P(E|D_j)P(D_j) \quad (3.2b)$$

$$P(D_j) = P(D_j|B)P(B|A)P(A) \quad j=1,2,3 \quad (3.2c)$$

$$P(\bar{E}) = 1 - P(E) \quad (3.2d)$$

Quantification of the risk in terms of $P(A)$, $P(B)$, ... is explained in the next chapter.

Again, it is emphasized that conservatively it is assumed that there is no sprinkler system installed in the house. Also it is noted that the conditional probability terms appeared in Eqs. 3.2 are only intended to describe the flow of events that are needed for a fire to occur.

CHAPTER IV
RISK QUANTIFICATION

In this chapter the risk of post-earthquake fires is estimated in terms of probabilities of various events appearing in the event trees of Figures 3.1 and 3.2. All calculations are performed for ground acceleration in the units of g. A correlation between g accelerations and intensity (MMI scale) is provided later in this Chapter (see Fig. 4.2).

4.1. Leak Probability of Gas System

An analytical approach to quantify the probability of leak in an interior gas distribution system is difficult to establish. This is mainly due to:

- Lack of adequate data on the performance of piping systems. Specifically, the data on the resistance capacity of individual piping system components and joints to leak development is scarce.
- Variety of factors (corrosion, bad installation practice, material defect, etc.) that influence leak development. In the event of an earthquake, the interaction of the dynamic force generated at a joint with these factors will increase the chance of leak development. However, the extent to which the risk may increase is not well known.

Moreover, most interior gas distribution piping systems

are installed without any specific design for the effect of earthquake loadings. The geometry of the system is very much dependent on the type of structure and building plan. Thus the existence of varieties in the geometrical design of piping systems makes the development of a generic analytical modeling somewhat difficult.

Factors that contribute to leak development at a given joint were reported by Longinow, et al. (1989). These factors were identified through a comprehensive search in the literature, failure reports and expert opinion data. Among others, the following factors are especially notable.

- Poor workmanship
- Corrosion
- Tampering
- Material defect
- Pipe movement due to natural forces or due to reconstruction or remodeling

An expert opinion data acquisition technique was especially designed to obtain performance data for interior gas piping systems (Longinow et al., 1989; Mohammadi, et al, 1991). The expert opinion data revealed that "poor workmanship" has the greatest probability of causing a leak at a joint (0.298×10^{-4} probability/year). The study by Longinow, et al. also established expert opinion data on the probability of leak development at various locations in a piping system. Table 4.1 summarizes these probabilities.

For a typical single family dwelling (with four bedrooms,

Table 4.1 Probability of Leak at Various Piping System Components

Components	Leak Probability (10^{-4})/year
Primary pipe	0.0303
Branch pipe	0.2097
Fitting	0.1232
Shut-off valve	0.0721
Appliance flexible connector	0.0968
Heater connector	0.0410
Threaded joint	0.1375
Welded joint	0.0037
Compression fitting	0.0470
Appliance regulator	0.0111
Service regulator	0.0071
Relief valve	0.0038

a living room, kitchen, basement and family room) the probability of leak was estimated to be 0.00132 per year. This was obtained using a fault tree analysis of the gas distribution system and the corresponding modes of failure (i.e., leak development at various gas system components).

The data presented in Table 4.1 shows the statistics of gas leak when the system is under normal conditions. Once an earthquake occurs, these probabilities will increase. The increase, of course, depends on the ground acceleration experienced by the piping system and the system interaction with the structure. An earthquake mainly causes an increase in the external load effect on the piping system components and makes the components more susceptible to leak development. However, the major question to be addressed is: "to what extent the leak probabilities will increase once an earthquake of, say, 0.20g or 0.30g occurs?" Since the leak data for different earthquake ground acceleration levels is not available, one method to quantify the risk of leak development due to an earthquake will be to augment the estimated values of Table 4.1 based on the level of force actions (bending, shear and axial force) and deflections developed at various piping system components; especially at joints, fittings, etc.). For this purpose, several piping system configurations as shown in Fig. 4.1 are considered and subjected to the Loma Prieta record. The record was adjusted to obtain different ground acceleration levels. The configurations depicted in Fig. 4.1 present portions of gas distribution systems mainly





Figure 4.1. Interior Gas Piping System Configurations Used in the Dynamic Analyses




Figure 4.1. (Continued)

in the basements or garages where heaters are located in single family dwellings. In most cases, the piping system attachment to walls or structural elements is loose. Thus the piping system will experience the ground motion through the meter and gas main or through the basement retaining wall. This means that no appreciable dynamic interaction between the piping system and the structure will take place.

It is also noted that the probability estimates given in Table 4.1 are treated as "bench marks" representing risks in a normal condition. Since small earthquake intensity levels are not likely to dramatically change these probabilities, a lower bound intensity is used as a level below which these probabilities can be assumed unaffected. This lower bound earthquake level was determined to be V on the MMI scale and was decided upon by reviewing reports of earthquake damage evaluation for several past earthquakes.

At or below this level, the risk of gas leak development is practically unaffected by the earthquake and is the same as that summarized in Table 4.1.

The intensity V on the MMI scale translates into about 0.05g for most past California earthquakes. Figure 4.2 shows the variation of MMI versus ground acceleration levels. The ground motion attenuation equations reported by Donovan (1973) and Newmark and Rosenblueth (1971) were used to arrive at the MMI-acceleration variation depicted in Fig. 4.2.




Figure 4.2. Modified Mercalli Intensity (MMI) vs. Ground acceleration in g's

4.1.1. Effect of Higher Acceleration on Risk of Leak in the Interior Gas Pipeline Systems

Table 4.2 summarizes the results of stresses developed at the most critical joint of systems in Fig. 4.1. The results are based on the Loma Prieta earthquake record adjusted for 1g acceleration. The record was applied in the longitudinal and transversal direction for each of the three structures in Fig.4.1 and the maximum stresses were then computed. Presented in Table 4.2 are also the maximum percentage of yield at the most critical joints. As seen in the table, under 1g application, the stresses are about 53% of yield. For the Loma Prieta record, this level is only exceeded for a few times. Thus it is concluded that the earthquake does not increase the risk of leak development in the gas piping system. The risk values presented in Table 4.1 are generally unaffected by the earthquake. An increase in the risk is however expected if a defect exists in the piping system especially at very high level accelerations that occur rarely.

4.2. Risk Associated with Appliance Failure

Failure in an appliance is defined, here, as overturning or sliding due to an earthquake. This means that once an appliance is dislodged or toppled, a leak will occur. The risk of failure for various types of appliances (water heaters) can then be obtained by modeling the movement of an appliance during an earthquake. Overturning will occur when

Table 4.2 Maximum Principle Stresses (psi) at Pipe Joints
for 1g Normalized Record of the Loma Prieta Earthquake

System	σ_1	σ_2	Max % of Yield*
Fig 4.1 a	19180	2551	53
Fig 4.1 b	8801	1134	24
Fig 4.1 c	11300	1498	31

*Yield Stress=36000 psi

[Note] σ_1 and σ_2 are principal stresses for the most critical stress condition.

the appliance loses its stability. If the appliance is secured to the wall by means of metal straps, the probability of overturning greatly reduces. In this case, the possibility for overturning exists practically only when the straps are not adequately attached to studs in the wall. The metal straps may fail (separated from the wall) due to a weak or missing screw. The formulation of overturning for both cases of appliance with and without straps is explained next.

4.2.1 Appliance Without Straps

The possibility of overturning depends primarily on the geometry of the appliance, its connections to the gas and water lines and, of course, the ground motion acceleration experienced by the appliance. Figure 4.3 shows four types of water heaters which are widely used in apartments and single family dwellings. The information on these heaters was obtained through retailers distributing water heaters to consumers. Several other types are also available. However, the four types depicted in Fig. 4.3 (designated as Type A, B, C and D) were used in the analysis due to their popularity.

In a generic form, an appliance (water heater) is similar to that shown in Fig. 4.4a. As shown in Fig. 4.4a, the pipe gas connection is a short link attached to a vertical pipe (riser) which, in turn, is connected to the piping system overhead. Water lines are generally directly connected to the heater from the top. For the purpose of stability analysis, the appliance in Fig. 4.4a is modeled with the dynamic system




Figure 4.3. Four Typical Water Heaters Used in Single Family Dwellings




Figure 4.4. Unstrapped Water Heater,
 (a) Typical Water Heater, (b) Idealization
 for Dynamic Analysis, (c) Failure Paths




Figure 4.4 (continued)

depicted in Fig. 4.4b. The idealized model is made of solid elements (representing the appliance) and beam elements representing the pipes.

When an earthquake occurs, depending on the direction of the earthquake, severe bending and shear stresses can develop in gas and water pipes. In a worst case scenario, where the gas pipe is similar to that shown in Fig. 4.3, maximum stresses can develop at junction A of the gas pipe (see Fig 4.4a). Failure (gas leak) will occur when stresses exceed the joint resistance.

Maximum stresses develop at junctions A (of the gas pipe) and/or B (of the water pipes). The sequence of failure and the two possible failure paths are shown in Fig. 4.4c. If the probability of failure through paths 1 and 2 is represented by fp_1 and fp_2 , one can respectively write:

$$fp_1 = P(E_1) \quad (4.1a)$$

$$fp_2 = P(E_1|E_2)P(E_2) \quad (4.1b)$$

in which E_1 =event of overstress in the gas pipe, E_2 =event of over stress in the water pipes and $E_1|E_2$ = conditional event of E_1 given E_2 . It is noted that once E_2 occurs, the distribution of stresses will change, and as a result, $P(E_1|E_2)$ may greatly increase. The computation of probabilities in Eq. 4.1 depends on the stresses developed in the pipes. Adapting the Tresca yield theory (Popov, 1968), if principal stresses at a critical location are σ_1 and σ_2 , failure will occur according to the following criteria:

$$\sigma_1 - \sigma_2 = F_y \quad (4.2a)$$

$$\sigma_1 = F_y \quad (4.2b)$$

$$\sigma_2 = F_y \quad (4.2c)$$

in which F_y = yield strength of the material.

Based on the criteria in Eq. 4.2, $P(E_1)$ is:

$$P(E_1) = \max[P(\sigma_1 - \sigma_2 > F_y); P(\sigma_1 > F_y); P(\sigma_2 > F_y)] \quad (4.3)$$

In deriving Eq. 4.3, it is assumed that the three events are highly correlated. This is a reasonable assumption in the sense that all three relations in Eq. 4.3 contain common parameters. Furthermore, σ_1 and σ_2 are affected by the same cause (i.e. ground acceleration) that make them highly correlated. Similar equations can also be written for $P(E_2)$ and $P(E_1|E_2)$.

In evaluating the probability terms in Eq. 4.3, principal stresses σ_1 and σ_2 and the yield strength F_y are treated as random variables. Randomness in the stresses is due to:

- Variation in workmanship and method of construction of the joint. This will be reflected in the stiffness of the piping system which in turn affects the stress results.
- Variation in pipe dimensions due to initial imperfection, corrosion, wear, etc.
- Variation in material properties.
- Variation in the method of stress analysis.

These variabilities result in uncertainty in the stress values obtained through analysis. If nominal stress values are denoted as $\sigma_1^{(n)}$ and $\sigma_2^{(n)}$, the random stresses σ_1 and σ_2 will then be written as:

$$\sigma_1 = C_1 \sigma_1^{(n)} \quad (4.4a)$$

$$\sigma_2 = C_1 \sigma_2^{(n)} \quad (4.4b)$$

in which C_1 (a random variable) is a correction factor that incorporates the aforementioned variations.

To precisely quantify the mean and standard deviation of C_1 is a challenging task. With the exception of variation in the material properties, the variability associated with the other factors has not been well studied. If there is no bias in C_1 , its mean will be 1. The uncertainty in C_1 will then appear in the form of a coefficient of variation (COV) that includes all various levels of uncertainties resulting from the factors cited earlier (Ang and Cornell, 1974). Since the nominal stress values are deterministic, the COV of stress σ_1 and σ_2 is then equal to that in C_1 .

The resistance of the joint (i.e., F_y) depends on the material yield strength, the threads resistance against overstress, the type of joint (elbow, tee, straight fitting), workmanship, etc. Specific data on the resistance of a joint with considerations for these factors is not available. Ideally, the joint resistance can be written as:

$$F_y = C_2 F_y^{(n)} \quad (4.5)$$

in which $F_y^{(n)}$ = nominal yield capacity of the pipe and C_2 = a random variable that takes into account all possible factors that may influence the resistance of the joint. With proper workmanship and under idealized conditions, the mean value of C_2 is expected to be equal to 1 (i.e., $\bar{C}_2 = 1$). However, generally, $\bar{C}_2 \leq 1$ when a large variation is expected in C_2 .

The probability terms in Eq. 4.3 can be formulated in terms of the mean and COV of the stresses and F_y . For example, for $P(\sigma_1 - \sigma_2 > F_y)$, the formulation is as follows:

Let $Z = F_y - (\sigma_1 - \sigma_2)$, then $P(\sigma_1 - \sigma_2 > F_y) = P(Z \leq 0)$ and

$$\bar{Z} = \bar{F}_y - (\bar{\sigma}_1 - \bar{\sigma}_2) \quad (4.6)$$

and

$$S_z = [S_f^2 + (S_1^2 + S_2^2 + 2S_1S_2\rho)]^{1/2} \quad (4.7)$$

in which bar indicates the mean value, S_z = standard deviation of Z , S_f = standard deviation of F_y and S_1 and S_2 = standard deviation of σ_1 and σ_2 , respectively (Ang and Tang, 1975). Parameter ρ is the correlation coefficient between σ_1 and σ_2 ($\rho = 1$ is used here). Using a normal probability distribution for Z ,

$$P(Z \leq 0) = 1 - \Phi(\bar{Z}/S_z) \quad (4.8)$$

in which Φ is the normal probability distribution function (Ang and Tang, 1975).

Similar equations for $P(\sigma_1 > F_y)$ and $P(\sigma_2 > F_y)$ can also be obtained.

The four types of water heaters (see Fig. 4.3) were analyzed for the acceleration record of the 1989 Loma Prieta earthquake. The analysis was conducted for the following two cases:

- Gas pipe fails first (i.e., Event E_1 occurs)
- Water pipes fail first, then gas pipe fails (Events E_2 occurs followed by E_1)

Table 4.3 summarizes stress σ_1 for 0.1g amplitude ($\sigma_2 \approx 0$). As seen in Table 4.3, for Types C and D heaters, failure of water

Table 4.3 Values of Stress σ_1 (psi) for 0.1g Amplitude

Heater	All Pipes intact	Water Pipes Failed
A	16,554	26,031
B	10,006	33,187
C	26,916	*
D	37,936	*

*Failure of water pipes will cause instability in heater and lead to failure of gas pipe also.

pipes causes instability in the heaters and thus leads to gas pipe failure. Using various amplitudes for the Loma Prieta record, the stresses σ_1 and σ_2 were obtained and used in Eqs. 4.3 and 4.8 to compute pf_1 and pf_2 . In calculating the mean stresses, the COV in C_1 and C_2 were taken as 0.2 and 0.1, respectively. The probability results appear in Table 4.4. The probability of failure (P_F) of a heater (i.e., gas leak) is obtained based on the failure probabilities of the individual paths as follows (Ang and Tang, 1984):

$$\max(pf_1, pf_2) \leq P_F \leq 1 - (1 - pf_1)(1 - pf_2) \quad (4.9)$$

We have selected the upper bound value in Eq. 4.9 as a conservative estimate for P_F . The results are summarized in Table 4.5 and graphed in Fig. 4.5.

4.2.2 Appliance with Straps

When the appliance is secured to a wall, the probability of failure reduces substantially. Figure 4.6 shows a typical scenario in which a metal strap is used to protect a heater. In this case the failure of the strap and its fasteners (screws or nails) are critical to the overall probability of overturning or sliding of the heater. Once the strap fails, the appliance behaves as the unprotected system explained in Section 4.2.1. Thus the failure probability f_p is:

$$f_p = P(F_A | F_S) P(F_S) \quad (4.10)$$

in which F_A =event describing the failure of appliance without a strap (as described in Section 4.2.1) and F_S =event




Figure 4.5. Leak Probabilities For Unstrapped Water Heaters




Figure 4.6. Strapped Water Heater, (a) Typical Water Heater, (b) Idealization for Dynamic Analysis

Table 4.4 Summary of Failure Probabilities pf_1 and pf_2

Peak Accel (g)	pf_1				pf_2			
	A	B	C	D	A	B	C	D
0.05	0	0	0	.001	0	0	0	0
0.10	0	0	.081	.591	0	0	0	.461
0.15	.012	0	.688	.942	0	0	.003	.903
0.20	.352	.002	.942	.995	0	0	.117	.986
0.25	.726	.038	.988	.999	.004	.001	.452	.997
0.30	.902	.198	.997	1	.049	.014	.745	1
0.35	.965	.363	1	1	.188	.084	.894	1
0.40	.986	.677	1	1	.405	.242	.955	1
0.45	.994	.824	1	1	1	.436	.981	1
0.50	.997	.907	1	1	1	.618	.991	1
0.55	1	.950	1	1	1	.758	.995	1
0.60	1	.973	1	1	1	.851	.997	1

Table 4.5 Summary of Leak Probabilities for Various Heaters

Peak Accel (g)	Leak Probability P_F			
	A	B	C	D
0.05	0	0	0	.001
0.10	0	0	.081	.780
0.15	.012	0	.689	.994
0.20	.352	.002	.949	1
0.25	.726	.039	.993	1
0.30	.907	.209	.999	1
0.35	.972	.417	1	1
0.40	.992	.755	1	1
0.45	1	.901	1	1
0.50	1	.964	1	1
0.55	1	.989	1	1
0.60	1	.996	1	1

describing the failure of the strap. Simulation analyses are needed to quantify $P(F_s)$ as described below.

The event F_s is the key parameter in Eq. 4.10. Once the earthquake-generated force in the strap exceeds the resistance capacity of the strap, it will fail. Resistance capacity of the strap depends on:

- Fasteners holding force
- Strap metal yield capacity
- Strap metal tear capacity
- Fasteners shear or bearing capacity

Table 4.6 presents the capacity of a strap made of a 1x1/8 inch steel (A36) strap and 1/4-in. diameter screws. As seen in the table, the capacity is determined by the fastener pull-out force. This means that the strap size will not drastically affect the capacity. Furthermore, the various modes of failure summarized in Table 4.6 are expected to be highly correlated. Thus the smallest value (i.e., the pull-out capacity) will dominate any potential failure. The pull-out capacity is highly random and varies with the size and type of fastener, density and type of studs, workmanship, etc. The variation given in Table 4.6 is for specific gravity of stud material ranging between 33 to 44 PCF oven dry condition. Environmental conditions such as humidity and dampness can reduce the pull-out strength. On the other hand, the use of special cements and composites in drilled holes (which are made for fasteners) can increase the strength. The variability (coefficient of variation, COV) in the strength

Table 4.6 Capacity of the Strap

Mode of Failure	Capacity (lbs)
Fastener pull-out ¹	110-170
Metal yield ²	2,700
Metal tear ²	2,262
Fastener shear ²	491
Metal Bearing ² (at the fastener)	453

1 Information from Avalone and Baumeister (1978), Table 12.2.4.

2 Obtained based on strength formulas in Manual of Steel Construction, for gross and net areas of a bar subjected to tension (AISC-ASD, 1989).

due to material type is $0.58(167-110)/(167+110)=0.12$ (based on a uniform distribution ranging between 110 to 167). Using a 0.25 COV for other uncertainties, the total COV (i.e., Ω_R) in pull-out strength is:

$$\Omega_R=(0.12^2+0.25^2)^{1/2}=0.28$$

The mean pull-out strength $\bar{R}=(167+110)/2=138.5$ lbs. If the force generated in the strap due to an earthquake of given acceleration is P , then

$$P(F_s)=P(R \leq P)=P(Z \leq 0)=1-\phi(\bar{Z}/S_z) \quad (4.11)$$

in which R =random variable describing the resistance, $Z=R-P$, bar indicates mean, S =standard deviation, and ϕ the normal probability distribution function.

$$\bar{Z}=\bar{R}-\bar{P}$$

$$S_z=(S_R^2+S_P^2)^{1/2}$$

Furthermore,

$$S_R=\Omega_R\bar{R}=0.28\bar{R} \text{ and } S_P=0.2\bar{P}$$

in which 0.2 is the COV of the force in the strap. This is the same COV used in Section 4.2.1.

A series of simulation studies was conducted to determine the force P generated in the strap. The strap (see Fig. 4.6) was idealized as a loose link effective mainly to an axial load. Using the Loma Prieta earthquake record, the force in the strap and the corresponding probabilities of appliance failure are computed (from Eq. 4.10) and summarized in Tables 4.7 and 4.8. The failure probabilities are also graphically shown in Fig. 4.7.

Table 4.7 Probability of Failure of Strap

Acceleration (g)	Force in Strap (lbs)				P(F _s)			
	A	B	C	D	A	B	C	D
0.05	3.6	4.5	5.5	7.1	.0002	.0003	.0003	.0003
0.10	7.1	9.0	11.1	14.3	.0003	.0004	.0005	.0007
0.15	10.7	13.5	16.6	21.4	.0005	.0006	.0009	.0013
0.20	14.2	18.0	22.2	28.5	.0007	.0010	.0014	.0025
0.25	17.8	22.5	27.7	35.6	.0010	.0015	.0023	.0045
0.30	21.4	27.0	33.3	42.8	.0013	.0022	.0038	.0080
0.35	24.9	31.5	38.8	49.9	.0018	.0034	.0049	.0136
0.40	28.5	36.1	44.4	57.0	.0025	.0047	.0089	.0222
0.45	32.1	40.6	49.9	64.1	.0034	.0068	.0136	.0351
0.50	35.6	45.1	55.5	71.3	.0047	.0094	.0197	.0526
0.55	39.2	49.6	61.0	78.4	.0060	.0132	.0281	.0749
0.60	42.7	54.1	66.6	85.5	.0080	.0179	.0401	.1056
0.65	46.3	58.6	72.1	92.6	.0104	.0244	.0548	.1423
0.70	49.9	63.1	77.7	99.8	.0136	.0322	.0722	.1867
0.75	53.4	67.6	83.2	106.9	.0170	.0418	.0951	.2389
0.80	57.0	72.1	88.8	114.0	.0217	.0548	.1210	.2946
0.85	60.0	76.6	94.3	121.1	.0274	.0694	.1539	.3520
0.90	64.1	81.1	99.9	128.3	.0344	.0708	.1894	.4129
0.95	67.7	85.6	105.4	135.4	.0436	.1056	.2266	.5279
1.00	71.2	90.1	111.0	142.5	.0526	.1292	.2709	.5319

Table 4.8 Probability of Failure of Heater with Strap

Acceleration (g)	D_f			
	A	B	C	D
0.05	0	0	0	0
0.10	0	0	0	0.0005
0.15	0	0	0.0006	0.0013
0.20	0.0002	0	0.0013	0.0025
0.25	0.0007	0.0001	0.0022	0.0045
0.30	0.0012	0.0005	0.0038	0.0080
0.35	0.0017	0.0014	0.0049	0.0136
0.40	0.0025	0.0035	0.0089	0.0222
0.45	0.0340	0.0061	0.0136	0.0351
0.50	0.0047	0.0091	0.0197	0.0526
0.55	0.0060	0.0131	0.0281	0.0749
0.60	0.0080	0.0178	0.0401	0.1056
0.65	0.0104	0.0244	0.0548	0.1423
0.70	0.0136	0.0322	0.0722	0.1867
0.75	0.0170	0.0418	0.0951	0.2389
0.80	0.0217	0.0548	0.1210	0.2946
0.85	0.0274	0.0694	0.1539	0.3520
0.90	0.0344	0.0708	0.1894	0.4129
0.95	0.0436	0.1056	0.2266	0.5279
1.00	0.0526	0.1292	0.2709	0.5319

4.3 Risk of Fire in Electrical Distribution System

4.3.1 Estimated Risk in Routine (non-Earthquake) Condition

As described in chapter III, under normal conditions, non-earthquake conditions, electric fires are considered to be caused by NFPA(1986):

- Worn out or "retired" electrical equipment
- Improper use of approved equipment
- Accidental occurrences
- Defective installation

In a survey reported NFPA(1986), the number of electrical fires for 174 cities (surveyed in 1980) and 176 cities (surveyed in 1981 and 1982) was reported. Table 4.9 summarizes these statistics in terms of the average percentage of the total number of fires. As seen in the table, the electrical distribution system (which includes cables, cords, distribution panels, receptacles, lamps, fixtures, switches, termination and splices and wires) accounts for about 49.55% of all electrical fires. Wiring alone constitutes about 15.07% of all electrical (or 30% of the electrical distribution system) fires. An investigation into causes of electrical fires (Smith and McCoskrie, 1990) revealed that fires originated from electrical distribution systems in residential units account for about eight percent (8%) of all residential fires reported nationwide. In their investigation of 149 electrical fires, Smith and McCoskrie concluded that the percentage of electrical fires increased with the age of dwellings. Table 4.10 summarizes this finding. Although the

Table 4.9 Statistics of Electrical Fires (Data from NFPA 1986)

Equipment Involved	Average No. of Fires/yr.	% of Total
Air Conditioners	154	3.18
Appliance (Commercial/Industrial)	372	7.69
Appliance (Residential)	1428	29.54
Cables*	171	3.54
Cords*	290	6.00
Distribution Panels*	170	3.52
Fixtures-Lightings*	484	10.02
Lamps (Bulbs)*	75	1.54
Lighting Motors (not Integral with Appliance)	212	4.38
Receptacles*	135	2.78
Signs	63	1.29
Switches*	106	2.19
Termination and Splices*	97	2.08
Transformers*	136	2.81
Wires*	728	15.07
Pools	10	0.21
Miscellaneous equipment	13	0.27
Others	188	3.89
Total	4832	100.00

* Part of electrical distribution system

Total for electrical distribution system=49.55%

Table 4.10 Percentage of Electrical Distribution System Fires vs Age of Dwelling in 149 Fires (Smith and McCoskrie, 1990)

Age of Dwelling (Years)	% of Total Fires
≤10	6.4
11 to 20	8.5
21 to 40	29.1
Over 40	56.0
Total	100.0

results in Table 4.10 do not present a statistical sample, they, nevertheless, emphasize the importance of age on the risk of fires originating at electrical distribution systems in dwellings. More detailed investigation of the cause of these 149 fires, which occurred in 16 cities, revealed that the highest percentage of fires (34%) initiated at the branch circuit wiring. Table 4.11 presents the summary of these findings. It is observed that this percentage (34%) compares reasonably well with the 30% from the NFPA data (see Table 4.9). These results indicate the great potential of the electrical distribution system in promoting fire compared with other electrical components and equipment.

The risk of an electrical distribution fire in a residential dwelling can be estimated based on the statistics of past occurrence of such fires in a given area. These statistics are compiled by fire departments for their jurisdictions on a routine basis and they provide a valid sample for the estimation of the risk. However, the risk estimated would only represent the likelihood of fire from all causes (not necessarily earthquake related). The risk will however increase during an earthquake because of disturbances that occur in an electrical distribution system due to the building vibration. The effort in this section is focused on estimating the risk of electrical distribution fire and provide a basis for extrapolating this risk to arrive at estimates that would represent the effect of an earthquake of a given intensity.

Table 4.11 Failure Modes Involved in Residential Electrical Distribution System Fires Based on 149 Fires (Smith and McCoskrie, 1990)

Component	% of Total Fires
Service Equipment	14
Branch-Circuit Wiring	34
Receptacle Outlets & Switches	19
Cords and Plugs	19
Light Fixtures & Lamps	13
Transformers	<1

Table 4.12 San Francisco Fire Statistics (San Francisco Fire Department, 1991)

Years	84-85	85-86	86-87	87-88	88-89	89-90
Total Fires	7132	6709	6267	6212	5920	6210
Building Fires					2307	2297
1&2 Family Fires					514	484
Apartment Fires					1251	1287
Total Residential					1765	1771

Statistics of fires in San Francisco for six annual periods (1984-1990) are summarized in Table 4.12. Given in Table 4.12 are also the residential building fires and, more specifically, the fires in one- and two-story family dwellings and apartments. These statistics reveal that on the average, there are 6408 (Std. Dev.=436) fires in San Francisco each year. Based on the 1988-1990 data, residential fires constitute about 29% of total fires. With an estimated 8% of residential fires being attributed to electrical distribution systems, the total number of such fires is estimated at about $0.08 \times 0.29 \times 6408 = 149$ (Std. Dev.=10) fires. According to Census Bureau's data (1990) as of 1990 there were 328,471 residential units (single family dwellings and apartments) in San Francisco. Thus the estimated risk of an electrical distribution system for any residential unit is 4.536×10^{-4} ($\pm 3.044 \times 10^{-5}$). This risk is expected to be lower for units which are less than 10 years old. However, due to the lack of a valid statistical sample that can be used to describe the effect of age, the estimated risk will be used for all age groups.

4.3.2 Effect of Earthquake on the Risk of Fire

As described earlier, with a severe and persistent vibration of structural members, walls, floors and partitions, the risk of electric fires will increase. The risk estimated in the preceding section needs to be adjusted for various levels of seismic activities as prescribed by the ground

accelerations. This can be achieved using one of the following two methods:

- Compile statistics of electric-related fires for past earthquakes and estimate to what extent the number of fires resulting from an earthquake increases. This method provides a data based approach for augmenting the risk of earthquake-related fires. However, the method is impaired by the fact that the data may be limited and biased (applied to certain unusual demographic conditions). Ideally to be useful in risk estimation, the data should clearly be descriptive of all causes and locations of fires and their severity in terms of casualty and property damage.
- Simulate the response of electric equipment and wires in an earthquake-induced vibration environment and estimate the increase in the level of activities that will trigger the risk of fire. The simulation will require that the mechanism via which an electric fire develops be known. This is generally difficult because of the variety of factors that are involved in the development of a fire.

Since data to establish the information on the effect of earthquakes on the development of electric fire is scarce, our effort is focused on simulation studies. For this purpose, the causes of electric fires, as described earlier, are evaluated to determine and select those that correlate directly with the vibration produced in various structural members. A factor that contributes to electric fire is the friction and wear of

wires specially at joints and receptacles. The design of an electrical distribution system, the age of the system, and the load on the system can also drastically affect the risk of fire.

Our effort in this section is focused on the development of scenarios in which portions of an electric wiring system engage in vibration of a structure including its walls and other structural members. Figure 4.7 shows a masonry wall with a portion of an electric wiring system mounted on it.

It is emphasized that the system shown in Fig. 4.7 is only intended for the investigation of the effect of ground motion on deformation and vibration generated in the wire in a typical case where the wire is mounted on the wall. Many variations to this system exist that may change the outcome of the results of the simulation. Our primary purpose is to determine how severe the elongation in the wire becomes when the wall vibrates persistently over the duration of a given earthquake. The model will then be changed and the simulation will be repeated to investigate whether or not the design and layout of the wiring system and the wall configuration will have a major influence in the outcome of the analysis.

The maximum elongation generated in the wire will then be used as a basis to augment the risk of electrical distribution system fire so that the effect of various levels of ground shaking can be ascertained and quantified.

Records of six different earthquakes were obtained and used in the simulation analysis. Table 4.13 summarizes the




Figure 4.7. Failure Probabilities for Water Heaters with straps

Table 4.13 Acceleration and Duration of Various Earthquakes Used in Electric Distribution Simulations

Earthquake	Acceleration (g)	Duration (sec)	Max Wire Displacement(in)
Olympia 2	0.140	82.0	2.40E-03
Taft	0.180	54.0	9.70E-03
Olympia 1	0.280	89.1	7.40E-03
Elcentro	0.318	53.7	24.0E-03
Loma Prieta	0.330	40.0	18.0E-03
Cholame	0.430	44.0	24.0E-03




Figure 4.8. Wiring Configuration Used for Dynamic Analysis

maximum acceleration and duration for the six records.

The result of simulation showed a small deflection obtained in the wall at the location where electric wires are installed. (see Table 4.13) Furthermore, it was found that this deflection was neither affected by the wall configuration nor by the duration of the earthquake. Based on these results, it is found that the displacement will increase by 1.4 times as the acceleration will increment by 0.1g. This can be used as a basis for adjusting the risk of electrical fire as a result of earthquakes of various acceleration levels. Again, as discussed in section 4.2.1, at an acceleration below 0.05g, the risk is unaffected. However, at higher accelerations the risk obtained in Section 4.3.1 can be adjusted accordingly (see Table 4.14).

Table 4.14 Risk of Electric Fires for Various Accelerations

Acceleration (g)	Risk of Fire
0.05	0.454E-03
0.10	0.771E-03
0.15	1.311E-03
0.20	2.229E-03
0.25	3.789E-03
0.30	6.440E-03
0.35	10.950E-03
0.40	18.610E-03
0.45	31.640E-03
0.50	53.790E-03

Chapter V

ESTIMATION OF PROBABILITY OF POST-EARTHQUAKE FIRES

5.1 Introductory Remarks

In this chapter the estimates obtained for the risk of fire associated with electrical and gas distribution systems are used in the event trees of Chapter III to arrive at the estimated probability of post-earthquake fires. Specifically, the event trees are applied to San Francisco. For this purpose, the probabilities associated with various acceleration levels in San Francisco are obtained using the seismic risk analysis method developed by Mohammadi and Suen (1991). Furthermore, the events following a gas leak or a malfunction in an electrical distribution system are described and used in the estimation of the probability of fire.

5.2 Seismic Risk of San Francisco

As Described earlier, several methods are available that can be used for the estimation of probabilities that a given acceleration level will be exceeded in a given year. In this study, the model developed by Mohammadi and Suen (1991) is used. The model is essentially an extension of the seismic risk analysis method proposed by Derkiureghian and Ang (1977). In Mohammadi and Suen's model, the fault is modeled by a plane of rupture and the occurrence of future earthquakes is modeled using a generalized renewal process that accounts for a time-dependent seismic activity rate. The details of the model can be found in Mohammadi and Suen (1991). The formulation of the

model will lead to the computation for $P(Y>y)$ in which Y is a random variable describing the acceleration due to all potential earthquakes of various magnitudes that can occur in San Francisco and y is a specific desired acceleration level. The probability $P(Y>y)$ is evaluated for a given year from the following equation:

$$P(Y>y) = \int_{m_o \leq M \leq m_u} P(Y>y|E_m) f_M(m) dm \quad (5.1)$$

in which E_m is the occurrence of an earthquake with a random magnitude $M=m$, f_M is the probability density function of M , and m_o and m_u are limits of the integral. The statistics of previous seismic activities in the area and the geometry of the existing major faults in Northern California are essential data used in solving Eq. 5.1 for $P(Y>y)$. It is noted that the occurrence of future earthquakes and their magnitudes are treated as random. For magnitude, the probability density function f_M follows a truncated exponential and for the occurrence of future earthquakes, a time-dependent renewal Poissonian distribution is used.

Table 5.1 presents the estimation of $P(Y>y)$, here referred to as the probability of exceedence. For San Francisco, this is obtained by using the model by Mohammadi and Suen (1991). The statistics presented in Table 5.1 were used in computing the probability of Event A in fault trees of Figs. 3.1 and 3.2.

Table 5.1 Estimation of Annual Probability of Acceleration Exceedence for San Francisco

Acceleration (g)	Probability of Exceedence
0.05	0.8110
0.10	0.2800
0.15	0.0850
0.20	0.0370
0.25	0.0180
0.30	0.0092
0.35	0.0053
0.40	0.0030
0.45	0.0016
0.50	0.0008

5.3 Events Following Gas Leaks

As seen in Fig. 3.1, following a gas leak, depending on the level of gas accumulation (about 4 to 14% volume of gas to volume of air must accumulate for gas to be ignitable, NFPA, 1986) and whether or not there exists an ignition source, a fire may or may not occur. The attempt in this section is focused on estimating the probabilities associated with these events.

The probability that a leak will be detected depends on many factors such as:

- The area where leaks occur
- Ventilation
- Occupants being at home at the time of the earthquake
- If at home, how sensitive occupants are to detect gas leaks

If a gas is detected, there may be many scenarios that can follow. An occupant may attempt to close the primary gas valve or may immediately call the gas company, police department or fire department. The amount of gas accumulated then depends on the response time by these authorities to close the area gas valves or to arrive at the site for appropriate actions.

If the gas leak is not detected, and no automatic shut-off valve is installed, then depending on the areas where the leak occurs, flammable level of accumulation can be reached at about 21 minutes. This is based on 4% gas accumulation (the minimum needed for ignition) in volume of air in a 3.5 ft.

diameter around an appliance and a partial pipe failure. At about 73 minutes after the start of the leak the gas will accumulate 14% of the air. This is the maximum level of accumulation that is needed for ignition to occur. At concentration above 14%, the accumulated gas will not ignite unless a dilution (due to opening windows, door, etc.) happens.

In the risk analysis conducted in this chapter, it is assumed that the gas will be detected by the occupants if they are at home at the time of the earthquake. However, it is assumed that there is a 50% chance that any occupant is at home at the time of the earthquake. If a leak occurs and it remains undetected, it is assumed, as the worst case scenario, that a combustible level will be reached in about 50% of the time. It is also assumed that there is a 50% chance that an effective igniting source is present (pilot burning, electrical wire malfunction occurs, etc.). If gas is not detected and it is accumulated to the combustible level, with an ignition source present, the occurrence of one of the four types of fire shown in Fig. 3.1 is unavoidable.

If, on the other hand, the leak is detected and an effective ignition source is present, then the probability that one of the four types of fire occurs depends on whether the gas concentration in the air can reach the 4% - 14% interval before there is an attempt by the fire department, gas company, etc. to shut off the gas. This probability can be estimated based on the average time needed for the

authorities (say the fire department) to respond to the call received at the station and the time that is needed for the gas concentration to reach the 4% - 14% level. Figure 5.1 shows a graphical presentation of the time involved in gas accumulation and response by the authorities (e.g., the fire department). The early response time (t_e) represents average times in everyday operation (San Francisco Fire Department Data); whereas the late response time (t_l) is the representative of situations where there is a great demand on emergency response and rescue (e.g., during the Loma Prieta earthquake). Shown on the graphs are also times needed for the gas to reach the 4% ($t_{4\%}$) and 14% ($t_{14\%}$) levels. The estimated times $t_{4\%}$ and $t_{14\%}$ are based on partial failure of a gas pipe in which gas escapes at an opening as large as 50% of the perimeter of a 3/4 in. pipe. With $t_{4\%}=21$, $t_{14\%}=73$, $t_e=3.5$ and $t_l=28.5$ minutes, the overlapping times as shown in Fig. 5.1 are used as an estimation of the probability of fire development.

$$\text{Overlapping times} = \frac{t_l - t_{4\%}}{t_{14\%} - t_{4\%}} = \frac{28.5 - 21}{73 - 21} = 0.14$$

This estimate constitutes an average probability.

5.4 Events Following a Disturbance in the Electrical Distribution System

As seen in Fig. 3.2, a disturbance in the electrical distribution system can lead to one of four types of fires if the electricity is not cut off and the earthquake vibration persists over a sufficiently long period of time. Knowing




Figure 5.1. Graphical Presentation of Events Following a Leak Detection

some data on the severeness of an electrical problem in the system and the length of time that the problem should persist so that a fire can occur, one can utilize a simulation model to estimate the probabilities of the events following the Event B in the tree of Fig. 3.2. However, due to lack of such data, our estimates of risk of electrical fires was directly obtained from available fire statistics (see Section 4.3) and adjusted for the earthquake effect. These estimates will be used for the calculation of the probability of post-earthquake fires for San Francisco.

5.5 Probability of Post-Earthquake fires for San Francisco

The probability of a post-earthquake fire is estimated using Eqs. 3.1 and 3.2. The estimates are for any type of fire. A discussion on the occurrence rates for a specific type of fire (of the four types) is explained later.

The probabilities obtained constitute the likelihood of occurrence of gas and electrical fires only. They do not include such isolated fire causes as overturning lamps and candles or spill of flammable materials.

(i) Gas-Related Fires -- The various events appearing in the tree of Fig. 3.1 and their respective probabilities are summarized below:

<u>Event</u>	<u>Estimate of Probability</u>
A	Use Table 5.1
B	Combine statistics in Table 4.1 (for piping system) and those in Tables 4.5 and 4.8 (for appliance without or with straps)
D	0.50
E	0.50
F	0.50
C (event of fire)	1.0 if leak not detected 0.14 if leak detected

Note that event A and B are acceleration-dependent and that B is estimated for two different cases, namely, appliances without and with straps for the four types of heaters described in section 4.2. It is also noted that the events given above are only considered when their corresponding preceding events occur. Thus, the probabilities for B, D, ... are basically probabilities $B|A$, $D|B$,

Event A represents the probability that an earthquake of a given acceleration (i.e., $Y=y$) occurs in San Francisco. Note that values given in Table 5.1 are exceedence probabilities, i.e.

$$P(Y>y) = 1 - \int_0^y f_Y(y) dy \quad (5.2)$$

in which f_Y = probability density function of ground acceleration Y . The probability of event A can be approximated as follows:

$$P(A) = P(Y=y) \approx P(y < Y \leq y+\Delta y) \quad (5.3)$$

$$\begin{aligned} &\approx f_Y(y)\Delta y = P(Y \leq y+\Delta y) - P(Y < y) \\ &= P(Y > y) - P(Y > y+\Delta y) \end{aligned}$$

By selecting a small acceleration interval (say, $\Delta y=0.05g$), $P(A)$ can be obtained using the statistics of Table 5.1. For example $P(Y = 0.20g) = P(Y > 0.20g) - P(Y > 0.20g + 0.05g) = 0.037 - 0.018 = 0.019$.

It is also noted that the probability that exactly an acceleration y occurs is extremely rare. The estimates for $P(A)$ are in fact $P(Y=y)$ with Δy variation. Using estimates of $P(A)$ along with probabilities for other events in the event tree of Fig. 3.1, the annual risk of post-earthquake fires for various intensities is then calculated (see Appendix B for typical computations) as reported in Tables 5.2 - 5.5 for the four types of water heaters (designated as Types A, B, C and D).

Since in any given year, theoretically, any acceleration level can occur, the probabilities for various accelerations can be combined to arrive at a gross estimate of the risk of fire. The following equation is used for this purpose:

$$P(C) = \sum P(C|A)P(A) = \sum_{y} P(C|Y=y)P(Y=y) \quad (5.4)$$

It is noted that $P(Y=y) \approx 0$ for $y > 0.50$ thus not contributing to Eq. 5.4. The gross estimates based on Eq. 5.4 are also given in Tables 5.2 - 5.5.

(ii) Electric Fires

The probability of electric fires resulting from a given acceleration level was obtained in Chapter IV. These

Table 5.2 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type A Gas Appliances and/or Gas Pipe)

Acceleration (g)	No Straps Used		Straps Used	
	P(C A)	P(C A)P(A)	P(C A)	P(C A)P(A)
0.05	0.00021	0.00011	0.00021	0.000110
0.10	0.00021	0.00004	0.00021	3.90E-05
0.15	0.00242	0.00012	0.00021	1.01E-05
0.20	0.05653	0.00107	0.00024	4.60E-06
0.25	0.11616	0.00102	0.00032	2.80E-06
0.30	0.14512	0.00056	0.00041	1.60E-06
0.35	0.15552	0.00036	0.00048	1.10E-06
0.40	0.15872	0.00022	0.00061	0.80E-06
0.45	0.16000	0.00013	0.00076	0.60E-06
0.50	0.16000	<u>0.00009</u>	0.00096	<u>0.60E-06</u>
Gross Estimate		0.00372		0.000170

*P(C|A) = Probability of fire given an acceleration level

**P(C|A)P(A) = Probability of fire considering a specific acceleration level

Table 5.3 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type B Gas Appliances and/or Gas Pipe)

Acceleration (g)	No Straps Used		Straps Used	
	P(C A)	P(C A)P(A)**	P(C A)	P(C A)P(A)
0.05	0.00021	0.0001100	0.00021	1.11E-04
0.10	0.00021	3.900E-05	0.00021	3.90E-05
0.15	0.00021	1.010E-05	0.00021	1.01E-05
0.20	0.00053	1.010E-05	0.00021	4.00E-06
0.25	0.00645	0.570E-04	0.00023	2.00E-06
0.30	0.03365	1.312E-04	0.00029	1.10E-06
0.35	0.06672	1.534E-04	0.00043	1.00E-06
0.40	0.12080	1.691E-04	0.00078	2.20E-06
0.45	0.14416	1.153E-04	0.00117	0.90E-06
0.50	0.15936	<u>0.956E-04</u>	0.00167	<u>1.00E-06</u>
Gross Estimate		0.00089		0.00017

*P(C|A) = Probability of fire given an acceleration level

**P(C|A)P(A) = Probability of fire considering a specific acceleration level

Table 5.4 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type C Gas Appliances and/or Gas Pipe)

Acceleration (g)	No Straps Used		Straps Used	
	P(C A)	P(C A)P(A)**	P(C A)	P(C A)P(A)
0.05	0.00021	0.000110	0.00021	0.000110
0.10	0.01317	0.002370	0.00021	3.90E-05
0.15	0.11023	0.005290	0.00022	1.10E-05
0.20	0.15183	0.002880	0.00042	0.80E-05
0.25	0.15888	0.001400	0.00056	4.90E-06
0.30	0.15984	0.000620	0.00082	3.20E-06
0.35	0.16000	3.70E-04	0.00094	2.20E-06
0.40	0.16000	2.20E-04	0.00163	2.30E-06
0.45	0.16000	1.28E-04	0.00023	1.90E-06
0.50	0.16000	0.94E-04	0.00336	2.00E-06
Gross Estimate		0.01348		0.000180

*P(C|A) = Probability of fire given an acceleration level

**P(C|A)P(A) = Probability of fire considering a specific acceleration level

Table 5.5 Estimated Probability of Post-Earthquake Fires for San Francisco (Based on Failure of Type D Gas Appliances and/or Gas Pipe)

Acceleration (g)	No Straps Used		Straps Used	
	P(C A)	P(C A)P(A)**	P(C A)	P(C A)P(A)
0.05	0.00037	0.00020	0.00020	0.000110
0.10	0.12480	0.02246	0.00029	5.20E-05
0.15	0.15904	0.00763	0.00042	2.00E-05
0.20	0.16000	0.00303	0.00061	1.16E-05
0.25	0.16000	0.00141	0.00093	0.82E-05
0.30	0.16000	0.00062	0.00149	0.58E-05
0.35	0.16000	0.00034	0.00239	5.50E-06
0.40	0.16000	0.00022	0.00376	5.20E-06
0.45	0.16000	0.00013	0.00583	4.70E-06
0.50	0.16000	<u>0.00009</u>	0.00863	<u>5.20E-06</u>
Gross Estimate		0.03615		0.000230

*P(C|A) = Probability of fire given an acceleration level

**P(C|A)P(A) = Probability of fire considering a specific acceleration level

statistics are adjusted by the probability of occurrence of various levels of ground acceleration (see Table 5.1 and Eq. 5.3, Appendix B provides sample computation). The results are summarized in Table 5.6. Again a gross estimate is obtained and given in Table 5.6 based on Eq. 5.4.

5.6 Types of Fires

Occurrence of a specific type of fire (of the four types) depends on:

- Location in the house where the fire starts
- Availability and type of combustible materials in the room where fire spreads
- Response time by the fire department

Most earthquake-related fires initiated as isolated cases are either Type 1 or 2. Only a few fires can lead to Type 3 or 4 fires (see Chapter II for description of the types). These cases are severe if they spread to other houses. An attempt to develop specific probability values for various types of fire requires information on past post-earthquake fires and distribution of the number of fires in each type. Based on the data reported in Chapter II, the distribution among various types of fire is as follows:

Type 1:	7.3 %		
Type 2:	61.0 %	Type 1 + 2:	68.3 %
Type 3:	12.2 %	Type 3 + 4:	31.7 %
Type 4:	19.5 %		

This distribution, however, concerns a specific case and does

Table 5.6 Estimated Probability of Earthquake-Related Fires
in San Francisco (Fires Caused by Electrical Problems)

Acceleration (g)	$P(C A)$ *	$P(C A)P(A)$ **
0.05	0.454E-03	0.241E-03
0.10	0.771E-03	1.388E-05
0.15	1.311E-03	6.293E-05
0.20	2.229E-03	4.235E-05
0.25	3.789E-03	3.334E-05
0.30	5.440E-03	2.512E-05
0.35	10.950E-03	2.519E-05
0.40	18.610E-03	2.605E-05
0.45	31.640E-03	2.531E-05
0.50	53.790E-03	<u>3.227E-05</u>
Gross Estimate		0.0005300

* $P(C|A)$ = Probability of fire given an acceleration level

** $P(C|A)P(A)$ = Probability of fire considering a specific
acceleration level

not offer a statistically valid sample. Additional analysis of previous post-earthquake fire data (both in US and Japan) along with simulation studies will be needed to determine a valid distribution among the four types.

5.7 Fire Risk Contours for a Repeat of the Loma Prieta Earthquake

The probabilities of fire computed in Section 5.5 are used to obtain seismic-fire risk contours for San Francisco for a repeat of the Loma Prieta earthquake. The estimates are based on the acceleration levels recorded for the 1989 Loma Prieta earthquake (see Fig. 2.1) and probabilities reported in Tables 5.2 and 5.6. A Type A water heater is used as a basis for the probability of gas-related fire due to the popularity of Type A. Risk contours are given for (i) gas-related fires when straps for water heaters are not used, (ii) gas-related fires when straps for water heaters are used and (iii) electrical fires. The contours are provided only as a means to identify risk-prone areas and to compare the effectiveness of using straps to secure water heaters. The contours are shown graphically in Figs. 5.2 - 5.4. The risk values appearing on contour lines describe the annual probability of post-earthquake fire for any given residential unit for a repeat of the Loma Prita earthquake.

The maximum acceleration reported for the Loma Prieta earthquake was about 0.35g. The risk of fire for this acceleration (using the probability that acceleration = 0.35g)




Figure 5.2. Risk Map for a Repeat of Loma Prieta for Unstrapped Water heater.

* The risk values appearing on the contour lines describe the annual probability of post-earthquake fire.




Figure 5.3. Risk Map for a Repeat of Loma Prieta for strapped Water heater.

* The risk values appearing on the contour lines describe the annual probability of post-earthquake fire.




Figure 5.4. Risk Map for a Repeat of Loma Prieta for Electrical Distribution Systems.

* The risk values appearing on the contour lines describe the annual probability of post-earthquake fire.

per residential unit/year is:

- 0.00036 Gas related fires using Type A heater without straps
- 1.1E-06 Gas related fires using type A with straps
- 2.52E-05 Electric-related fires

Considering the fact that there are 328,471 residential units in San Francisco (see Sec. 4.3), the above risk levels translate into the following number of fires/year if acceleration is expected to be about 0.35g.

- about 118 fires if none of the residential units have secured heaters
- about 1 fire if all residential units have secured heaters; and
- about 8 fires due to potential electrical problems

These estimates are obtained by multiplying the risk for one unit by the total number of residential units. They emphasize the importance of having gas appliances secured to walls using straps. In the Loma Prieta earthquake, there were a total of 2 fires due to water heaters, 6 due to electrical wiring and 11 due to other appliances. It was not known what percentage of appliances during the earthquake in San Francisco had straps and were secured from movement.

It is emphasized that only a few areas experienced such high ground acceleration level (i.e., 0.35g). Thus the 118 fires estimated is an over-estimation. Considering the

percentage of the population in District 4 (see Fig. 2.4) that experienced a high acceleration level, to the total population of San Francisco (approx. 10%), the estimate is 12 fires. This estimate is perhaps a better representative of the risk associated with potential areas that are more vulnerable to a high intensity ground motion.

CHAPTER VI

SUMMARY AND CONCLUSIONS

6.1 Summary and Conclusions

This study of post earthquake fire hazard reiterates the risks associated with residential fires following earthquakes and further emphasizes the need to plan for risk mitigation. The goal of constructing a risk model that dealt with residential units in particular introduced a new set of challenges which were very unique to this problem.

A thorough literature review was performed focussing specifically on :

- Fire investigation after the Loma Prieta earthquake of 1989.
- Fires following other past earthquakes.
- Causes of post-earthquake fires.
- Available models on fire hazard estimation and evaluation.

Such review provided the necessary data base for encompassing aspects such as types of fire, intensity of ground motion, soil type at the site of fires, and type and location of the effected structures. Moreover, examining previous models provided the frame work needed for the development of a model for simulating initiation of fires in residential units in urban areas following an earthquake event.

The methodology proposed provided more insight into the risk of post earthquake fire hazard as it concerned residential units. The methodology applied existing

principles of probability as related to structural safety and seismic risk analysis.

A major effort in this research focused on the analysis of cause and effects of fires following the Loma Prieta earthquake of 1989. A summary of the findings is provided below:

The data on the number of fires by areas, cause and severeness of them was obtained from fire departments, reports on the events following the Loma Prieta earthquake and several communications with the San Francisco Fire Department.

The total number of fires was 67 of which 41 occurred in San Francisco. Although this seems to be many, yet it is a small number considering the intensity of the earthquake and affected areas which are densely populated. Twenty-seven fires occurred within seven hours after the earthquake. Beyond San Francisco, Santa Cruz County had 20 fires, Santa Clara and Berkeley each had 1 fire and Watsonville had 3 fires.

An investigation into the fires after the Loma Prieta earthquake indicated a variety of causes. Of 41 fires in San Francisco, 14 were due to electric wiring or electric equipment, 11 were caused by stoves (gas/electric), 2 due to water heaters and 2 other gas appliances. Several isolated causes such as overturning candles were also mentioned. The Marina City fires were initiated as a result of a fire in a four-story wood-frame building. The exact cause of this fire is unknown but it is believed to have originated at the rear

of the building. This fire triggered 6 additional fires by the time the situation was under control. Santa Cruz had 20 fires of which only one residential building was destroyed by the fire. The cause of this was reported to be a gas main leak. Watsonville had 3 residential units destroyed by fires following the earthquake. The investigation of the fires following the Loma Prieta earthquake further emphasized the importance of such factors as intensity of the ground motion acceleration, the type of soil and its ground motion amplification characteristics, and the population density in the potential number of fires. In San Francisco, very densely populated areas (Marina City) are on mud and fill-type soil. The accelerations at some of these areas was reported to exceed 0.3g which caused more severe conditions in terms of building vibration and damage in the form of structural collapse and also fire.

Post-earthquake fires can occur as a result of a variety of causes. These include natural gas related incidents such as gas main ruptures, failures in the interior gas piping, and failure of gas appliances (i.e., water heaters). Post-earthquake fires of electric origin can be the result of failures in electric wiring, equipment and appliances. Overturning of lamps and burning candles and flammable material spills are also responsible for a portion of such fires, however; due to the unsystematic nature of this group of causes fires resulting from these were not modeled in this study.

Event trees were used in modeling the steps leading to gas and electrical fires following an earthquake. The trees proved to be very practical in demonstrating the sequence of events that follow after an earthquake and that can lead to a fire. The probability associated with individual events in the trees were quantified either using mathematical modeling or post performance data. When neither method could be used, subjective estimates were used on an over-estimated basis. However, these can easily be modified once more specific data for the occurrence of a given event is known. It is recommended that the trees be continuously reviewed and revised to incorporate any new data that could prove more specific information on the occurrence of those events for which subjective values were assigned. These events include gas leak detection, existence of an effective ignition source, and gas accumulation to a flammable level.

In case of gas leak detection, factors such as whether or not an occupant was present in the house at the time of the earthquake, location of the leak, and possible leak detection by smell are critical yet difficult to quantify.

Calculation of the probability of existence of an effective ignition source at the site of gas accumulation was also a perplexing task. The possibilities ranged from turning on the lights, or an electrical short to the introduction of a burning candle to the scene as a result of electrical power loss.

To quantify the time necessary for the gas to accumulate

to a flammable level scenarios involving different size leaks in the gas piping system were considered. Using flow equations these times were calculated and compared to fire department's early and late response times thus arriving at the probability of reaching flammable levels of gas accumulation.

Generation of such an event tree yet introduced a new set of problems, namely the quantification of risk when mathematical modeling was not possible and no specific performance or subjective data was justified to be used. In such a case risk quantification was based on extrapolating the probabilities known to represent ordinary conditions. The result of the augmentation process in itself is dependent on the extent and variety of simulations and experiments performed to explicate the correlation between normal condition values and earthquake subjected results. For instance in case of electrical post-earthquake fires, listed failure probabilities for different components of a residential electrical system in normal conditions were augmented using the results of numerous computer simulations of a model depicting the electrical wiring of a residential unit under earthquake excitations.

Further investigation (including complete simulations where applicable) of such topics as dynamics of gas accumulation process in residential units, gas leak detection, in depth studies of possible sources of ignition in gas leak scenarios, and behavior of electrical distribution systems in

an earthquake would be of enormous help to future attempts to refine risk models such as the one presented in this study.

An approach based on simulation via computer animation was tried in this study and showed some promises. However, the animation needs to be done on a case-by-case basis and requires an extensive computer modeling and analysis effort.

Employing our models for gas and electrical fire initiation in conjunction with the probabilities associated with various earthquake ground acceleration levels, probabilities of post-earthquake fires for a single family residential unit were computed considering gas and electrical fires. These probabilities were then calibrated for ground accelerations reported after the Loma Prieta earthquake. The result was estimated risk of fire in San Francisco for a repeat of the Loma Prieta event. Such information can provide basis for seismic preparedness planning and fire fighting effort during an earthquake emergency. Planners could use the information to provide alternative routes, shelters, and evacuation plans in case of conflagrations. Area hospitals could become prepared for a higher number of burn victims. Furthermore, the utility companies could introduce special seismic shut-off valves in the more vulnerable areas and dramatically reduce the risks.

The risk estimates for San Francisco were obtained for potential electric fires and gas-related fires for two possible scenarios, namely, water heaters unrestrained and restrained. The results indicated that using straps to secure

heaters to walls can substantially mitigate the risk of fire. The result of analyses conducted in this study showed that any gas leak development (in the case of the survival of the building) is mainly because of water heaters being dislodged or overturned. Using straps to secure heaters is thus a very important mitigation effort that can be applied with almost no cost to the building owner.

6.2 Recommendations for Further Studies

As a result of our investigation into the fires following the Loma Prieta Earthquake, we recommend several additional studies that can be useful in risk analysis and risk mitigation for future earthquakes.

- Post-earthquake fire risk data (in the form of risk maps) need to be developed to describe potentials for fire in residential buildings. A limited study to estimate the risk for San Francisco is completed and included in this report. However, this needs to be further evaluated and refined.
- Alternative sources for fire fighting activities need to be studied and optimized for various localities. Alternative routes and water sources for a timely response to a fire in the area are to be fully investigated and identified. This is especially critical for densely populated areas and areas which are prone to amplified ground motion due to their soil types.

- Possible measures to reduce risk of fire in residential buildings need to be quantified in terms of their effectiveness in reducing the probability of fire. Using straps to secure water heaters, installing automatic gas shut-off valves and automatic electrical distribution system circuit breakers are some examples of such fire-risk mitigation measures. The effectiveness of straps in mitigating fire risk was investigated in this study. Other measures need to be evaluated also.
- The reliability of sprinkler systems in an earthquake and their effectiveness to reduce the risk of intense fires needs to be estimated and quantified. Since such information cannot easily be established from past performances, analytical methods needs to be developed and tested for this purpose.
- With the advents in computer animation technology many possibilities for post-earthquake fire simulation and investigation have become available. Computer animation techniques could be employed for both investigative and educational ventures into the problem of post-earthquake fire hazard.

BIBLIOGRAPHY

- American Institute of Steel Construction (1989). Manual of Steel Construction, Allowable Stress Design. 9th ed. AISC, Chicago.
- Ang, A. H.-S., and C. A. Cornell (1974). "Reliability Basis of Structural Safety and Design". Journal of Structural Division, ASCE, ST9, Vol. 100, Sept., Pages 1755-1769.
- Ang, A. H.-S., and W.H. Tang (1975). Probability Concepts in Engineering Planning and Design. Vol. I. John Wiley and Sons, New York.
- Ang, A. H.-S., and W.H. Tang (1984). Probability Concepts in Engineering Planning and Design. Vol. II. John Wiley and Sons, New York.
- Avallone, E.A., and T. Baumeister III (1978). Marks' Standard Handbook for Mechanical Engineers. 9th ed. McGraw-Hill, Inc., New York.
- Cornell, C. A. (1968) "Engineering Seismic Risk Analysis," Bulletin of Seismological Society of America, Vol. 58, No. 5, pages 1583-1606.
- Der-kiureghian, A., and A. H.-S. Ang (1977). "A Fault-Rupture Model for Seismic Risk Analysis." Bulletin of Seismological Society of America. Vol. 67, No. 4, August.
- Donovan, N.C. (1973). A Statistical Evaluation of Strong Motion Data Including the February 9, 1971 San Fernando Earthquake. Proc. of Fifth World Conference on Earthquake Engineering. EERI, Rome, Italy.
- Federal Emergency Management Agency, United States Fire Administration (1991). The Loma Prieta (San Francisco /Monterey Bay) Earthquake. Report Prepared by the National Fire Protection Association, Fire Investigations Department, Grant EMW-90-G-3440, September.
- Itoigawa, E., and I. Tsukagoshi (1988). Stochastic Model for Fire Spread in Urban Areas Based on Fire Brands Effect. Proc. of 2nd Japan-U.S. Workshop on Urban Earthquake Hazard Reduction. Institute of Social Safety, Japan, and Earthquake Eng. Research Institute, USA. 223-233.
- Longinow, A., J. Mohammadi, and T. A. Williams (1989). "Analysis of Risk Associated with Interior Gas Distribution Systems." Topical Report. Gas Research Institute, Chicago.

- Longinow, A. et al (1990). "Load and Environmental Effects on Interior Gas Piping Systems." Final Technical Report #GRI-90/0132: 4.1-1.4. Prepared for Gas Research Institute, by Wiss, Janney, Elstner Associates, Northbrook, Illinois.
- Mizuno, H. (1987). "On Outbreak of Fires in Earthquakes." Dissertation, Dept. of Architecture. Kyoto University, Kyoto.
- Mohammadi, J. (1990). "Earthquakes and Earthquake-Resistant Design. Cost Engineering 32: 12-17.
- Mohammadi, J., A. Longinow, and T. A. Williams (1991). "System Reliability Using Expert Opinions." Structural Safety.
- Mohammadi, J., and S.-J. Suen (1991). "Effect of Source Parameters in Seismic Hazard Analysis." European Earthquake Engineering.
- National Fire Protection Agency (1986). Fire Protection Handbook. 16th ed. NFPA.
- Newmark, N. M., and E. Rosenblueth (1971). Fundamentals of Earthquake Engineering. Prentice-Hall, Inc. Englewood Cliffs, N.J.
- Popov, E. P. (1968). Introduction to Mechanics of Solids. Prentice Hall, Englewood Cliffs, NJ, Page 319.
- San Francisco Fire Department (1990-1992). Various Personal, Correspondence, and Communications.
- Scawthorn, C. G., and Y. Yamada (1981). Lifeline Effects on Post-Earthquake Fire Risk. Lifeline Earthquake Engineering: The Current State of Knowledge. Proc. of the 2nd Specialty Conference of the Technical Council on Lifeline Earthquake Engineering. Ed. D.J. Smith, Jr. American Society of Civil Engineers, New York.
- Scawthorn, C. G. (1985). "Post-Earthquake Fire", Proceedings-U.S.- Japan Workshop on Urban Earthquake Hazard Reduction. Publication No. 85-03, EERI, Berkeley, CA, Pages 237-243.
- Scawthorn, C.G. (1986). Simulation Modeling of Fire Following Earthquake. Proc. of 3rd U.S. National Conf. on Earthquake Engineering. Vol. III.

- Scawthorn, C.G. (1987). Fires Following Earthquakes. Proc. of 1st International Symp. on Fire Safety Science. Hemisphere, New York.
- Scawthorn, C.G. (1988). Fire and Hazardous Materials Following Earthquake: U.S. Perspectives. Proc. of 2nd Japan-United States Workshop on Urban Earthquake Hazard Reduction. Inst. of Social Safety, Japan, and Earthquake Eng. Res. Inst., USA. 234-243.
- Schiff, A.J. (1985). "Life Lines", Proceedings-U.S.- Japan Workshop on Urban Earthquake Hazard Reduction. Publication No. 85-03, EERI, Berkeley, CA, Pages 243-249.
- Schiff, A.J. (1988). "The Whittier-Narrows, California Earthquake of October 1, 1987." Earthquake Spectra 4.
- Shakal A., et al. (1989). "CSMIP Strong-Motion Records from the Santa Cruz Mountains(Loma Prieta), California Earthquake of 17 October 1989," Report No. OSMS 89-06, California Strong Motion Instrumentation Program, California Department of Conservation, Sacramento, CA.
- Smith, L.E., and D. McCoskrie (1990). "What Causes Wiring Fires in Residences." Fire Journal. Jan./Feb. 19-24.
- Steinbrugge, K. V., R. Bush, and E. Zacher (1973). "San Fernando Earthquake February 9, 1971." Pacific Fire Rating Bureau, San Francisco.
- Stussman, H. B., and J. J. Kosowatz (1989). "Utility Lines Stood Up Quite Well." Engineering News Record. 26 Oct.
- URS Corporation (1988). "Risk of Earthquake-Induced Gas Fires in Residential Housing." Report Prepared for Southern California Gas Company. URS Corporation, San Francisco.

APPENDIX A
THE MODIFIED MERCALLI INTENSITY SCALE

THE MODIFIED MERCALLI INTENSITY SCALE
(Excerpted from Suen 1988)

Mercalli's improved intensity scale served as a basis for the scale advanced by Wood and Neumann, known as the modified Mercalli scale and commonly abbreviated MM. The modified version is described below with some improvements (Newmark and Rosenblueth, 1971).

To eliminate many verbal repetitions in the original scale, the following convention has been adopted. Each effect is named at the level of intensity at which it first appears frequently and characteristically. Each effect may be found less strongly, or in fewer instances, at the next lower grade of intensity; more strongly or more often at the next higher grade. A few effects are named at two successive levels to indicate a more gradual increase.

Masonry A, B, C, D. To avoid ambiguity of language, the quality of masonry, brick or otherwise, is specified by the following lettering (which has no connection with the conventional Class A, B, C construction).

Masonry A. Good workmanship, mortar, and design; reinforced, especially laterally, and bound together by using steel, concrete, etc.; designed to resist lateral forces.

Masonry B. Good workmanship and mortar; reinforced, but not designed in detail to resist lateral forces.

Masonry C. Ordinary workmanship and mortar; no extreme weaknesses like failing to tie in at corners, but neither reinforced nor designed against horizontal forces.

Masonry D. Weak materials, such as adobe; poor mortar;

low standards of workmanship; weak horizontally.

Modified Mercalli Intensity Scale of 1931 (Abridged and Rewritten by C. F. Richter.)

1. Not felt. Marginal and long-period of large earthquakes.
2. Felt by persons at rest, on upper floors, or favorably placed.
3. Felt indoors. Hanging objects swing. Vibration like passing of light trucks. Duration estimated. May not be recognized as an earthquake.
4. Hanging objects swing. Vibration like passing of heavy trucks; or sensation of a jolt like a heavy ball striking the walls. Standing motor cars rock. Windows, dishes, doors rattle. Glasses clink. Crockery clashes. In the upper range of 4, wooden walls and frames crack.
5. Felt outdoors; direction estimated. Sleepers wakened. Liquids disturbed, some spilled. Small unstable objects displaced or upset. Doors swing, close, open. Shutters, pictures move. Pendulum clocks stop, start, change rate.
6. Felt by all. Many frightened and run outdoors. Persons walk unsteadily. Windows, dishes, glassware broken. Knickknacks, books, and so on, off shelves. Pictures off walls. Furniture moved or overturned. Weak plaster and masonry cracked. Small bells ring (church, school). Trees, bushes shaken visibly, or heard to rustle.
7. Difficult to stand. Noticed by drivers of motor cars. Hanging objects quiver. Furniture broken. Damage to masonry including cracks. Weak chimneys broken at roof

line. Fall of plaster, loose bricks, stones, tiles, cornices, unbraced parapets, and architectural ornaments. Some cracks in masonry C. Waves on ponds; water turbid with mud. Small slides and caving in along sand or gravel banks. Large bells ring. Concrete irrigation ditches damaged

8. Steering of motor cars affected. Damage to masonry C; partial collapse. Some damage to masonry B; none to masonry A. Fall of stucco and some masonry walls. Twisting, fall of chimneys, factory stacks, monuments, towers, elevated tanks. Frame houses moved on foundations if not bolted down; loose panel walls thrown out. Decayed piling broken off. Branches broken from trees. Changes in flow or temperature of springs and wells. Cracks in wet ground and on steep slopes.
9. General panic. Masonry D destroyed; masonry C heavily damaged, sometimes with complete collapse; masonry B seriously damaged. General damage to foundations. Frame structures, if not bolted, shifted off foundations. Frames racked. Conspicuous cracks in ground. In alleviated areas sand and mud ejected, earthquake fountains, sand craters.
10. Most masonry and frame structures destroyed with their foundations. Some well-build wooden structures and bridges destroyed. Serious damage to dams, dikes, embankments. Large landslides. Water thrown on banks of canals, rivers, lakes, etc. Sand and mud shifted

horizontally on beaches and flat land. Rails bent slightly.

11. Rails bent greatly. Underground pipelines completely out of service.
12. Damage nearly total. Large rock masses displaced. Lines of sight and level distorted. Objects thrown into the air.

APPENDIX B
SAMPLE COMPUTATIONS FOR PROBABILITY OF FIRE

SAMPLE COMPUTATIONS FOR PROBABILITY OF FIRE

B.1 Gas Related Fires

The following computation is done for an acceleration level equal to 0.20g and Type A heater as an example. Equations 3.1 are used for calculating P(C).

$$P(C|E) = 1.0 \quad \text{if leak is not detected}$$

$$P(C|E) = 0.14 \quad \text{if leak is detected}$$

$$P(E|D) = 0.5$$

$$P(D|B) = 0.5$$

$$P(E|F) = 0.50$$

$$P(F|\bar{D}) = 0.50$$

$$P(\bar{D}|B) = 0.50$$

$$P(B|A) = 0.352 \quad \text{(For 0.2g acceleration, Type A heater without straps, see Table 4.5).}$$

$$P(B|A) = 0.00132 \quad \text{(For the gas piping system for a typical Single Family dwelling, see Section 4.1).}$$

Thus, the heater failure dominates. Probability of fire from Eqs. 3.1 given 0.20g acceleration is:

$$P(C|A) = [0.14 \times 0.5 \times 0.50 + 1.0 \times 0.50 \times 0.5 \times 0.5] \times 0.352 = 0.0563$$

Considering the probability for the event A, i.e.

$$P(A) = 0.037 - 0.018 = 0.019 \quad \text{(From Table 5.1), then:}$$

$$P(C|A)P(A) = 0.0563 \times 0.019 = 0.00107$$

These are given in Table 5.2 for 0.20g, and the case where no straps are used. Similar calculations are done for other accelerations, heater types with or without straps.

B.2 Electric Fires

The following computation is done for an acceleration level equal to 0.20g. The risk value computed in Chapter IV and reported in Table 4.14 for 0.20g is 2.229E-03.

Thus, $P(C|A) = 2.229E-03$

Considering the probability of having the acceleration 0.20g, i.e.

$P(A) = 0.019$, then:

$$P(C|A)P(A) = 2.229E-03 \times 0.019 = 4.235E-05$$

These estimates are reported in Table 5.6.

Similar calculations can be done for other acceleration levels. Note that the above simple procedure was used instead of Eqs. 3.2 because of the fact that the estimates for the risk of electric fires given an acceleration level was calculated without any specific reference to the intermediate events depicted in Fig. 3.2. This was done due to the fact that no information was available to quantify the intermediate events in the tree of Fig. 3.2.

APPENDIX C
FIRE INCIDENT REPORTS FOR THE CITY OF SAN FRANCISCO
(OCT. 17-20)
SAN FRANCISCO FIRE DEPARTMENT

Every completed report must be submitted to the Chief of the Fire Department, Office of the State Fire Marshal, 1500 Market Street, San Francisco, California 94102. This report is to be used only for the purpose of recording and reporting fire incidents. It is not to be used for any other purpose.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL Date 10/17/89 Time 21:30

() Box / No. 8422 (X) Unit Disp. / Co. No. E-33

8079

1 OCCUPANT NAME K. DINTCHO	2 RELATIONSHIP	3 FLAME SOURCE	4 TEL. NO.	5 OFF. NO.	6 DASH NO.
7 ADDRESS 150 Font Blvd.	8 UNIT / FLOOR 1F	9 CITY San Francisco	10 ZIP 94132	11 TELEPHONE NO. 194132	12 TELEPHONE NO.
13 STREET NAME Same	14 STREET NAME Same	15 CITY	16 ZIP	17 TELEPHONE NO.	18 TELEPHONE NO.
19 MANAGED UNIT Parkview APTS.	20 ADDRESS	21 CITY	22 ZIP	23 TELEPHONE NO.	24 TELEPHONE NO.

A. INFORMATION (PAGE 7)

1 FIRE DIST. NO.	2 REPORT NO.	3 INCIDENT NO.	4 TIME	5 MONTH	6 DAY	7 YEAR	8 COUNTY	9 ZIP	10 CITY	11 OUT OF JURISDICTION
38005	0086	21301017	21:30	10	17	89	San Francisco	94132	San Francisco	<input type="checkbox"/>

B. PROPERTY CLASSIFICATION (PAGE 15)

1 CODE TYPE OF INCIDENT 1.1 Building Fire	2 DAMAGE DONE NO. OF VEH. D. NO. OF VEH. I.
3 CODE PROPERTY CLASSIFICATION (ASSEMBLY) 4.2 Apartment Complex	
4 CODE PROPERTY CLASSIFICATION (INDUSTRIAL) 2.4 Apartments	

C. PROPERTY TYPE (PAGE 61)

1 CODE PROPERTY CLASSIFICATION 2.1 Building Type 1	2 DAMAGE DONE NO. OF VEH. D. NO. OF VEH. I.
3 STRUCTURE DIVISION OF VEHICLE - CONSTRUCTION TYPE 1.3	

D. EXTENT OF DAMAGE (PAGE 45)

1 CODE EXTENT OF DAMAGE - FIRE 2.1 Confined to area of origin.	
2 CODE EXTENT OF DAMAGE - SINGLE 2.1	
3 CODE EXTENT OF DAMAGE - WATER 2.1	
4 ESTIMATED LOSS - PROPERTY 21000	5 ESTIMATED LOSS - CONTENTS 11000

E. LOCATION & CAUSE (PAGE 49)

1 CODE LEVEL OF DAMAGE 1.02 Second Floor
2 CODE SOURCE OF HEAT (CAUSE) 4.6 Lamp
3 CODE POINT OF HEAT (CAUSE) 5.4 Electric Lamp
4 CODE ACT OF DAMAGED CAUSE (LOCATION) 8.2 Earthquake

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

1 CODE AREA OF ORIGIN 1.4 Living Room
2 CODE TYPE OF MATERIAL FIRST NOTICED 6.9 Paper
3 CODE POINT OF MATERIAL FIRST NOTICED 2.1 Chair
4 CODE AREA DAMAGED (SMOKE SPREAD) 0.1 Ceiling

G. SPREAD OF FIRE (PAGE 71)

1 CODE AREA DAMAGED (FIRE SPREAD) 0.1 Ceiling
2 CODE TYPE OF MATERIAL, CAUSING SPREAD 6.8 Cardboard
3 CODE POINT OF MATERIAL, CAUSING SPREAD 2.0 Furniture
4 CODE ACT OF DAMAGED CAUSING SPREAD 8.2 Earthquake

H. PROTECTION FACILITIES (PAGE 91)

1 CODE SPRINKLER - TYPE	2 CODE SPRINKLER - EFFECTIVENESS
3 CODE STANDPIPE - TYPE	4 CODE STANDPIPE - EFFECTIVENESS
5 CODE PORTABLE EXTINGUISHERS - TYPE	6 CODE PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 97)

1 CODE PROTECTIVE DEVICES - TYPE	2 CODE PROTECTIVE DEVICES - EFFECTIVENESS
3 CODE SPECIAL RISER PROTECTION - TYPE	4 CODE SPECIAL RISER PROTECTION - EFFECTIVENESS
5 CODE SIGNAL OR WARNING SYSTEM - TYPE	6 CODE SIGNAL OR WARNING SYSTEM - EFFECTIVENESS
7 CODE SIGNAL OR WARNING SYSTEM - MEANS OF ACTIVATION	
8 CODE SIGNAL OR WARNING SYSTEM - TYPE DETECTION	
9 CODE SYSTEMS - TYPE	10 CODE SYSTEMS - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 109)

1 NO. OF DEATHS	2 NO. OF DEATHS	3 NO. OF DEATHS	4 NO. OF DEATHS

MAIN FIRE BLDG.

EXEMPT FROM PAYMENT OF TAXES... STATE OF CALIFORNIA... OFFICE OF THE STATE FIRE MARSHAL

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

Date 10/17/81 Time 1710

INCIDENT NO. 012101217

(X) Box / No. E-19 () Unit Disp. / Co. No.

PERSONAL DATA: Name Ramone Lang, Relationship Renter, Address 354 Ryxbee, City S.F., Telephone 334-1872. Name Ted McCann, Address 7, City Belmont, CA, Telephone.

A. INFORMATION (PAGE 17)

DATE REPORTED 3 8 0 0 5, PRESIDENT NO., LABORER NO., TIME 1 5, MONTH 11, DAY 01, YEAR 1981, LOSS \$ 0.00, DIST. OF JURISDICTION.

B. PROPERTY CLASSIFICATION (PAGE 19)

CODE 1 1 | Bldg. Fire, CODE 4 1 | Dwelling, Sin. Fam.

C. PROPERTY TYPE (PAGE 41)

CODE 1 | Building Type 5, CODE 2 5 | Short Circuit Arc, Unspes., CODE 5 5 | Electrical Failure

D. EXTENT OF DAMAGE (PAGE 49)

CODE 5 | Spread Beyond Bldg., ESTIMATED LOSS - PROPERTY 1,5,010,0.0, ESTIMATED LOSS - CONTENTS 1,5,010,0.0

E. LOCATION & CAUSE (PAGE 49)

CODE 1 0 1 | Ground Floor, CODE 4 1 | Fixed Wiring, CODE 2 5 | Short Circuit Arc, Unspes., CODE 5 5 | Electrical Failure

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

CODE 2 1 | Bedroom, CODE 6 3 | Wood, Sawm, CODE 1 7 | Structural Member or Framing, CODE 1 2 | Exterior of Bldg.

G. SPREAD OF FIRE (PAGE 77)

CODE 0 2 | Exterior of Bldg., CODE 6 3 | Wood, Sawm, CODE 1 2 | Exterior Sidewall Covering, CODE 6 5 | Prop. Too Close, Exposure

H. PROTECTION FACILITIES (PAGE 81)

CODE 2 1 | Bedroom, CODE 6 3 | Wood, Sawm, CODE 1 7 | Structural Member or Framing, CODE 1 2 | Exterior of Bldg.

I. PROTECTION FACILITIES (PAGE 81)

CODE 0 2 | Exterior of Bldg., CODE 6 3 | Wood, Sawm, CODE 1 2 | Exterior Sidewall Covering, CODE 6 5 | Prop. Too Close, Exposure

J. MISCELLANEOUS (PAGE 108)

NO DAMAGE TO ADJACENT PROPERTIES, NO DAMAGE TO LIFE, NO DAMAGE TO PROPERTY, NO DAMAGE TO ENVIRONMENT

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 17:33 INCIDENT NO. 3047
 () Box / No. _____ (x) Unit Disp. / Co. No. _____

1. OCCUPANT NAME <u>Unknown</u>	RELATIONSHIP <u>Unknown</u>	PLANS SINGLE <input type="checkbox"/> DUP <input type="checkbox"/> TRIP <input type="checkbox"/> OTHER <input type="checkbox"/>
2. ADDRESS <u>3723-25 Divisadero St.</u>	CITY <u>San Francisco</u>	STATE <u>19, 4, 1, 2, 3</u>
3. PHONE NO. <u>Unknown</u>	TELEPHONE NO. <u>Unknown</u>	TELETYPE NO.
4. MESSAGE NO.	ADDRESS	TELEPHONE NO.

A. INFORMATION (PAGE 17)

FIRE DEPT. ID <u>38005</u>	INCIDENT NO. <u>3555</u>	EXPOSURE NO. <u>4</u>	TITLE <u>17, 24, 10, 17, 18, 9</u>	DATE <u>3</u>	TIME <u>04</u>	DAY OF WEEK <u>04</u>	DAY OF MONTH <u>04</u>
-------------------------------	-----------------------------	--------------------------	---------------------------------------	------------------	-------------------	--------------------------	---------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

1. CODE <u>1 1</u>	TYPE OF STRUCTURE <u>Building fire.</u>	CLASSIFICATION <u>Building fire.</u>
2. CODE <u>4.2, 1</u>	PROPERTY CLASSIFICATION <u>Two flats.</u>	

C. PROPERTY TYPE (PAGE 18)

1. CODE <u>1</u>	PROPERTY TYPE <u>Building Type 5</u>
---------------------	---

D. EXTENT OF DAMAGE (PAGE 43)

1. CODE <u>5 1</u>	EXTENT OF DAMAGE - FEET <u>Spread beyond building of exposure.</u>
2. CODE <u>5 1</u>	EXTENT OF DAMAGE - SQUARE FEET
3. CODE <u>5 1</u>	EXTENT OF DAMAGE - CUBIC FEET
4. ESTIMATED LOSS - PROPERTY <u>18,000.00</u>	ESTIMATED LOSS - CONTENTS <u>5,010.00</u>

E. LOCATION & CAUSE (PAGE 49)

1. CODE <u>1</u>	LOCATION OF ORIGIN <u>Refer to B.F.I.</u>
2. CODE	CHARACTER OF HEAT SOURCE
3. CODE	FORM OF HEAT SOURCE
4. CODE	ACT OR CAUSE OF HEAT SOURCE

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 53)

1. CODE <u>1</u>	AREA OF ORIGIN <u>Refer to B.F.I.</u>
2. CODE	TYPE OF MATERIAL FIRST NOTICED
3. CODE	FORM OF MATERIAL FIRST NOTICED
4. CODE	AREA OF SPREAD

G. SPREAD OF FIRE (PAGE 77)

1. CODE <u>1</u>	SPREAD OF FIRE <u>Refer to B.F.I.</u>
2. CODE	TYPE OF SPREAD
3. CODE	FORM OF SPREAD
4. CODE	ACT OR CAUSE OF SPREAD

H. PROTECTION FACILITIES (PAGE 81)

1. CODE	SMOKERS - TYPE
2. CODE	SMOKERS - EFFECTIVENESS
3. CODE	SMOKERS - TYPE
4. CODE	SMOKERS - EFFECTIVENESS
5. CODE	PORTABLE EXTINGUISHERS - TYPE
6. CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

1. CODE	SMOKERS - TYPE
2. CODE	SMOKERS - EFFECTIVENESS
3. CODE	SMOKERS - TYPE
4. CODE	SMOKERS - EFFECTIVENESS
5. CODE	SMOKERS - TYPE
6. CODE	SMOKERS - EFFECTIVENESS
7. CODE	SMOKERS - TYPE
8. CODE	SMOKERS - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 100)

1. NO. OF DEATHS	NO. OF INJURIES	NO. OF DEATHS	NO. OF INJURIES
2. NO. OF DEATHS	NO. OF INJURIES	NO. OF DEATHS	NO. OF INJURIES

8038

Report prepared in accordance with the provisions of the State Fire Marshal's Office of the State Fire Marshal. This report is for informational purposes only and does not constitute an official statement of the State Fire Marshal's Office. It is subject to change and should not be used for legal purposes.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 10/17/89 Time 2000

INCIDENT NO. 000 22

(x) Box / No. 6374 () Unit Disp. / Co. No. E's 326
Batt. 910 Div 3

REPORT MADE AT GOODMAN LUMBER COMPANY	REPORT MADE BY N A	DATE 10/17/89	TIME 2000
ADDRESS 445 BAYSHORE BLVD.	CITY SAN FRANCISCO	STATE CA	ZIP 94134
PHONE NO. UNKNOWN	TELEPHONE NO. 475 336-0014	FIRE ALARM NO. NOT AVAILABLE	

#8038

A. INFORMATION (PAGE 17)

TYPE OF LOSS 3 8005	INCIDENT NO. 6-003-3	REPORT NO. 200010117	DATE 18/01/89	TIME 2000	LOCATION SAN FRANCISCO	STATE CA	ZIP 94134	INCIDENT NO. 000 22
-------------------------------	--------------------------------	--------------------------------	-------------------------	---------------------	----------------------------------	--------------------	---------------------	-------------------------------

B. PROPERTY CLASSIFICATION (PAGE 41)

CODE 1, 1	TYPE OF BUILDING BUILDING FIRE
CODE 5, 8	PROPERTY CLASSIFICATION SHOPPING COMPLEX
CODE 5, 5.5	PROPERTY CLASSIFICATION BUILDING SUPPLY STORE

CODE 3	PROPERTY TYPE Building Type
CODE 10.0.1	STRUCTURAL CLASSIFICATION 10.0.1

D. EXTENT OF DAMAGE (PAGE 45)

CODE 2	EXTENT OF DAMAGE - FIRE CONFINED TO AREA OF ORIGIN
CODE 4	EXTENT OF DAMAGE - SMOKE CONFINED TO BUILDING OF ORIGIN
CODE 2	EXTENT OF DAMAGE - WATER CONFINED TO AREA OF ORIGIN
ESTIMATED LOSS - PROPERTY 1, 0, 0, 0	ESTIMATED LOSS - CONTENTS 510, 00

E. LOCATION & CAUSE (PAGE 49)

CODE 1, 0.1	LOCATION OF ORIGIN GROUND FLOOR
CODE 5, 5	CAUSE OF ORIGIN GENERATOR (PROPANE FUELED)
CODE 1, 2	CAUSE OF ORIGIN HEAT FROM GAS FUELED FURNACE
CODE 5, 1	CAUSE OF ORIGIN PART FAILURE (GREAT IN TYPE EARTHQUAKE)

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 53)

CODE 7, 6	AREA OF ORIGIN EXTERIOR WALL SURFACE
CODE 1, 4	TYPE OF MATERIAL FIRST NOTICED L. P. GAS
CODE 1, 2	FORM OF MATERIAL FIRST NOTICED EXTERIOR SIDEWALL FINISH
CODE 0, 2	AREA OF ORIGIN EXTERIOR OF BUILDING

G. SPREAD OF FIRE (PAGE 57)

CODE 0, 2	SPREAD OF FIRE EXTERIOR OF BUILDING
CODE 1, 4	TYPE OF MATERIAL SPREAD L. P. GAS
CODE 1, 2	FORM OF MATERIAL SPREAD EXTERIOR SIDEWALL
CODE 5, 1	CAUSE OF SPREAD PART FAILURE (GREAT IN TYPE EARTHQUAKE)

H. PROTECTION FACILITIES (PAGE 61)

CODE 1	PROTECTION FACILITIES - TYPE WET PIPE
CODE 1	PROTECTION FACILITIES - EFFECTIVENESS NOT A FACTOR
CODE 1	PROTECTION FACILITIES - TYPE WET
CODE 1	PROTECTION FACILITIES - EFFECTIVENESS NOT A FACTOR
CODE 5	PROTECTION FACILITIES - TYPE A. B. C.
CODE 1	PROTECTION FACILITIES - EFFECTIVENESS NOT A FACTOR

I. PROTECTION FACILITIES (PAGE 67)

CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS
CODE	PROTECTION FACILITIES - TYPE	CODE	EFFECTIVENESS

J. MISCELLANEOUS (PAGE 100)

NO. OF REPORTS	NO. OF REPORTS	NO. OF REPORTS	NO. OF REPORTS
NO. OF REPORTS	NO. OF REPORTS	NO. OF REPORTS	NO. OF REPORTS

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 17:33 INCIDENT NO. 13101417
 () Box / No. E16, B511, B4 (X) Unit Disp. / Co. No. NO. CODE

REPORT MADE <u>Unknown</u>	REPORT MADE BY <u>Renters</u>	ALARM SOURCE <input type="checkbox"/> SEA <input type="checkbox"/> OTHER <input type="checkbox"/> OTHER <input checked="" type="checkbox"/>
ADDRESS <u>2130 Beach St.</u>	CITY <u>San Francisco</u>	STATE <u>19, 4, 1, 2, 3</u>
PHONE NO. <u>Unknown</u>	TELEPHONE NO. <u>Unknown</u>	TELEPHONE NO. <u>Unknown</u>
DAMAGE NO. <u>Unknown</u>	TELEPHONE NO.	

A. INFORMATION (PAGE 17)

AREA NO. <u>3, 8, 0, 0, 5</u>	INCIDENT NO. <u>3, 5, 5, 5</u>	REPORT NO. <u>1</u>	TIME <u>1, 7, 2, 4, 1, 0, 1, 7, 8, 9, 3</u>	DATE <u>10</u>	MONTH <u>0</u>	YEAR <u>8</u>	OUT OF SERVICE <input type="checkbox"/>
-------------------------------	--------------------------------	---------------------	--	-------------------	-------------------	------------------	--

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE <u>1, 1</u>	TYPE OF BUILDING <u>Building fire.</u>	PROPERTY CLASSIFICATION <u>(X)</u>
CODE <u>4, 2, 3</u>	PROPERTY CLASSIFICATION <u>Apartments 7-20 units.</u>	

C. PROPERTY TYPE (PAGE 18)

CODE <u>1</u>	PROPERTY TYPE <u>Building Type 5</u>
------------------	---

D. EXTENT OF DAMAGE (PAGE 41)

CODE <u>9</u>	EXTENT OF DAMAGE - FIRE <u>Spread from exposure.</u>
CODE <u>5</u>	EXTENT OF DAMAGE - SMOKE <u>Spread beyond building of exposure.</u>
CODE <u>5</u>	EXTENT OF DAMAGE - WATER
ESTIMATED LOSS - PROPERTY <u>1, 5, 0, 0, 0, 0, 0</u>	ESTIMATED LOSS - CONTENTS <u>1, 2, 5, 0, 0, 0, 0</u>

E. LOCATION & CAUSE (PAGE 49)

CODE <u>Refer to B.F.I.</u>	LEVEL OF DAMAGE
CODE <u>Refer to B.F.I.</u>	SOURCE OF HEAT CAUSING DAMAGE
CODE	FORM OF HEAT CAUSING DAMAGE
CODE	ACT OF CAUSING DAMAGE

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 43)

CODE <u>Refer to B.F.I.</u>	AREA OF SMOKE
CODE	TYPE OF MATERIAL FIRST BURNED
CODE	FORM OF MATERIAL FIRST BURNED
CODE	AREA OF SMOKE SPREAD

G. SPREAD OF FIRE (PAGE 77)

CODE <u>Refer to B.F.I.</u>	HOW SPREAD FIRE SPREAD
CODE	TYPE MATERIAL CAUSING SPREAD
CODE	FORM MATERIAL CAUSING SPREAD
CODE	ACT OF CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 91)

CODE	SMOKEALARMS - TYPE
CODE	SMOKEALARMS - EFFECTIVENESS
CODE <u>0</u>	SMOKEALARMS - TYPE
CODE <u>0</u>	SMOKEALARMS - EFFECTIVENESS
CODE <u>0</u>	PORTABLE EXTINGUISHERS - TYPE
CODE <u>0</u>	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 97)

CODE	SMOKE EXHAUST - TYPE
CODE	SMOKE EXHAUST - EFFECTIVENESS
CODE	SMOKE EXHAUST PROTECTION - TYPE
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS
CODE <u>0</u>	SIGNAL OR WARNING SYSTEM
CODE <u>0</u>	TYPE
CODE <u>0</u>	EFFECTIVENESS
CODE <u>0</u>	SMOKE EXHAUST SYSTEM - METHOD OF ACTIVATION
CODE <u>0</u>	SIGNAL WARNING SYSTEM - TYPE DETECTION

J. MISCELLANEOUS (PAGE 100)

NO. OF BURNED	NO. OF BURNED	NO. OF BURNED	NO. OF BURNED
NO. OF BURNED	NO. OF BURNED	NO. OF BURNED	NO. OF BURNED

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 15:23 1, 2, 0, 0, 4
 () Box / No. (x) Unit Disp. / Co. No. E3/B4

REPORT NAME N/A	TELEPHONE N/A	ALARM SOURCE YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
ADDRESS Intersection Octavia & California St.	CITY San Francisco	ZIP 94115
ADDRESS P. G. & E.	ADDRESS 245 Market St. San Francisco Ca. 94105	TELEPHONE NO N/A

A. INFORMATION (PAGE 17)

FILE NO 38005	INCIDENT NO 2994	OFFICIAL NO 15231101718013	TIME 15:23	DATE 10/17/89	DAY 04	OUT OF JURISDICTION <input type="checkbox"/>
------------------	---------------------	-------------------------------	---------------	------------------	-----------	---

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1, 9	TYPE OF DAMAGE Under ground P.G. & E. Vault	ADDITIONAL CODE <input checked="" type="checkbox"/>
CODE 6, 4, 2	PROPERTY CLASSIFICATION Electrical vault.	

C. PROPERTY TYPE (PAGE 21)

CODE 7	STRUCTURE, EQUIPMENT OR VEHICLE - PROPERTY TYPE Building Type 2	CONSTRUCTION CODE 1201
-----------	--	---------------------------

D. EXTENT OF DAMAGE (PAGE 45)

CODE 2	EXTENT OF DAMAGE - FIRE Confined to area of origin.
CODE 9	EXTENT OF DAMAGE - SMOKE Not a factor.
CODE 9	EXTENT OF DAMAGE - WATER Not a factor.
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
None	2010.00

E. LOCATION & CAUSE (PAGE 49)

CODE 2, 0, 1	LEVEL OF ORIGIN One floor below ground.
CODE 4, 2, 1	CHARACTER OF HEAT SOURCE ORIGIN Transformer.
CODE 2, 4	FORM OF HEAT CAUSING ORIGIN Short circuit arc, unspecified.
CODE 5, 4	SET OF ORIGIN ORIGIN ORIGIN Short circuit or ground fault.

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE 9, 2	AREA OF ORIGIN Public street.
CODE 0, 0	TYPE OF MATERIAL FIRST IDENTIFIED Insulating oil for switches.
CODE 6, 2	FORM OF MATERIAL, CAUSING SPREAD Transformer.
CODE 5, 2	MODE ORIGIN'S SMOKE SPREAD Exterior / ground level.

G. SPREAD OF FIRE (PAGE 77)

CODE	MODE ORIGIN'S FIRE SPREAD
CODE	TYPE MATERIAL, CAUSING SPREAD
CODE	FORM MATERIAL, CAUSING SPREAD
CODE	SET OF ORIGIN ORIGIN SPREAD

H. PROTECTION FACILITIES (PAGE 91)

CODE	STANDARD - TYPE
CODE	STANDARD - EFFECTIVENESS
CODE	STANDARD - TYPE
CODE	STANDARD - EFFECTIVENESS
CODE	PORTABLE ESTABLISHED - TYPE
CODE	PORTABLE ESTABLISHED - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 97)

CODE	PRIVATE ORIGIN - TYPE
CODE	PRIVATE ORIGIN - EFFECTIVENESS
CODE	SIGNAL SOUNDING PROTECTION - TYPE
CODE	SIGNAL SOUNDING PROTECTION - EFFECTIVENESS
CODE	SIGNAL OR ORIGIN SYSTEM TYPE
CODE	SIGNAL OR ORIGIN SYSTEM - EFFECTIVENESS
CODE	SIGNAL OR ORIGIN SYSTEM - MODE OF DETECTION
CODE	SIGNAL OR ORIGIN SYSTEM - TYPE DETECTED

J. MISCELLANEOUS (PAGE 105)

NO. OF INCIDENTS	NO. OF DEATHS	NO. OF INCIDENTS	NO. OF DEATHS

Contains summarized investigation and...
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

FIRE INCIDENT REPORT San Francisco Fire Department
Date 10/17/89 Time 21:30

8049

() Box / No. 8422 (X) Unit Disp. / Co. No. E-33

1. OCCUPANT NAME K. DINTCEO	RELATIONSHIP	ALARM SOURCE	NO. <input type="checkbox"/>	SPAD <input type="checkbox"/>	THREAT <input type="checkbox"/>
2. ADDRESS 150 Font Blvd.	APPT. NO. 1F	CITY San Francisco	ZIP 94132	TELEPHONE NO. 1, 3, 2	TELEPHONE NO. 1, 3, 2
3. OFFICE NAME Same	ADDRESS Same	CITY	ZIP	TELEPHONE NO.	TELEPHONE NO.
4. EMPLOYED NAME Parkmead Apts.	ADDRESS	CITY	ZIP	TELEPHONE NO.	TELEPHONE NO.

A. INFORMATION (PAGE 17)

TYPE DEPT. NO. 38005	INCIDENT NO. 0086	REPORTED BY	TIME 21:30	DATE 10/17/89	DAY 17	MONTH 10	YEAR 89	STATUS <input type="checkbox"/>	OUT OF SERVICE <input type="checkbox"/>
--------------------------------	-----------------------------	-------------	----------------------	-------------------------	------------------	--------------------	-------------------	------------------------------------	--

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1.1	TYPE OF INCIDENT Building Fire	EXTENDED DATE <input type="checkbox"/>
CODE 4.3	PROPERTY CLASSIFICATION - COMPLETE Apartment Complex	
CODE 2	PROPERTY CLASSIFICATION - INDIVIDUAL 2 Apartments	

C. PROPERTY TYPE (PAGE 21)

CODE 2	STRUCTURE TYPE, DIVISION OF BUILDING - PROPERTY TYPE Building Type 1	STORY NO. 2
------------------	--	-----------------------

D. EXTENT OF DAMAGE (PAGE 45)

CODE 2	LATENCY OF DAMAGE - FOL Confined to area of origin.
CODE 2	LATENCY OF DAMAGE - SOURCE
CODE 2	EXTENT OF DAMAGE - MOVED
ESTIMATED LOSS - PROPERTY 210,000	ESTIMATED LOSS - CONTENTS 110,000

E. LOCATION & CAUSE (PAGE 49)

CODE 1.02	LEVEL OF ORIGIN Second Floor
CODE 4.6	SOURCE OF HEAT CAUSING INCIDENT Lamp
CODE 5.4	FORM OF HEAT CAUSING INCIDENT Electric Lamp
CODE 8.2	ACT OR OMISSION CAUSING INCIDENT Earthquake

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE 1.4	AREA OF ORIGIN Living Room
CODE 5.9	TYPE OF MATERIAL FIRST STARTED Paper
CODE 2.1	FORM OF MATERIAL FIRST STARTED Chair
CODE 0.1	AREA OF ORIGIN & SMOKE SPREAD Ceiling

G. SPREAD OF FIRE (PAGE 77)

CODE 0.1	AREA AFFECTED FIRE SPREAD Ceiling
CODE 6.8	TYPE MATERIAL CAUSING SPREAD Cardboard
CODE 2.0	FORM MATERIAL CAUSING SPREAD Furniture
CODE R.2	ACT OR OMISSION CAUSING SPREAD Earthquake

H. PROTECTION FACILITIES (PAGE 81)

CODE	SMOKEALERS - TYPE
CODE	SMOKEALERS - EFFECTIVENESS
CODE	STANDPIPES - TYPE
CODE	STANDPIPES - EFFECTIVENESS
CODE	PORTABLE EXTINGUISHERS - TYPE
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

CODE	PRIVATE STORAGE - TYPE
CODE	PRIVATE STORAGE - EFFECTIVENESS
CODE	SPECIAL HOURLY PROTECTION - TYPE
CODE	SPECIAL HOURLY PROTECTION - EFFECTIVENESS
CODE	SMOKE OR WARNING SYSTEM - TYPE
CODE	SMOKE OR WARNING SYSTEM - EFFECTIVENESS
CODE	SMOKE WARNING SYSTEM - METHOD OF ACTIVATION
CODE	SMOKE WARNING SYSTEM - TYPE DETECTOR

J. MISCELLANEOUS (PAGE 109)

NO. DAMAGED	NO. OF DEVICES	NO. DAMAGED	NO. OF DEVICES
OTHER DATA SUBMITTED FOR THIS DATE			
CHECKED OFF BY: <input type="checkbox"/>			

MAIN FIRE BLDG.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL Date 10/17/84 Time 1710

INCIDENT NO. 0121027

(X) Box / No. E-19 () Unit Disp. / Co. No.

Printed information on this form is for the use of the State Fire Marshal, Department of Industrial Relations and Employment Division. This form is not to be used for any other purpose. Any information on this form is to be used only for the purpose of determining the cause of the fire and the extent of the damage. It is not to be used for any other purpose.

1 OCCUPANT NAME Ramona Lang	RELATIONSHIP Renter	ALARM SOUNDS YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	TELEPHONE NO. 334-1872
2 ADDRESS 354 Bvxbee	CITY S.F.	STATE CA	ZIP 94117
3 OCCUPANT NAME Ted McGann	ADDRESS 7	CITY Belmont, CA	STATE CA
4 OCCUPANT NAME	ADDRESS	CITY	TELEPHONE NO.

A. INFORMATION (PAGE 17)

FIRE DEPT. NO. 38005	INCIDENT NO.	EXPOSURE NO.	TIME 1.5	ALERTY	GOV. YEAR 11.011.718.913	DAY 0.8	MONTH 0.8	YEAR 0.8	STATE OF JURISDICTION
----------------------	--------------	--------------	----------	--------	--------------------------	---------	-----------	----------	-----------------------

B. PROPERTY CLASSIFICATION (PAGE 19)

1 CODE TYPE OF INCIDENT 1.1 Bldg. Fire
2 CODE PROPERTY CLASSIFICATION FOR HAZARDOUS
3 CODE PROPERTY CLASSIFICATION FOR OCCUPANCY 4.1, 1 Dwelling, Sin. Fam.

C. PROPERTY TYPE (PAGE 43)

1 Building Type 5
STRUCTURE BUILT ON OR VEHICLE - CONSTRUCTION TYPE

D. EXTENT OF DAMAGE (PAGE 45)

1 CODE EXTENT OF DAMAGE - FIRE 5 Spread Beyond Bldg.
2 CODE EXTENT OF DAMAGE - SMOKING 5
3 CODE EXTENT OF DAMAGE - WATER 5
4 ESTIMATED LOSS - PROPERTY 11,5,010,0.0
5 ESTIMATED LOSS - CONTENTS 1,5,010,0.0

E. LOCATION & CAUSE (PAGE 48)

1 CODE LEVEL OF DAMAGE 1.0 1 Ground Floor
2 CODE NUMBER OF HEAT SENSORS DETECTED 4 1 Fixed Wiring
3 CODE FORM OF HEAT SENSING METHOD 2.5 1 Short Circuit Arc, Unspes.
4 CODE ACT OF DAMAGE CAUSING INCIDENT 5.5 1 Electrical Failure

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

1 CODE AREA OF ORIGIN 2.1 Bedroom
2 CODE TYPE OF MATERIAL FIRST NOTICED 6.3 Wood, Saw
3 CODE FORM OF MATERIAL FIRST NOTICED 1.7 Structural Member or Framing
4 CODE AREA OF ORIGIN AS TO FIRE SPREAD 12 Exterior of Bldg.

G. SPREAD OF FIRE (PAGE 77)

1 CODE FORM OF SPREAD OF FIRE 0.2 Exterior of Bldg.
2 CODE TYPE OF MATERIAL CAUSING SPREAD 6.3 Wood, Saw
3 CODE FORM OF MATERIAL CAUSING SPREAD 1.2 Exterior Sidewall Covering
4 CODE ACT OF SPREAD CAUSING SPREAD 6.5 Prop. Too Close, Exposure

H. PROTECTION FACILITIES (PAGE 81)

1 CODE SPRINKLERS - TYPE
2 CODE SPRINKLERS - EFFECTIVENESS
3 CODE STANDPIPES - TYPE
4 CODE STANDPIPES - EFFECTIVENESS
5 CODE PORTABLE EXTINGUISHERS - TYPE
6 CODE PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

1 CODE FIRE ALARMS - TYPE
2 CODE PORTABLE SMOKE - EFFECTIVENESS
3 CODE SPECIAL HAZARD PROTECTION - TYPE
4 CODE SPECIAL HAZARD PROTECTION - EFFECTIVENESS
5 CODE S.S. AL. OR W. SMOKE SYSTEM - TYPE
6 CODE S.S. AL. OR W. SMOKE SYSTEM - EFFECTIVENESS
7 CODE SMOKE WARNING SYSTEM - METHOD OF ACTIVATION
8 CODE SMOKE WARNING SYSTEM - TYPE DETECTOR

J. MISCELLANEOUS (PAGE 109)

1 CODE UNEXTINGUISHED	2 CODE UNEXTINGUISHED
3 CODE UNEXTINGUISHED	4 CODE UNEXTINGUISHED
5 CODE UNEXTINGUISHED	6 CODE UNEXTINGUISHED

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 17:33
 () Box / No. (X) Unit Disp. / Co. No. 3.0-4.7

UNKNOWN	UNKNOWN	CLASSIFICATION	PERMITS	PERMITS	PERMITS
ADDRESS	CITY	STATE	COUNTY	ZIP	TELEPHONE NO.
3735-37 Divisadero St.	San Francisco	9, 4, 1, 2, 3	Unknown		
UNKNOWN					
UNKNOWN					

A. INFORMATION (PAGE 17)

FILE NO. <u>38005</u>	INCIDENT NO. <u>3525</u>	EXPOSURE NO. <u>6</u>	TIME <u>17:24</u>	DATE <u>10/17/89</u>	YEAR <u>89</u>	MONTH <u>10</u>	DAY <u>17</u>	COUNTY <u>04</u>	ZIP <u>94118</u>	OUT OF JURISDICTION <u>0</u>
-----------------------	--------------------------	-----------------------	-------------------	----------------------	----------------	-----------------	---------------	------------------	------------------	------------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF DAMAGE
1, 1	Building fire.
CODE	PROPERTY CLASSIFICATION
4, 2, 1	Two flats

C. PROPERTY TYPE (PAGE 18)

CODE	PROPERTY TYPE
1	Building Type 5

D. EXTENT OF DAMAGE (PAGE 43)

CODE	CATEGORY OF DAMAGE - FIRE
3	Confined to floor of exposure.
CODE	CATEGORY OF DAMAGE - OTHER
4	Confined to building of exposure.
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
1,000,000	25,000

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE
	Refer to B.F.I.
CODE	CHARACTER OF CAUSE
CODE	FORM OF CAUSE
CODE	ACT OF CAUSE

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF DAMAGE
	Refer to B.F.I.
CODE	TYPE OF MATERIAL FIRST NOTICED
CODE	FORM OF MATERIAL FIRST NOTICED
CODE	HOW DAMAGE BEGAN

G. SPREAD OF FIRE (PAGE 71)

CODE	HOW DAMAGE BEGAN
CODE	TYPE OF MATERIAL CAUSING SPREAD
CODE	FORM OF MATERIAL CAUSING SPREAD
CODE	ACT OF DAMAGE CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 71)

CODE	PROTECTED - TYPE
CODE	PROTECTED - EFFECTIVENESS
CODE	UNPROTECTED - TYPE
CODE	UNPROTECTED - EFFECTIVENESS
CODE	PROTECTIVE ESTABLISHMENT - TYPE
CODE	PROTECTIVE ESTABLISHMENT - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 71)

CODE	PROTECTED - TYPE
CODE	PROTECTED - EFFECTIVENESS
CODE	SPECIAL DAMAGE PROTECTION - TYPE
CODE	SPECIAL DAMAGE PROTECTION - EFFECTIVENESS
CODE	SMOKE OR HEAT DETECTION SYSTEM
CODE	SMOKE OR HEAT DETECTION SYSTEM - TYPE
CODE	SMOKE OR HEAT DETECTION SYSTEM - EFFECTIVENESS
CODE	SMOKE OR HEAT DETECTION SYSTEM - FORM OF DETECTION
CODE	SMOKE OR HEAT DETECTION SYSTEM - TYPE DETECTOR
CODE	SMOKE OR HEAT DETECTION SYSTEM - TYPE DETECTOR
CODE	SMOKE OR HEAT DETECTION SYSTEM - TYPE DETECTOR

J. MISCELLANEOUS (PAGE 100)

NO. OF PERSONS INJURED	NO. OF DEATHS	NO. OF PERSONS MISSING	NO. OF RELATIVES
OTHER FORMS SUBMITTED FOR THIS CASE			
SPECIAL CODE OF USE <input type="checkbox"/>			

FIRE INCIDENT REPORT San Francisco Fire Department
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 17:33 13000
 () Box / No. (X) Unit Disp. / Co. No.

REPORT MADE	RELATIONSHIP	ALARM SOURCE	TEL. NO.	OFF. NO.	DATE	TIME
Unknown	Unknown					
ADDRESS	CITY	ZIP	TELEPHONE NO.			
2136-38 Beach St.	San Francisco	94123	Unknown			
REPORT MADE	ADDRESS	CITY	ZIP	TELEPHONE NO.		
Unknown						

A. INFORMATION (PAGE 17)

FIRE DIST. NO.	INCIDENT NO.	EXPENSE NO.	MONTH	DAY	YEAR	DAY	MONTH	YEAR	DAY	MONTH	YEAR	DAY	MONTH	YEAR
38005	3555	217	24	10	17	89	3	0	0	0	0	0	0	0

B. PROPERTY CLASSIFICATION (PAGE 19)

CODE	TYPE OF INCIDENT	EXTENT OF DAMAGE
1, 1	Building fire.	
CODE	PROPERTY CLASSIFICATION (STRUCTURE)	
4, 2, 1	Two flats.	

C. PROPERTY TYPE (PAGE 21)

CODE	PROPERTY TYPE
1	Building Type 5

D. EXTENT OF DAMAGE (PAGE 23)

CODE	EXTENT OF DAMAGE - FIRE
4	Confined to building of exposure.
CODE	EXTENT OF DAMAGE - STRUCTURE
4	
CODE	EXTENT OF DAMAGE - CONTENTS
4	
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
1,000,000	2,500,000

E. LOCATION & CAUSE (PAGE 25)

CODE	LEVEL OF EXPOSURE
	Refer to B.F.I.
CODE	ORIGIN OF HEAT CAUSING INCIDENT
CODE	POINT OF HEAT CAUSING INCIDENT
CODE	ACT OF CHANGING CAUSING INCIDENT

F. AREA MATERIALS & SMOKE SPREAD (PAGE 27)

CODE	AREA OF ORIGIN
	Refer to B.F.I.
CODE	TYPE OF MATERIAL FIRST SPREAD
CODE	FORM OF MATERIAL FIRST SPREAD
CODE	FORM SPREAD SECOND SPREAD

G. SPREAD OF FIRE (PAGE 29)

CODE	FORM SPREAD FIRE SPREAD
CODE	TYPE OF SPREAD, CAUSING SPREAD
CODE	FORM SPREAD, CAUSING SPREAD
CODE	ACT OF CHANGING CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 31)

CODE	SPRINKLER - TYPE
CODE	SPRINKLER - EFFECTIVENESS
CODE	STAMPED - TYPE
CODE	STAMPED - EFFECTIVENESS
CODE	PORTABLE ESTABLISHED - TYPE
CODE	PORTABLE ESTABLISHED - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 33)

CODE	SPRINKLER - TYPE
CODE	SPRINKLER - EFFECTIVENESS
CODE	STAMPED - TYPE
CODE	STAMPED - EFFECTIVENESS
CODE	PORTABLE ESTABLISHED - TYPE
CODE	PORTABLE ESTABLISHED - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 35)

NO. OF BURNED	NO. OF BURNED	NO. OF BURNED	NO. OF BURNED
DO NOT WRITE IN THESE SPACES			

K. MISCELLANEOUS (PAGE 37)

CODE	OTHER FACILITIES

FOR OFFICIAL USE ONLY
THIS FORM IS THE PROPERTY OF THE
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL
REPRODUCTION OR DISTRIBUTION OF THIS FORM
WITHOUT THE WRITTEN PERMISSION OF THE
OFFICE OF THE STATE FIRE MARSHAL IS
PROHIBITED.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 10-17-89 Time 17:35

INCIDENT NO. 3,047

() Box / No. _____

(X) Unit Disp. / Co. No. E16

1	UNKNOWN	RENTERS	TYPE OF OCCUPANCY	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS
2	3701 Divisadero St.	SAN FRANCISCO	CITY	94123	ZIP	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.
3	UNKNOWN	ADDRESS	CITY	ZIP	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.
4	UNKNOWN	ADDRESS	CITY	ZIP	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.

A. INFORMATION (PAGE 17)

1	38005	INCIDENT NO.	3555	ADDRESS NO.	172410	STREET	1789	AVENUE	00	OUT OF JURISDICTION
---	-------	--------------	------	-------------	--------	--------	------	--------	----	---------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

1	1, 1	BUILDING FIRE	TYPE OF INCIDENT
2	4, 2, 4	APARTMENTS OVER 20 UNITS	PROPERTY CLASSIFICATION

C. PROPERTY TYPE (PAGE 18)

1	1	BUILDING TYPE 5	PROPERTY TYPE
---	---	-----------------	---------------

D. EXTENT OF DAMAGE (PAGE 43)

1	5	SPREAD BEYOND BUILDING OF ORIGIN	EXTENT OF DAMAGE - FIRE
2	5		EXTENT OF DAMAGE - DAMAGE
3	5		EXTENT OF DAMAGE - WATER
4	2, 5, 0, 0, 0, 0	ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
	4, 0, 0, 0, 0, 0		

E. LOCATION & CAUSE (PAGE 49)

1		REFER TO B.F.I.	LOCATION OF ORIGIN
2			CAUSE OF FIRE
3			FORM OF FIRE
4			EXTENT OF DAMAGE

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 53)

1		REFER TO B.F.I.	AREA OF ORIGIN
2			TYPE OF MATERIALS FIRST NOTICED
3			FORM OF MATERIALS FIRST NOTICED
4			SMOKE SPREAD

G. SPREAD OF FIRE (PAGE 57)

1		REFER TO B.F.I.	AREA SPREAD
2			TYPE OF SPREAD
3			FORM OF SPREAD
4			EXTENT OF SPREAD

H. PROTECTION FACILITIES (PAGE 59)

1	0	UNKNOWN	PROTECTION FACILITIES - TYPE
2	0		PROTECTION FACILITIES - EFFECTIVENESS
3	0		PROTECTION FACILITIES - TYPE
4	0		PROTECTION FACILITIES - EFFECTIVENESS
5	0		PROTECTION FACILITIES - TYPE
6	0		PROTECTION FACILITIES - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 59)

1	0	UNKNOWN	PROTECTION FACILITIES - TYPE
2	0		PROTECTION FACILITIES - EFFECTIVENESS
3	0		PROTECTION FACILITIES - TYPE
4	0		PROTECTION FACILITIES - EFFECTIVENESS
5	0		PROTECTION FACILITIES - TYPE
6	0		PROTECTION FACILITIES - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 100)

1		NO. OF UNITS	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS
2					

1		NO. OF UNITS	NO. OF UNITS	NO. OF UNITS	NO. OF UNITS
2					

#0133

8003

OFFICE OF THE STATE FIRE MARSHAL
STATE OF CALIFORNIA
FIRE INCIDENT REPORT

FIRE INCIDENT REPORT

SAN FRANCISCO FIRE DEPARTMENT

OFFICE OF THE STATE FIRE MARSHAL

Date 10/17/89 Time 4:0013

() Box / No. 8175 () Unit Disp. / Co. No.

1	RECIPIENT NAME Rose Adams	RELATIONSHIP Tenant	PHONE NUMBER TEL. NO. <input type="checkbox"/> AREA <input type="checkbox"/> EXT. <input type="checkbox"/>
2	ADDRESS 965 Chermery	CITY S F	STATE 94.1.3.1
3	ZIP CODE 94117	CITY S F	TELEPHONE NO. 365 1711
4	ADDRESS 965 Chermery	CITY S F	TELEPHONE NO. 365 1711

#8003

A. INFORMATION (PAGE 17)

1	INCIDENT NO. 38005	REPORT NO. 00732	REPORT DATE 10/17/89	REPORT TIME 11:28:00	REPORT HOUR 11	REPORT MINUTE 28	REPORT SECOND 00	REPORT DAY 3	REPORT MONTH 10	REPORT YEAR 89	REPORT HOUR 11	REPORT MINUTE 28	REPORT SECOND 00	REPORT DAY 3	REPORT MONTH 10	REPORT YEAR 89	REPORT HOUR 11	REPORT MINUTE 28	REPORT SECOND 00	REPORT DAY 3	REPORT MONTH 10	REPORT YEAR 89
---	------------------------------	----------------------------	--------------------------------	--------------------------------	--------------------------	----------------------------	----------------------------	------------------------	---------------------------	--------------------------	--------------------------	----------------------------	----------------------------	------------------------	---------------------------	--------------------------	--------------------------	----------------------------	----------------------------	------------------------	---------------------------	--------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

1	TYPE OF INCIDENT 1.1 Building Fire
2	PROPERTY CLASSIFICATION 4.1.1 single family

C. PROPERTY TYPE (PAGE 41)

1	BUILDING TYPE 5
2	SOURCE OF HEAT 9.81 no Equipment
3	FORM OF HEAT 4.4.1 candle
4	MODE OF HEAT 7.1 overturned

D. EXTENT OF DAMAGE (PAGE 45)

1	EXTENT OF DAMAGE - FIRE 2.1 confined to area
2	EXTENT OF DAMAGE - WATER 2.1
3	ESTIMATED LOSS - PROPERTY 110,000
4	ESTIMATED LOSS - CONTENTS 15,000

E. LOCATION & CAUSE (PAGE 49)

1	LEVEL OF DAMAGE 1.0.2.1 second floor
2	SOURCE OF HEAT 9.81 no Equipment
3	FORM OF HEAT 4.4.1 candle
4	MODE OF HEAT 7.1 overturned

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

1	AREA OF DAMAGE 2.1 bedroom
2	TYPE OF MATERIAL FIRST NOTICED 7.2 cotton
3	FORM OF MATERIAL FIRST NOTICED 3.1 Mattress
4	MODE OF DAMAGE 0.1 ceilings

G. SPREAD OF FIRE (PAGE 77)

1	MODE OF SPREAD 0.91 not a factor
2	TYPE OF SPREAD 1
3	FORM OF SPREAD 1
4	MODE OF SPREAD 1

H. PROTECTION FACILITIES (PAGE 91)

1	APPROVALS - TYPE
2	APPROVALS - EFFECTIVENESS
3	STANDARD - TYPE
4	STANDARD - EFFECTIVENESS
5	PORTABLE EXTINGUISHERS - TYPE
6	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 97)

1	PRIVATE PROTECT - TYPE
2	PRIVATE PROTECT - EFFECTIVENESS
3	PRIVATE PROTECT - TYPE
4	PRIVATE PROTECT - EFFECTIVENESS
5	PRIVATE PROTECT - TYPE
6	PRIVATE PROTECT - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 108)

1	NO. OF REPORTS	NO. OF STATES	NO. OF REPORTS	NO. OF STATES
2	NO. OF REPORTS	NO. OF STATES	NO. OF REPORTS	NO. OF STATES

K. MISCELLANEOUS (PAGE 114)

1	NO. OF REPORTS	NO. OF STATES	NO. OF REPORTS	NO. OF STATES
2	NO. OF REPORTS	NO. OF STATES	NO. OF REPORTS	NO. OF STATES

EXPOSURE # 1

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 10/17/89 Time 1710

INCIDENT NO. 0.3.0.2.7

DCI Box / No. E-19 () Unit Disp. / Co. No.

1 OCCUPANT NAME Mable Havter	2 OCCUPANT RELATIONSHIP Owner	3 ALARM SOURCE YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	4 IF YES, TYPE SOUND <input type="checkbox"/> VISUAL <input type="checkbox"/>
5 ADDRESS 350 Bvxbee St.	6 CITY S.F.	7 ZIP 94117	8 TELEPHONE NO. 884-1026
9 OTHER NAME Same	10 ADDRESS Same	11 CITY S.F.	12 TELEPHONE NO. Same

A. INFORMATION (PAGE 17)

1 FIRE NO. 38005	2 INCIDENT NO. 0.3.0.2.7	3 EXPOSURE NO. 0.0.1	4 TIME 17.10	5 MONTHS 10	6 DAY 17	7 YEAR 1989	8 LOSS TYPE 13	9 LOSS VALUE 0.0	10 OUT OF JURISDICTION
------------------	--------------------------	----------------------	--------------	-------------	----------	-------------	----------------	------------------	------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

1 CODE 7.7	2 TYPE OF BLDG. Bldg. Flap
3 CODE	4 PROPERTY CLASSIFICATION (NON-RESIDENTIAL)
5 CODE	6 PROPERTY CLASSIFICATION (RESIDENTIAL)
7 CODE	8 -4, 1, 1 Dwelling, Sin. Fam.

C. PROPERTY TYPE (PAGE 41)

1 CODE 1	2 BUILDING TYPE Building Type 5
3 CODE	4 STRUCTURE, BUILDING OR VEHICLE CONSTRUCTION TYPE
5 CODE	6 CONSTRUCTION TYPE

1 CODE 4	2 EXTENT OF DAMAGE - BLDG. Bldg. of Orig.
3 CODE 4	4 EXTENT OF DAMAGE - BURNING
5 CODE 4	6 EXTENT OF DAMAGE - WATER
7 ESTIMATED LOSS - PROPERTY 0.0000	8 ESTIMATED LOSS - CONTENTS 15000.00

E. LOCATION & CAUSE (PAGE 49)

1 CODE 1.0	2 LEVEL OF BLDG. Ground Floor
3 CODE 9.3	4 POSITION OF BLDG. Separate Adjoining Object
5 CODE 8.1	6 FORM OF HEAT TRANSFER Direct Flame
7 CODE 6.5	8 ACT OR OMISSION CAUSING INCIDENT Prop. Too Close, Exposure Fire

1 CODE 7.6	2 AREA OF SPILLAGE Exterior Wall Surface
3 CODE 6.3	4 TYPE OF MATERIAL BLDG. Painted Wood, Sawn
5 CODE 1.2	6 FORM OF MATERIAL FIRST SPILLED Exterior Sidewall Covering
7 CODE 0.2	8 ACTION TAKEN BY BLDG. Exterior of Bldg.

G. SPREAD OF FIRE (PAGE 77)

1 CODE	2 WIND DIRECTION & FORCE
3 CODE	4 TYPE OF MATERIAL CAUSING SPREAD
5 CODE	6 FORM OF MATERIAL CAUSING SPREAD
7 CODE	8 ACT OR OMISSION CAUSING SPREAD

1 CODE	2 TYPE OF FACILITY
3 CODE	4 APPROVED - EFFECTIVENESS
5 CODE	6 STANDARDS - TYPE
7 CODE	8 STANDARDS - EFF. SYSTEM
9 CODE	10 PORTABLE ESTABLISHMENT - TYPE
11 CODE	12 PORTABLE ESTABLISHMENT - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

1 CODE	2 NO. OF FACILITY	3 TYPE
4 CODE	5 PRIVATE SYSTEM - EFFECTIVENESS	6
7 CODE	8 SPECIAL HAZARD PROTECTION - TYPE	9
10 CODE	11 SPECIAL HAZARD PROTECTION - EFFECTIVENESS	12
13 CODE	14 P.E.M. OR OTHER SYSTEM - TYPE	15 EFFECTIVENESS
16 CODE	17 SPECIAL HAZARD SYSTEM - METHOD OF DETECTION	18
19 CODE	20 SPECIAL HAZARD SYSTEM - PROP. DETECTION	21
22 CODE	23 WATERWORKS - EFFECTIVENESS	24 OTHER FACILITIES - TYPE

J. MISCELLANEOUS (PAGE 100)

1 NO. OF PERSONS	2 NO. OF BLDGS.	3 NO. OF VEHICLES	4 NO. OF DEATHS
5	6	7	8
9	10	11	12

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-17-89 Time 17:33 INCIDENT NO. 3107 PAGE 7
 () Box / No. _____ (X) Unit Disp. / Co. No. _____

1 OCCUPANT NAME Unknown	RELATIONSHIP Unknown	PLANNED BOULEVARD	NO. <input type="checkbox"/>	STREET NO.	NO. <input type="checkbox"/>	APARTMENT NO.	NO. <input type="checkbox"/>	TELEPHONE NO.
2 ADDRESS 3729-31 Divisadero St.	CITY San Francisco	STATE CA	ZIP 94118	PARCEL NO.	NO. <input type="checkbox"/>	SECTION NO.	NO. <input type="checkbox"/>	TELEPHONE NO.
3 OCCUPANT NAME Unknown	RELATIONSHIP	PLANNED	NO. <input type="checkbox"/>	STREET	NO. <input type="checkbox"/>	APARTMENT	NO. <input type="checkbox"/>	TELEPHONE
4 OCCUPANT NAME	RELATIONSHIP	PLANNED	NO. <input type="checkbox"/>	STREET	NO. <input type="checkbox"/>	APARTMENT	NO. <input type="checkbox"/>	TELEPHONE

A. INFORMATION (PAGE 7)

FIRE DEPT. ID 38005	INCIDENT NO. 3555	EXPOSURE NO. 5	UNIT NO. 1724	TRUCK NO. 1101	ENGINE NO. 7189	DATE 10/17/89	TIME 17:33	CHECK OF UNIT <input type="checkbox"/>
------------------------	----------------------	-------------------	------------------	-------------------	--------------------	------------------	---------------	---

B. PROPERTY CLASSIFICATION (PAGE 12)

CODE 1, 1	TYPE OF INCIDENT Building fire.	EXPOSURE DATE <input checked="" type="checkbox"/>
CODE 4, 2, 1	PROPERTY CLASSIFICATION (SIC)	
CODE 5	PROPERTY CLASSIFICATION (SIC)	

C. PROPERTY TYPE (PAGE 13)

CODE 1	PROPERTY TYPE Building Type 5	NO. OF FLOORS 3
CODE 2, 2, 1	STRUCTURE CLASSIFICATION (CONSTRUCTION TYPE)	

D. EXTENT OF DAMAGE (PAGE 43)

CODE 5	EXTENT OF DAMAGE - TYPE Spread beyond building of exposure.
CODE 5	EXTENT OF DAMAGE - DAMAGE
CODE 5	EXTENT OF DAMAGE - DATED
ESTIMATED LOSS - PROPERTY 8,000,000	ESTIMATED LOSS - CONTENTS 5,000,000

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF ORIGIN Refer to B.F.I.
CODE	SCOPE OF HEAT EXPOSURE
CODE	FORM OF HEAT EXPOSURE
CODE	SET ON EXPOSURE

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF ORIGIN Refer to B.F.I.
CODE	TYPE OF MATERIAL FIRST NOTICED
CODE	FORM OF MATERIAL FIRST NOTICED
CODE	AREA SPREAD

G. SPREAD OF FIRE (PAGE 71)

CODE	AREA SPREAD Refer to B.F.I.
CODE	TYPE OF SPREAD
CODE	FORM OF SPREAD
CODE	SET ON SPREAD

H. PROTECTION FACILITIES (PAGE 77)

CODE	SPRINKLER - TYPE
CODE	SPRINKLER - EFFECTIVENESS
CODE	STANDPIPE - TYPE
CODE	STANDPIPE - EFFECTIVENESS
CODE	PORTABLE EXTINGUISHERS - TYPE
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

CODE	SMOKE EXHAUSTION - TYPE
CODE	SMOKE EXHAUSTION - EFFECTIVENESS
CODE	SMOKE EXHAUSTION PROTECTION - TYPE
CODE	SMOKE EXHAUSTION PROTECTION - EFFECTIVENESS
CODE	SMOKE EXHAUSTION SYSTEM - TYPE
CODE	SMOKE EXHAUSTION SYSTEM - EFFECTIVENESS
CODE	SMOKE EXHAUSTION SYSTEM - MODE OF DETECTION
CODE	SMOKE EXHAUSTION SYSTEM - TYPE DETECTOR

J. MISCELLANEOUS (PAGE 100)

NO. OF REPORTS NO. OF REPORTS	NO. OF REPORTS NO. OF REPORTS
NO. OF REPORTS NO. OF REPORTS	NO. OF REPORTS NO. OF REPORTS

SFD FORM 60-60 (7-78)

Completed
8020
25001

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/17/59 Time 17:15

4522
 () Box / No. 221, 65 (X) Unit Disp. / Co. No. _____

1. OCCUPANT NAME MR. MR ARTHY	RELATIONSHIP TENANT	CLASSIFICATION RESIDENCE	TYPE OF DAMAGE NO DAMAGE	EXTENT OF DAMAGE NO DAMAGE
2. ADDRESS 3739 LOYOLA TERRACE	CITY SAN FRANCISCO	STATE CA	ZIP 94117	TELEPHONE OR LOCAL DIALING
3. OCCUPANT NAME MR. HOWARD JUNKER	RELATIONSHIP (UNKNOWN)	CLASSIFICATION RESIDENCE	TYPE OF DAMAGE NO DAMAGE	EXTENT OF DAMAGE NO DAMAGE
4. ADDRESS	CITY	STATE	ZIP	TELEPHONE OR LOCAL DIALING

A. INFORMATION (PAGE 17)

1. FIRE DEPT. NO. 38005	2. INCIDENT NO.	3. EXPOSURE NO.	4. TIME	5. MONTH	6. DAY	7. YEAR	8. (OPTIONAL) DAY	9. (OPTIONAL) MONTH	10. (OPTIONAL) YEAR
B. PROPERTY CLASSIFICATION (PAGE 19)					C. PROPERTY TYPE (PAGE 21)				
1. TYPE OF PROPERTY 1.1 BUILDING FIRE	2. EXTENT OF DAMAGE - TYPE	3. EXTENT OF DAMAGE - SOURCE	4. EXTENT OF DAMAGE - MEDIUM	5. ESTIMATED LOSS - PROPERTY	6. ESTIMATED LOSS - CONTENTS	7. PROPERTY TYPE	8. BUILDING TYPE	9. BUILDING TYPE	10. BUILDING TYPE
1. TYPE OF DAMAGE - TYPE 3.1 CONFINED TO FLOOR OF ORIGIN	2. TYPE OF DAMAGE - SOURCE 4.1 CONFINED TO BUILDING	3. TYPE OF DAMAGE - MEDIUM 4.1 CONFINED TO BUILDING	4. ESTIMATED LOSS - PROPERTY 1,000.00	5. ESTIMATED LOSS - CONTENTS 500.00	6. LOCATION OF ORIGIN 1.0.2 SECOND LEVEL	7. SOURCE OF HEAT CAUSING INCIDENT 2.1 STOVE	8. FUEL OF HEAT CAUSING INCIDENT 1.2 GAS FUELED	9. SET OF DAMAGED LAMPING INDICATOR 7.2 ACCIDENTALLY NOT TURNED OFF	10. SPREAD OF FIRE (PAGE 27)
F. AREA MATERIALS & SMOKE SPREAD (PAGE 31)					G. SPREAD OF FIRE (PAGE 27)				
1. AREA OF ORIGIN 3.4 KITCHEN	2. TYPE OF MATERIAL FIRST NOTICED 5.71 FOOD	3. FORM OF MATERIAL FIRST NOTICED 7.6 COOKING MATERIAL	4. HOW SPREAD & SMOKE SPREAD 0.7 HORIZONTAL	5. TYPE OF MATERIAL CAUSING SPREAD	6. HOW SPREAD & SMOKE SPREAD	7. TYPE OF MATERIAL CAUSING SPREAD	8. HOW SPREAD & SMOKE SPREAD	9. TYPE OF MATERIAL CAUSING SPREAD	10. HOW SPREAD & SMOKE SPREAD
H. PROTECTION FACILITIES (PAGE 37)					I. PROTECTION FACILITIES (PAGE 37)				
1. SPRINKLERS - TYPE	2. SPRINKLERS - EFFECTIVENESS	3. STAMPED - TYPE	4. STAMPED - EFFECTIVENESS	5. PORTABLE ESTABLISHED - TYPE	6. PORTABLE ESTABLISHED - EFFECTIVENESS	7. PRIVATE SPRINKLER - TYPE	8. PRIVATE SPRINKLER - EFFECTIVENESS	9. SPECIAL SPECIAL PROTECTION - TYPE	10. SPECIAL SPECIAL PROTECTION - EFFECTIVENESS
J. MISCELLANEOUS (PAGE 109)					K. MISCELLANEOUS (PAGE 109)				
1. FORM FILLING	2. NO. OF SECTIONS	3. NO. OF SECTIONS	4. NO. OF SECTIONS	5. NO. OF SECTIONS	6. NO. OF SECTIONS	7. NO. OF SECTIONS	8. NO. OF SECTIONS	9. NO. OF SECTIONS	10. NO. OF SECTIONS

Ring the Co - *don't take without incident* 8478

(FORMER) CONTAINS INFORMATION ON...
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

FIRE INCIDENT REPORT

San Francisco Fire Department
Date 10-17-97 Time 2:16

8478
incident

(K) Box / No. 8631 () Unit Disp. / Co. No.

REPORT NAME: Mrs Diamond
ADDRESS: 69 Castenada Av.
CITY: S.F.
STATE: CA ZIP: 94131
TELEPHONE NO: 94131

A. INFORMATION (PAGE 17)

INCIDENT NO: 38005
PREMISE NO: 00013
ADDRESS: 1017893
CITY: S.F. STATE: CA ZIP: 94131

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE: 1.1 Building Fire
CODE: 4.1.1 Dwelling 1-family

C. PROPERTY TYPE (PAGE 21)

CODE: 1 Building Type Single Occup. in 0 2

D. EXTENT OF DAMAGE (PAGE 43)

CODE: 2 Confined to area of origin
CODE: 2
ESTIMATED LOSS - PROPERTY
ESTIMATED LOSS - CONTENTS

E. LOCATION & CAUSE (PAGE 49)

CODE: 1.0.1 Ground Floor
CODE: 0.0 Unknown
CODE: 0.0 Undetermined
CODE: 8.2 Earthquake

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE: 4.3 Storage room
CODE: 1.1 Natural gas
CODE: 1.4 Flooring
CODE: 0.4 Other vertical openings

G. SPREAD OF FIRE (PAGE 77)

CODE: 0.9 Not a factor
CODE: 1.1 Natural Gas
CODE: 1.7 Wood framing
CODE: 8.2 Earthquake

H. PROTECTION FACILITIES (PAGE 87)

CODE: []
CODE: []
CODE: []
CODE: []
CODE: []
CODE: []

I. PROTECTION FACILITIES (PAGE 87)

CODE: []
CODE: []
CODE: []
CODE: []
CODE: []
CODE: []

J. MISCELLANEOUS (PAGE 109)

NO OF DAMAGED...
NO OF DAMAGED...
NO OF DAMAGED...
NO OF DAMAGED...

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/17/89 Time 1549 INCIDENT NO. 0, 3.0.0.5
 (X) Box / No. 6141 () Unit Disp. / Co. No. _____

REPORT NAME Eleina Rivera	RELATIONSHIP Owner	PLANNED YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	RECALLED YES <input type="checkbox"/> NO <input type="checkbox"/>
ADDRESS 718 Brazil Ave.	CITY S.F.	STATE CA	TELEPHONE NO. 587-9697
PREVIOUS NAME Same	ADDRESS	CITY	STATE
PREVIOUS NAME	ADDRESS	CITY	STATE

A. INFORMATION (PAGE 17)

INCIDENT NO. 38005	REPORT NO. 0, 3.0.0.5	REPORT DATE 10/17/89	REPORT TIME 1549	REPORT DAY 10	REPORT MONTH 10	REPORT YEAR 89	REPORT COUNTY 09	REPORT DISTRICT 00	REPORT CITY 00	REPORT ZIP 00
------------------------------	---------------------------------	--------------------------------	----------------------------	-------------------------	---------------------------	--------------------------	----------------------------	------------------------------	--------------------------	-------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

TYPE OF INCIDENT 1 1 Bldg. Fire	PROPERTY CLASSIFICATION 4 1 1 Dwelling, Sin. Fam.
---	---

C. PROPERTY TYPE (PAGE 41)

PROPERTY TYPE 1 Building Type C

D. EXTENT OF DAMAGE (PAGE 45)

AREA OF ORIGIN 2 1 Area of Orig.	ESTIMATED LOSS - PROPERTY 0	ESTIMATED LOSS - CONTENTS 1, 0
--	---------------------------------------	--

E. LOCATION & CAUSE (PAGE 46)

LEVEL OF ORIGIN 1 0 2 Second Floor	FORM OF HEAT CAUSING INCIDENT 1 2 Gas Fueled Equip.
--	---

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

AREA OF ORIGIN 2 4 Kitchen	TYPE OF MATERIAL CAUSING SPREAD 1 1 Nat'l. Gas
--------------------------------------	--

G. SPREAD OF FIRE (PAGE 77)

TYPE MATERIAL CAUSING SPREAD	ACT OF EXTENSION CAUSE SPREAD
------------------------------	-------------------------------

H. PROTECTION FACILITIES (PAGE 91)

SPRINKLER - TYPE	SPRINKLER - EFFECTIVENESS
STAMPED - TYPE	STAMPED - EFFECTIVENESS
PORTABLE EXTINGUISHERS - TYPE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 91)

SMoke Alarm - TYPE	SMoke Alarm - EFFECTIVENESS
SMoke Alarm - TYPE	SMoke Alarm - EFFECTIVENESS
SMoke Alarm - TYPE	SMoke Alarm - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 100)

NO. OF REPORTS	NO. OF S.O.'S	NO. OF S.O.'S	NO. OF S.O.'S
----------------	---------------	---------------	---------------

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL
 Date 10-17-89 Time 08:15 INCIDENT NO. 2,9,1,0 1,0
 (X) Box / No. 1543 () Unit Disp. / Co. No.

RECEIPT NAME Miss Cardender	RELATIONSHIP Renter	PHONE SOURCE <input checked="" type="checkbox"/>	PHONE NUMBER <input type="checkbox"/>	PHONE AREA <input type="checkbox"/>
ADDRESS 830 Post St.	CITY Rm. 17	STATE San Francisco	ZIP 9,4,1,0,9	TELEPHONE NO. Unknown
OWNER NAME Unknown	ADDRESS 830 Post. S.F. Ca. 94109	CITY Rm. 14	STATE Ca.	ZIP 928 - 4467
PROPERTY OWNER Miss Reinesch	ADDRESS 830 Post. S.F. Ca. 94109	CITY Rm. 14	STATE Ca.	ZIP 928 - 4467

A. INFORMATION (PAGE 17)

FIRE DEPT. NO. 3,8,0,0,5	INCIDENT NO. 2,9,1,0	EXPOSURE NO. 0,8,1,5,1,0,1,1,7,18,9,1,3	DATE 10,17,89	TIME 0,8	OUT OF JURISDICTION <input type="checkbox"/>
------------------------------------	--------------------------------	---	-------------------------	--------------------	---

B. PROPERTY CLASSIFICATION (PAGE 19)

CODE 1, 1	TYPE OF INCIDENT Building fire.	LOSS DATE <input checked="" type="checkbox"/>
CODE 4, 2, 3	PROPERTY CLASSIFICATION - MULTIFAMILY APARTMENTS 7-20 UNITS.	

C. PROPERTY TYPE (PAGE 21)

CODE 1	PROPERTY TYPE Building Type 3
------------------	---

D. EXTENT OF DAMAGE (PAGE 43)

CODE 1	EXTENT OF DAMAGE - FIRE Confined to materials first ignited.
CODE 1	EXTENT OF DAMAGE - STRUCTURE None
CODE 1	EXTENT OF DAMAGE - WATER None
ESTIMATED LOSS - PROPERTY None	ESTIMATED LOSS - CONTENTS 1,0

E. LOCATION & CAUSE (PAGE 49)

CODE 1, 0, 4	LEVEL OF ORIGIN Fourth floor.
CODE 2, 1	SOURCE OF HEAT CAUSING INCIDENT Stove.
CODE 8, 1	FORM OF HEAT CAUSING INCIDENT Direct flame.
CODE 7, 3	ACT OF CAUSING INCIDENT Unattended.

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE 2, 4	AREA OF ORIGIN Kitchen.
CODE 7, 6	TYPE OF MATERIAL FIRST IGNITED Cooking materials.
CODE 5, 7	FORM OF MATERIAL FIRST IGNITED Food.
CODE 0, 4	AREA OF SMOKE SPREAD Verticle openings.

G. SPREAD OF FIRE (PAGE 77)

CODE	WIND DIRECTION & FORCE
CODE	TYPE OF SPREAD, CAUSING SPREAD
CODE	FORM MATERIAL CAUSING SPREAD
CODE	ACT OF SPREAD CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 81)

CODE 4	STANDARD - TYPE Dry without permanent water supply.
CODE 1	STANDARD - EFFECTIVENESS Not a factor in outcome.
CODE 5	PORTABLE ESTABLISHMENTS - TYPE For classes A, B & C type fires.
CODE 1	PORTABLE ESTABLISHMENTS - EFFECTIVENESS Not a factor in outcome.

I. PROTECTION FACILITIES (PAGE 87)

CODE	PRIVATE SPRINKLER - TYPE
CODE	PRIVATE SPRINKLER - EFFECTIVENESS
CODE	SPRINKLER SYSTEM PROTECTION - TYPE
CODE	SPRINKLER SYSTEM PROTECTION - EFFECTIVENESS
CODE 1	SMOKE OR GAS DETECTOR SYSTEM Local
CODE 2	SMOKE OR GAS DETECTOR SYSTEM - TYPE OF DETECTOR Satisfactory
CODE 2	SMOKE OR GAS DETECTOR SYSTEM - TYPE OF DETECTOR Automatic detectors & pull stations.
CODE 2	SMOKE OR GAS DETECTOR SYSTEM - TYPE OF DETECTOR Smoke.

J. MISCELLANEOUS (PAGE 100)

NO. OF INHABITANTS	NO. OF BEINGS	NO. OF INHABITANTS	NO. OF BEINGS
NO. OF INHABITANTS	NO. OF BEINGS	NO. OF INHABITANTS	NO. OF BEINGS
MAY FORM BE SUBMITTED FOR GOLD DEATH CHECKED ONE OF YES <input type="checkbox"/>			

Contents explained in the report are intended for the use of the State Fire Marshal, Commission and appropriate state departments. This report and "Final Report" shall not be used for any other purpose without the written consent of the State Fire Marshal's Office. It is the responsibility of the user to verify the accuracy of the information contained herein before using it for any other purpose.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA

OFFICE OF THE STATE FIRE MARSHAL

Date 10-17-89 Time 17:37

INCIDENT NO. 131047

() Box / No. _____

(X) Unit Disp. / Co. No. _____

NO. OF REPORTS YES

1	REPORT NAME <u>Unknown</u>	PLACEMENT <u>Unknown</u>	PLANS SOURCE YES <input type="checkbox"/> NO <input type="checkbox"/>	DATE YES <input type="checkbox"/> NO <input type="checkbox"/>	STATUS YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
2	ADDRESS <u>3717-19 Divisadero St.</u>	CITY <u>San Francisco</u>	ZIP <u>94112.3</u>	TELEPHONE OR MAIL ORDER <u>Unknown</u>	
3	OWNER NAME <u>Unknown</u>	ADDRESS CITY ZIP	TELEPHONE NO		
4	DAMAGE CODE	ADDRESS CITY ZIP	TELEPHONE NO		

A. INFORMATION (PAGE 7)

FIRE DEPT. NO.	INCIDENT NO.	EXPOSURE NO.	TITLE	MONTH	DAY	YEAR	DAY	MONTH	YEAR	DATE OF INCIDENT	DATE OF REPORT	PERCENT OF LOSS	CHECK OF LOSS
<u>38005</u>	<u>3555</u>	<u>3</u>	<u>17.24</u>	<u>10</u>	<u>17</u>	<u>89</u>	<u>10</u>	<u>17</u>	<u>89</u>	<u>17:37</u>	<u>10/17/89</u>	<u>0%</u>	<input type="checkbox"/>

B. PROPERTY CLASSIFICATION (PAGE 10)

CODE	TYPE OF INCIDENT	CLASSIFICATION
<u>11</u>	<u>Building fire.</u>	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
CODE	PROPERTY CLASSIFICATION	
<u>421</u>	<u>Two flats.</u>	

C. PROPERTY TYPE (PAGE 11)

CODE	PROPERTY TYPE	STRUCTURE	CONSTRUCTION	DATE
<u>1</u>	<u>Building Type 5</u>	<u>1</u>	<u>3</u>	

D. EXTENT OF DAMAGE (PAGE 43)

CODE	EXTENT OF DAMAGE - FIRE
<u>5</u>	<u>Spread beyond exposure building.</u>
CODE	EXTENT OF DAMAGE - WATER
<u>5</u>	
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
<u>18,000.00</u>	<u>5,000.00</u>

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE
	<u>Refer to B.F.I.</u>
CODE	SOURCE OF HEAT CAUSING INCIDENT
CODE	FORM OF HEAT CAUSING INCIDENT
CODE	AGE OF EXPOSURE CAUSING INCIDENT

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 52)

CODE	AREA OF ORIGIN
	<u>Refer to B.F.I.</u>
CODE	TYPE OF MATERIAL FIRST NOTICED
CODE	FORM OF MATERIAL FIRST NOTICED
CODE	SMOKE SPREAD'S SMOKE SPREAD

G. SPREAD OF FIRE (PAGE 77)

CODE	WIND DIRECTION & FORCE
	<u>Refer to B.F.I.</u>
CODE	TYPE OF SPREAD CAUSING SPREAD
CODE	FORM OF SPREAD CAUSING SPREAD
CODE	AGE OF EXPOSURE CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 81)

CODE	SPRINKLERS - TYPE
CODE	SPRINKLERS - EFFECTIVENESS
CODE	STANDPIPELS - TYPE
CODE	STANDPIPELS - EFFECTIVENESS
CODE	PORTABLE ESTABLISHMENTS - TYPE
CODE	PORTABLE ESTABLISHMENTS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

CODE	SMOKE EXHAUST - TYPE		
CODE	SMOKE EXHAUST - EFFECTIVENESS		
CODE	SPECIAL HAZARD PROTECTION - TYPE		
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS		
CODE	SEMI-AUTOMATIC SYSTEM	TYPE	EFFECTIVENESS
CODE	SEMI-AUTOMATIC SYSTEM - METHOD OF DETECTION		
CODE	SEMI-AUTOMATIC SYSTEM - TYPE DETECTION		
CODE	WATERMIST SYSTEMS - TYPE	EFFECTIVENESS	
CODE	WATERMIST SYSTEMS - TYPE DETECTION	EFFECTIVENESS	

J. MISCELLANEOUS (PAGE 100)

NO. OF REPORTS	NO. OF DEATHS	NO. OF INJURIES	NO. OF DEATHS
NO. OF REPORTS SUBMITTED FOR LOSS CLAIM			
CHECKED ONE OF YES <input type="checkbox"/>			

Enquirer... (Small text regarding insurance and liability)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

8062

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL Date 10/17/89 Time 23:31

CD 8062

Box / No. 4532 () Unit Disp. / Co. No.

Form with address fields: 630 & 632 COLC STREET S.F. 94117, DORRIS KASHNAROFF 145 MCGEE AVE. S.F. 94127

A. INFORMATION (PAGE 1)

Form with incident details: 38005 00.0.0.9 1.01.718.9 5 FOS

B. PROPERTY CLASSIFICATION (PAGE 2) 1.1 BUILDING FIRE 4.2.1 FLATS (2 UNITS)

C. PROPERTY TYPE (PAGE 3) 1 Building Type 5 1002

D. EXTENT OF DAMAGE (PAGE 4) 4.1 CONFINED TO BUILDING 4.1 CONFINED TO BUILDING 4.1 CONFINED TO BUILDING

E. LOCATION & CAUSE (PAGE 5) 1.0.1 GROUND FLOOR 4.1 ELECTRICAL WIRING 2.2 SHORT CIRCUIT (MECHANICAL DMC) 8.2.1 EARTHQUAKE

F. AREA MATERIALS & SMOKE SPREAD (PAGE 6) 4.2 CLOSET 6.3 WOOD 1.2 LATHE 6.7 HORIZONTAL OPENINGS

G. SPREAD OF FIRE (PAGE 7) 0.9 NOT A FACTOR

H. PROTECTION FACILITIES (PAGE 8)

I. PROTECTION FACILITIES (PAGE 9)

J. MISCELLANEOUS (PAGE 10)

MISCELLANEOUS (PAGE 10)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL Date: Oct 1968 Time: 1010

INCIDENT NO.
A. 2. 7. C. 0

(X) Box / Name AAAZ () Unit Disp. / Co. No.

REPORTING OFFICE <u>10044</u>	REPORTING OFFICER <u>[Signature]</u>	ALARM SOURCE <input type="checkbox"/> TEL <input type="checkbox"/> WIRE <input type="checkbox"/> OTHER <input type="checkbox"/>
ADDRESS <u>3007 Jackson St</u>	CITY <u>San Francisco CA</u>	DATE <u>9 / 11 8</u>
REPORTING OFFICER	ADDRESS	TELEPHONE NO.

A. INFORMATION (PAGE 17)

FIRE REPORT NO. <u>38005</u>	INCIDENT NO. <u>03750</u>	EXPOSURE NO. <u>101</u>	TIME <u>1010</u>	MONTH <u>10</u>	DAY <u>11</u>	YEAR <u>1968</u>	CLASSIFICATION <u>101</u>	TYPE OF CASE <u>101</u>	DATE OF JURISDICTION <u>10/11/68</u>
---------------------------------	------------------------------	----------------------------	---------------------	--------------------	------------------	---------------------	------------------------------	----------------------------	---

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF DAMAGE	EXTENT OF DAMAGE
<u>1</u>	<u>1</u>	<u>1</u>
CODE	PROPERTY CLASSIFICATION (STRUCTURE)	
<u>4</u>	<u>1.1</u>	<u>dwelling</u>

C. PROPERTY TYPE (PAGE 19)

CODE	STRUCTURE TYPE	CONSTRUCTION TYPE
<u>1</u>	<u>Building Type</u>	<u>5</u>

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FIRE
<u>2</u>	<u>confined to area floor</u>
CODE	EXTENT OF DAMAGE - BURGLAR
<u>2</u>	<u>none</u>
CODE	EXTENT OF DAMAGE - OTHER
<u>2</u>	<u>none</u>
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
<u>0000</u>	<u>1500</u>

E. LOCATION & CAUSE (PAGE 48)

CODE	FLOOR OF ORIGIN
<u>1</u>	<u>2nd floor</u>
CODE	SOURCE OF HEAT CAUSING INCIDENT
<u>4</u>	<u>lamp bulb</u>
CODE	FORM OF HEAT CAUSING INCIDENT
<u>5</u>	<u>incandescent</u>
CODE	ACT OR OMISSION CAUSING INCIDENT
<u>8</u>	<u>earthquake</u>

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF ORIGIN
<u>1</u>	<u>living room</u>
CODE	TYPE OF MATERIAL FIRST NOTICED
<u>1</u>	<u>wood</u>
CODE	FORM OF MATERIAL FIRST NOTICED
<u>1</u>	<u>solid</u>
CODE	AREA AFFECTED SMOKE SPREAD
<u>1</u>	<u>ceiling</u>

G. SPREAD OF FIRE (PAGE 77)

CODE	AREA AFFECTED FIRE SPREAD
<u>1</u>	<u>none</u>
CODE	FORM OF MATERIAL CAUSING SPREAD
<u>1</u>	<u>wood</u>
CODE	FORM OF MATERIAL CAUSING SPREAD
<u>1</u>	<u>wood</u>
CODE	ACT OR OMISSION CAUSING SPREAD
<u>1</u>	<u>none</u>

H. PROTECTION FACILITIES (PAGE 81)

CODE	SPRINKLERS - TYPE
<u>1</u>	<u>none</u>
CODE	SPRINKLERS - EFFECTIVENESS
<u>1</u>	<u>none</u>
CODE	STAMPED - TYPE
<u>1</u>	<u>none</u>
CODE	STAMPED - EFFECTIVENESS
<u>1</u>	<u>none</u>
CODE	PORTABLE ESTABLISHMENTS - TYPE
<u>1</u>	<u>none</u>
CODE	PORTABLE ESTABLISHMENTS - EFFECTIVENESS
<u>1</u>	<u>none</u>

I. PROTECTION FACILITIES (PAGE 87)

CODE	PRIVATE FIRE ALARMS - TYPE
<u>1</u>	<u>none</u>
CODE	PRIVATE FIRE ALARMS - EFFECTIVENESS
<u>1</u>	<u>none</u>
CODE	SPECIAL HAZARD PROTECTION - TYPE
<u>1</u>	<u>none</u>
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS
<u>1</u>	<u>none</u>
CODE	SMOKE DETECTION SYSTEM - TYPE
<u>1</u>	<u>none</u>
CODE	SMOKE DETECTION SYSTEM - EFFECTIVENESS
<u>1</u>	<u>none</u>
CODE	SMOKE DETECTION SYSTEM - NAME OF ACTION
<u>1</u>	<u>none</u>
CODE	SMOKE DETECTION SYSTEM - TYPE DETECTORS
<u>1</u>	<u>none</u>

J. MISCELLANEOUS (PAGE 100)

NO. OF DEATHS	NO. OF INJURIES	NO. OF DEATHS	NO. OF INJURIES
<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>

Form 100-50-17 (7)
General information on this report is provided for the use of the State Fire Marshal, California Office of the State Fire Marshal.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL Date 10/16/89 Time 2048

0, 4, 1, 4, 7

() Box / No. / C.D. / (x) Unit Disp. / Co. No. E 3

Incident details form including: Incident Name (Cal Draughter), Relationship (Tenant/Manager), Address (1020 Larkin Street, Apt 106), City (San Francisco), ZIP (19, 4.1, 0.9), and Telephone No.

A. INFORMATION (PAGE 17)

Incident identification form with fields for Fire Dept ID (38005), Incident No (04147), Exposure No (2048), Time (1018), Day (10), Year (89), and other details.

B. PROPERTY CLASSIFICATION (PAGE 19)

Property classification form with entries: 1.1 Building fire, 4.2.2 Flats.

C. PROPERTY TYPE (PAGE 21)

Property type form with entry: 2 Building Type 5.

D. EXTENT OF DAMAGE (PAGE 45)

Extent of damage form with entries: 1 Confined to material first ignited, 2 Confined to area of origin, and estimated loss of property (.50) and contents (P).

E. LOCATION & CAUSE (PAGE 49)

Location and cause form with entries: 1 0, 21 second floor, 2 6 Barbeque, 4 7 open fire, 4 91 misuse of equipment.

F. AREA MATERIALS & FLAME SPREAD (PAGE 63)

Area materials and flame spread form with entries: 2 4 Kitchen, 5 6 briquettes, 7 6 charcoal.

G. SPREAD OF FIRE (PAGE 77)

Spread of fire form with fields for main spread, type material, form material, and act of spread.

H. PROTECTION FACILITIES (PAGE 89)

Protection facilities form with fields for sprinklers, standpipes, and portable extinguishers.

I. PROTECTION FACILITIES (PAGE 97)

Protection facilities form with fields for private sprinklers, smoke detectors, and alarm systems.

J. MISCELLANEOUS (PAGE 109)

Miscellaneous form with fields for fire department and other agency information.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/18/89 Time 2054

INCIDENT NO. 0
 DISTRICT 5
 UNIT 1

REPORT MADE BY: Yvonne Samers RELATIONSHIP: Lessee

ADDRESS: 1308 Larkin Street CITY: San Francisco ZIP: 10 21 00

PROPERTY CLASSIFICATION: 1 () Box / No. (X) Unit Disp. / Co. No. E 1

A. INFORMATION (PAGE 17)

PERMITS: 3 8 0 0 5 0 4 1 5 1 EXPENSES: 2 0 5 4 1 0 1 7 8 1 8 9 1 2 1 0 4

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE: 1 1 Building fire

CODE: 4 2 4 Flats

C. PROPERTY TYPE (PAGE 41)

CODE: 2 Building Type 5

D. EXTENT OF DAMAGE (PAGE 45)

CODE: 2 Confined to area of origin

ESTIMATED LOSS - PROPERTY: 12,000 ESTIMATED LOSS - CONTENTS: 13,000

E. LOCATION & CAUSE (PAGE 49)

CODE: 1 0 2 Second floor

CODE: 9 8 No equipment involved

CODE: 4 4 Candle

CODE: 4 6 Combustible to close to wall

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE: 2 5 Bedroom

CODE: 5 9 Candle

G. SPREAD OF FIRE (PAGE 71)

H. PROTECTION FACILITIES (PAGE 81)

CODE: 1 Sprinklers - Type

CODE: 1 Sprinklers - Effectiveness

CODE: 1 Standpipes - Type

CODE: 1 Standpipes - Effectiveness

CODE: 1 Portable extinguishers - Type

CODE: 1 Portable extinguishers - Effectiveness

I. PROTECTION FACILITIES (PAGE 87)

CODE: 1 Private garage - Type

CODE: 1 Private garage - Effectiveness

CODE: 1 Special alarm protection - Type

CODE: 1 Special alarm protection - Effectiveness

CODE: 1 Manual alarm system - Type

CODE: 1 Manual alarm system - Effectiveness

CODE: 1 Manual alarm system - Means of detection

CODE: 1 Manual alarm system - Type detection

J. MISCELLANEOUS (PAGE 109)

NO. OF DEATHS: 0 NO. OF INJURED: 0

NO. OF DEATHS: 0 NO. OF INJURED: 0

FIRE INCIDENT REPORT San Francisco Fire Department
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/18/89 Time 1637
 () Box / No. 3365 () Unit Disp. / Co. No.

REPORT MADE BY Ms Morgan	RELATIVITY Tenant	IN ALIAS ADDRESS	TOL	SPR	PROP	PROP
ADDRESS 5 Galileo	CITY SF	STATE	ZIP	TELEPHONE NO	TELEPHONE NO	TELEPHONE NO
ADDRESS	CITY	STATE	ZIP	TELEPHONE NO	TELEPHONE NO	TELEPHONE NO
ADDRESS	CITY	STATE	ZIP	TELEPHONE NO	TELEPHONE NO	TELEPHONE NO

A. INFORMATION (PAGE 17)

DATE OF LOSS 3 8 0 0 5 0	INCIDENT NO 0 3 9 8 9	EXPOSURE NO	TIME	SECTION	DAY	YEAR	DAY	MONTH	YEAR	DAY	MONTH	YEAR	DAY	MONTH	YEAR	DAY	MONTH	YEAR
-----------------------------	--------------------------	-------------	------	---------	-----	------	-----	-------	------	-----	-------	------	-----	-------	------	-----	-------	------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	INCIDENT DATE
1 1	Building Fire	
CODE	PROPERTY CLASSIFICATION (PROPERTY)	
4 2 3	Apartments 12 Units	

C. PROPERTY TYPE (PAGE 41)

CODE	PROPERTY TYPE	INCIDENT DATE
1	Building Type 5	
CODE	STRUCTURE TYPE	
1	Building Type 5	

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FIRE
1	Confined to material first ignited
CODE	EXTENT OF DAMAGE - SMOKE
1	
CODE	EXTENT OF DAMAGE - WATER
1	
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
0	0

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE
1 0 2	Second Floor
CODE	SOURCE OF HEAT (CAUSE)
2 1	Stove
CODE	FORM OF HEAT (CAUSE)
1 2	Gas Fueled
CODE	ACT OF DAMAGE (CAUSE)
7 3	Unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE	AREA OF SPREAD
2 4	Kitchen
CODE	TYPE OF MATERIAL FIRST IGNITED
5 7	Food
CODE	FORM OF MATERIAL FIRST IGNITED
7 6	Cooking Materials
CODE	MODE OF SMOKE SPREAD
0 7	Horizontal

G. SPREAD OF FIRE (PAGE 77)

CODE	MODE OF SMOKE SPREAD
1	
CODE	TYPE OF MATERIAL, LAUNCH SPREAD
1	
CODE	FORM OF MATERIAL, LAUNCH SPREAD
1	
CODE	ACT OF DAMAGE, LAUNCH SPREAD
1	

H. PROTECTION FACILITIES (PAGE 81)

CODE	SPRINKLER - TYPE
1	
CODE	SPRINKLER - EFFECTIVENESS
1	
CODE	STANDPIPE - TYPE
1	
CODE	STANDPIPE - EFFECTIVENESS
1	
CODE	PORTABLE ESTABLISHMENT - TYPE
1	
CODE	PORTABLE ESTABLISHMENT - EFFECTIVENESS
1	

I. PROTECTION FACILITIES (PAGE 87)

CODE	PORTABLE BRIGADE - TYPE
1	
CODE	PORTABLE BRIGADE - EFFECTIVENESS
1	
CODE	SPECIAL HAZARD PROTECTION - TYPE
1	
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS
1	
CODE	SMOKE OR HEAT DETECTOR
1	
CODE	SMOKE OR HEAT DETECTOR - EFFECTIVENESS
1	
CODE	SMOKE OR HEAT DETECTOR - TYPE
1	
CODE	SMOKE OR HEAT DETECTOR - EFFECTIVENESS
1	

J. MISCELLANEOUS (PAGE 109)

NO. OF PERSONS INJURED	NO. OF DEATHS	NO. OF PERSONS INJURED	NO. OF DEATHS
0	0	0	0
NO. OF PERSONS INJURED FOR LOSS OF EYE	NO. OF PERSONS INJURED FOR LOSS OF HEAR	NO. OF PERSONS INJURED FOR LOSS OF HEAR	NO. OF PERSONS INJURED FOR LOSS OF HEAR
0	0	0	0

FIRE INCIDENT REPORT San Francisco Fire Department
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 18 Oct 89 Time 17:01 INCIDENT NO 04002
 (X) Box / No. 1313 () Unit Disp. / Co. No.

REPORT MADE BY Rosita Young	RELATIONSHIP Tenant	PHONE NUMBER 	TELEPHONE NO.
ADDRESS 754 Grant	CITY San Francisco	ZIP 94108	TELEPHONE NO. 325-2281
OWNER NAME 	ADDRESS 	CITY 	ZIP
MANAGED NAME 	ADDRESS 	CITY 	ZIP

A. INFORMATION (PAGE 17)

FIRE DEPT. NO. 38005	INCIDENT NO. 04002	EXPOSURE NO. 1701	YEAR 1101818914	DATE 5.6.03	OUT OF JURISDICTION <input type="checkbox"/>
--------------------------------	------------------------------	-----------------------------	---------------------------	-----------------------	---

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1 1	TYPE OF INCIDENT building fire
CODE 5.4.4	PROPERTY CLASSIFICATION (PROPERTY)
CODE 5.4.4	PROPERTY CLASSIFICATION (INDIVIDUAL)
CODE 5.4.4	PROPERTY CLASSIFICATION (SHOP)

C. PROPERTY TYPE (PAGE 41)

CODE 1	BUILDING TYPE Building Type 5
CODE 3	STRUCTURE BUILDING OR VEHICLE - CONSTRUCTION CODE

D. EXTENT OF DAMAGE (PAGE 43)

CODE 1	EXTENT OF DAMAGE - TYPE confined to material first ignited
CODE 1	EXTENT OF DAMAGE - DAMAGE
CODE 1	EXTENT OF DAMAGE - WATER
ESTIMATED LOSS - PROPERTY 0.0	ESTIMATED LOSS - CONTENTS 0.0

E. LOCATION & CAUSE (PAGE 49)

CODE 2 0 1	LEVEL OF DAMAGE basement one floor
CODE 9 8	EQUIPMENT no equipment
CODE 4 4	FORM OF HEAT (LOADING POSITION) candle
CODE 7 3 1	ATTENTION CAUSING INCIDENT unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 43)

CODE 2 7	AREA OF DAMAGE office
CODE 7 2	TYPE OF MATERIAL FIRST IGGNITED cotton
CODE 3 4	FORM OF MATERIAL FIRST IGGNITED wearing not on person
CODE 0 A	OTHER VENTILE OPENINGS other venticle openings

G. SPREAD OF FIRE (PAGE 77)

CODE 0 9	SMOKE SPREAD TYPE SPREAD not a factor
CODE 	TYPE OF SPREAD (LOADING SPREAD)
CODE 	FORM MATERIAL CAUSING SPREAD
CODE 	ATTENTION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 81)

CODE 	SMOKE ALARMS - TYPE
CODE 	SMOKE ALARMS - EFFECTIVENESS
CODE 	SMOKE ALARMS - TYPE
CODE 	SMOKE ALARMS - EFFECTIVENESS
CODE 5	PORTABLE EXTINGUISHERS - TYPE for classes A,B,C
CODE 1	PORTABLE EXTINGUISHERS - EFFECTIVENESS not a factor in outcome

I. PROTECTION FACILITIES (PAGE 97)

CODE 	PRIVATE SPRINKLER - TYPE
CODE 	PRIVATE SPRINKLER - EFFECTIVENESS
CODE 	SMOKE EXHAUST PROTECTION - TYPE
CODE 	SMOKE EXHAUST PROTECTION - EFFECTIVENESS
CODE 	SMOKE EXHAUST SYSTEM - TYPE
CODE 	SMOKE EXHAUST SYSTEM - EFFECTIVENESS
CODE 	SMOKE EXHAUST SYSTEM - MEANS OF ACTIVATION
CODE 	SMOKE EXHAUST SYSTEM - TYPE DETECTORS
CODE 	SMOKE EXHAUST SYSTEM - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 109)

NO. OF DEATHS 	NO. OF INJURIES 	NO. OF DEATHS 	NO. OF INJURIES
OTHER COMMENTS: <input type="checkbox"/>			

SP-7 FORM 68-66 (7-79)

Written statements by the person or persons for the use of the State Fire Marshal. Estimates and descriptions made herein represent "facts only" and are not intended to be used as evidence in any court of law. The State Fire Marshal's Office is not responsible for the accuracy of information furnished hereon. It is the responsibility of the person or persons furnishing the information to make certain that it is accurate and complete.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL

Date 10/18/89 Time 17:57

0 4 0 2 7

Box / No. 7242 () Unit Disp. / Co. No.

Incident Name: Marcella Harvey, Address: 818-A 30th Ave., City: San Francisco, ZIP: 94114, Telephone: 221-1684

A. INFORMATION (PAGE 17)

3 8 0 0 5 | 0 4 0 2 7 | 1 7 5 7 | 1 0 1 8 | 8 9 | 0 8

B. PROPERTY CLASSIFICATION (PAGE 18)

1.1 Building fire, 4.2 Apartment house, 4.2.2 Apartment house 4-units

C. PROPERTY TYPE (PAGE 41)

2 Building Type C

D. EXTENT OF DAMAGE (PAGE 45)

1 Confined to material first ignited, 1 Confined to material first ignited, 1 Confined to material first ignited

E. LOCATION & CAUSE (PAGE 48)

1.0.2 Second floor, 2.1 Stove, 5.9 Heat from hot object, 7.3 Unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

2.4 Kitchen, 5.7 Food, 7.6 Cooking materials, 0.9 Not a factor

G. SPREAD OF FIRE (PAGE 77)

0.9 Not a factor

H. PROTECTION FACILITIES (PAGE 81)

Blank form for protection facilities

I. PROTECTION FACILITIES (PAGE 87)

Blank form for protection facilities

J. MISCELLANEOUS (PAGE 100)

Blank form for miscellaneous information

Blank form for miscellaneous information

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/18/80 Time 0437 INCIDENT NO. 03777
 () Box / No. 4362 () Unit Disp. / Co. No.

REPORT MADE BY Gretha Evans	RELATIONSHIP Tenant	PLANNED SOURCE <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
ADDRESS 1954 MC Allister	CITY S F	TELEPHONE NO.
REPORTED BY Bill Sfakiotakis	ADDRESS 11 Sagebuch San Rafael	TELEPHONE NO.

A. INFORMATION (PAGE 17)

DATE OF REPORT 3 8 0 0 5 0	INCIDENT NO. 3 7 7 7	REPORT NO. 0 9 4 3 1 1 0 1 1 8 1 8 0 1 5	TYPE OF INCIDENT 1 1	AREA OF INCIDENT 4 2 2	EXTENT OF DAMAGE 1	LOCATION & CAUSE 1 0 31 Third Floor	SPREAD OF FIRE 2 4	PROTECTION FACILITIES 5 7	MISCELLANEOUS 7 6
--------------------------------------	--------------------------------	--	--------------------------------	----------------------------------	------------------------------	---	------------------------------	-------------------------------------	-----------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

TYPE OF INCIDENT 1 1 Building fire
PROPERTY CLASSIFICATION - COMMENTS
PROPERTY CLASSIFICATION - COMMENTS
PROPERTY CLASSIFICATION - COMMENTS 4 2 2 Flats

C. PROPERTY TYPE (PAGE 18)

STRUCTURAL DIVISION OF PROPERTY - PROPERTY TYPE 1 Building Type c
STRUCTURE TYPE, MATERIALS OR FINISHES - COMMENTS (PAGE 19)

D. EXTENT OF DAMAGE (PAGE 43)

EXTENT OF DAMAGE - TYPE 1 Confined to material first ignited	
EXTENT OF DAMAGE - NUMBER 1	
EXTENT OF DAMAGE - NUMBER 1	
ESTIMATED LOSS - PROPERTY 0	ESTIMATED LOSS - CONTENTS 0

E. LOCATION & CAUSE (PAGE 49)

LEVEL OF DAMAGE 1 0 31 Third Floor
SOURCE OF HEAT CAUSING INCIDENT 2 1 Stove
FORM OF HEAT CAUSING INCIDENT 1 2 1 Gas Fueled
ACT OR OMISSION CAUSING INCIDENT 7 2 1 Unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

AREA OF SPREAD 2 4 Kitchen
TYPE OF MATERIAL FIRST IGGITED 5 7 Food
FORM OF MATERIAL FIRST IGGITED 7 6 Cooking Materials
MODE OF SPREAD & SMOKE SPREAD 0 7 Horizontal Openings

G. SPREAD OF FIRE (PAGE 77)

MODE SPREAD OF FIRE SPREAD
TYPE MATERIAL CAUSING SPREAD
FORM MATERIAL CAUSING SPREAD
ACT OR OMISSION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 87)

SMOKE ALARMS - TYPE
SMOKE ALARMS - EFFECTIVENESS
STANDPIPES - TYPE
STANDPIPES - EFFECTIVENESS
PORTABLE EXTINGUISHERS - TYPE
PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

SMOKE ALARMS - TYPE
SMOKE ALARMS - EFFECTIVENESS
SPECIAL ALARMS PROTECTION - TYPE
SPECIAL ALARMS PROTECTION - EFFECTIVENESS
SPRINKLER SYSTEMS - TYPE
SPRINKLER SYSTEMS - EFFECTIVENESS
STROBE WARNING SYSTEM - MEANS OF ACTIVATION
STROBE WARNING SYSTEM - TYPE DETECTION

J. MISCELLANEOUS (PAGE 109)

UNIDENTIFIED 	IDENTIFIED
NO OF DEATHS 	NO OF DEATHS
NO OF INJURIES 	NO OF INJURIES
NO OF PROPERTY DAMAGE 	NO OF PROPERTY DAMAGE

Form 100-100 (Rev. 1-75)
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
Date 10/12/89 Time 20:22

0.4.13.0

(X) Box / No. 1542 () Unit Disp. / Co. No.

Occupant name: JALLY LACEY
Address: 1040 BUSH ST #303 SAN FRANCISCO CA 94108
Telephone: 675.6768

A. INFORMATION (PAGE 17)
38005

B. PROPERTY CLASSIFICATION (PAGE 18)
1.1 Building
4.2.47 ADTS

C. PROPERTY TYPE (PAGE 19)
2. Building Type 3

D. EXTENT OF DAMAGE (PAGE 43)
2.1 CONFINED TO AREA
1.1 CONFINED TO MATERIAL
1.1 CONFINED TO MATERIAL

E. LOCATION & CAUSE (PAGE 49)
1.0.31 THIRD
9.8.1 No EQUIPMENT INVOLVED
4.4 CANDLE
7.3.1 UNATTENDED

F. AREA MATERIALS & SMOKE SPREAD (PAGE 51)
2.1.1 Sleeping Room
2.5.1 WINE
2.5.1 CHEST OF DRAWERS

G. SPREAD OF FIRE (PAGE 77)

H. PROTECTION FACILITIES (PAGE 81)
4.1 Dry
1.1 RING A FLOOR
2.1 ABC
4.1 EXTINGUISHED FIRE

I. PROTECTION FACILITIES (PAGE 81)
1.1 Lobe
2.1 Auto & Manual
7.1 SMOKE

J. MISCELLANEOUS (PAGE 100)
No. of persons injured: 0

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 18 Oct 80 Time 18:35 INCIDENT NO. 04046
 (x) Box / No. 1557 () Unit Disp. / Co. No.

REPORT MADE BY Greg Higgs	RELATIONSHIP Incident	INVESTIGATOR 10	DATE 19.4.100	TELEPHONE NO. 1030 Larkin
ADDRESS 1030 Larkin	CITY San Francisco	STATE CA	COUNTY San Francisco	ZIP 94109
REPORT MADE BY Arnie Gottlibb	RELATIONSHIP see above	INVESTIGATOR see above	DATE see above	TELEPHONE NO. see above

A. INFORMATION (PAGE 17)

TYPE DIST. NO. 38005	INCIDENT NO. 04046	EXPOSURE NO. 18	DATE 10/18/80	TIME 18:35	DAY MON	MONTH 10	YEAR 80	OUT OF JURISDICTION <input type="checkbox"/>
--------------------------------	------------------------------	---------------------------	-------------------------	----------------------	-------------------	--------------------	-------------------	---

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1	TYPE OF INCIDENT 1	DESCRIPTION building fire
CODE 4	PROPERTY CLASSIFICATION 2	DESCRIPTION apartment over 20 units

C. PROPERTY TYPE (PAGE 41)

CODE 1	PROPERTY TYPE Building Type	CODE 5	CONSTRUCTION TYPE 5
------------------	---------------------------------------	------------------	-------------------------------

D. EXTENT OF DAMAGE (PAGE 43)

CODE 2	EXTENT OF DAMAGE - FOL 1	DESCRIPTION confined to area of origin
CODE 2	EXTENT OF DAMAGE - BURN 1	DESCRIPTION no equipment
CODE 2	EXTENT OF DAMAGE - WATER 1	DESCRIPTION cigarette
ESTIMATED LOSS - PROPERTY 1,210.00	ESTIMATED LOSS - CONTENTS 310.00	

E. LOCATION & CAUSE (PAGE 49)

CODE 1	LEVEL OF ORIGIN 0.2	DESCRIPTION second floor
CODE 9	SOURCE OF HEAT 8	DESCRIPTION no equipment
CODE 3	FORM OF HEAT CAUSING INCIDENT 1	DESCRIPTION cigarette
CODE 3	ACT OR CONDITION EMPLOYED 1	DESCRIPTION unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE 2	AREA OF ORIGIN 1	DESCRIPTION bedroom
CODE 5	TYPE OF MATERIAL FIRST IDENTIFIED 7	DESCRIPTION paper
CODE 7	FORM OF MATERIAL FIRST IDENTIFIED 5	DESCRIPTION rubbish
CODE 9	WIND DIRECTION CAUSING SPREAD 1	DESCRIPTION was a factor

G. SPREAD OF FIRE (PAGE 77)

CODE 0	WIND DIRECTION CAUSING SPREAD 0	DESCRIPTION not a factor
CODE 0	TYPE OF SPREAD 0	DESCRIPTION not a factor
CODE 0	FORM OF SPREAD 0	DESCRIPTION not a factor
CODE 0	ACT OR CONDITION CAUSING SPREAD 0	DESCRIPTION not a factor

H. PROTECTION FACILITIES (PAGE 87)

CODE 1	STANDARD - TYPE 1	DESCRIPTION not a factor
CODE 1	STANDARD - EFFECTIVENESS 1	DESCRIPTION not a factor
CODE 4	STANDARD - TYPE 1	DESCRIPTION dry
CODE 4	STANDARD - EFFECTIVENESS 1	DESCRIPTION not a factor
CODE 5	STANDARD ESTABLISHED - TYPE 1	DESCRIPTION for classes A B C
CODE 5	STANDARD ESTABLISHED - EFFECTIVENESS 1	DESCRIPTION was a factor

I. PROTECTION FACILITIES (PAGE 97)

CODE 1	STANDARD - TYPE 1	DESCRIPTION not a factor
CODE 1	STANDARD - EFFECTIVENESS 1	DESCRIPTION not a factor
CODE 1	SPECIAL - TYPE 1	DESCRIPTION not a factor
CODE 1	SPECIAL - EFFECTIVENESS 1	DESCRIPTION not a factor
CODE 1	SMOKE OR HEAT DETECTION SYSTEM - TYPE 1	DESCRIPTION not a factor
CODE 1	SMOKE OR HEAT DETECTION SYSTEM - EFFECTIVENESS 1	DESCRIPTION not a factor
CODE 1	SMOKE OR HEAT DETECTION SYSTEM - TYPE 1	DESCRIPTION not a factor
CODE 1	SMOKE OR HEAT DETECTION SYSTEM - EFFECTIVENESS 1	DESCRIPTION not a factor

J. MISCELLANEOUS (PAGE 109)

NO. OF DEATHS 0	NO. OF INJURIES 0	NO. OF DEATHS 0	NO. OF INJURIES 0
SPECIAL COMMENTS (SEE PAGE 109) <input type="checkbox"/>			

FIRE INCIDENT REPORT San Francisco Fire Department
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 10/18/89 Time 13:06

0 3 8 6 2

() Box / No. (X) Unit Disp. / Co. No. E 34

REPORT MADE AT Curia's Bath	REPORT MADE BY Tenant	REPORT MADE ON 300 16TH Ave Apt. 402	REPORT MADE IN San Francisco	REPORT MADE ON Mr. Woo	REPORT MADE BY Mrs. Wilson
ADDRESS 300 16TH Ave Apt. 402	CITY San Francisco	STATE CA	ZIP 94101	TELEPHONE NO. 301-5853	
REPORT MADE ON Mr. Woo	REPORT MADE BY Mrs. Wilson	REPORT MADE AT Same Apt. 102	REPORT MADE IN San Francisco	REPORT MADE ON Mr. Woo	REPORT MADE BY Mrs. Wilson

A. INFORMATION (PAGE 17)

INCIDENT NO. 3800503862	DATE 10/18/89	TIME 13:06	REPORT MADE BY 10118189	REPORT MADE AT 07	REPORT MADE IN 07	REPORT MADE ON 07	REPORT MADE BY 07	REPORT MADE AT 07	REPORT MADE IN 07	REPORT MADE ON 07
-----------------------------------	-------------------------	----------------------	-----------------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1 1 Building Fire	PROPERTY CLASSIFICATION 1
CODE 4 2 3 Apartments	PROPERTY CLASSIFICATION 4

C. PROPERTY TYPE (PAGE 41)

CODE 2 Building Type 5	PROPERTY TYPE 0 0 0
------------------------------------	-------------------------------

D. EXTENT OF DAMAGE (PAGE 43)

CODE 1 Confined to material first ignited	EXTENT OF DAMAGE 1
CODE 0 0 Estimated Loss - Property	ESTIMATED LOSS - PROPERTY 0.0
CODE 0 0 Estimated Loss - Contents	ESTIMATED LOSS - CONTENTS 50

E. LOCATION & CAUSE (PAGE 49)

CODE 1 0 4 Fourth floor	LOCATION & CAUSE 1 0 4
CODE 2 1 Stove	LOCATION & CAUSE 2 1
CODE 5 7 Improperly op. elec. heat equip.	LOCATION & CAUSE 5 7
CODE 4 6 Combustible to close	LOCATION & CAUSE 4 6

F. AREA MATERIALS & SMOKE SPREAD (PAGE 51)

CODE 2 4 Kitchen	AREA MATERIALS & SMOKE SPREAD 2 4
CODE 2 9 Wine vinegar	AREA MATERIALS & SMOKE SPREAD 2 9
CODE 9 9 Not Classified	AREA MATERIALS & SMOKE SPREAD 9 9
CODE 0 9 Not a factor	AREA MATERIALS & SMOKE SPREAD 0 9

G. SPREAD OF FIRE (PAGE 71)

CODE 1	SPREAD OF FIRE 1
CODE 1	SPREAD OF FIRE 1
CODE 1	SPREAD OF FIRE 1
CODE 1	SPREAD OF FIRE 1

H. PROTECTION FACILITIES (PAGE 81)

CODE 5 Combination	PROTECTION FACILITIES 5
CODE 1 Not a factor	PROTECTION FACILITIES 1
CODE 4 Dry	PROTECTION FACILITIES 4
CODE 1 Not a factor	PROTECTION FACILITIES 1
CODE 2 B & C	PROTECTION FACILITIES 2
CODE 4 Ext. fire	PROTECTION FACILITIES 4

I. PROTECTION FACILITIES (PAGE 81)

CODE 1	PROTECTION FACILITIES 1
CODE 1	PROTECTION FACILITIES 1
CODE 1	PROTECTION FACILITIES 1
CODE 1	PROTECTION FACILITIES 1
CODE 1 Local	PROTECTION FACILITIES 1
CODE 2 Auto & Manual	PROTECTION FACILITIES 2
CODE 2 Smoke	PROTECTION FACILITIES 2

J. MISCELLANEOUS (PAGE 109)

NO. REPORTED 1	NO. OF STATES 1	NO. REPORTED 1	NO. OF STATES 1
--------------------------	---------------------------	--------------------------	---------------------------

Form designed to standardize and streamline the collection of the same fire incident information and distribution of this information to the State Fire Marshal, Office of the State Fire Marshal, and the State Fire Marshal's Office. It is not intended to be used as a substitute for the State Fire Marshal's Office. It is not intended to be used as a substitute for the State Fire Marshal's Office.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL Date 10/18/89 Time app. 11:30

INCIDENT NO
0.0.0.0.0.0

Box / No 7332 () Unit Disp. / Co. No. _____

1 OCCUPANT NAME Mrs. Harris	RELATIONSHIP Tenant	PHONE SOURCE TEL. NO. <input type="checkbox"/> FAX <input type="checkbox"/> TELETYPE <input type="checkbox"/> OTHER <input type="checkbox"/>
2 ADDRESS 1256-6th Ave.	CITY San Francisco	ZIP 19.4. 1 22
3 STREET NAME	CITY	ZIP
4 MANAGER NAME	CITY	ZIP

A. INFORMATION (PAGE 17)

LINE SECT. NO 3 8 0 0 5	INCIDENT NO 0 0 0 0 0 0	EXPOSURE NO 1 1 3	TYPE 0 1 0	DAY 1 8	YEAR 8 9	CONTR. DIST. 3 7 0 0 5	OUT OF JURISDICTION <input type="checkbox"/>
-----------------------------------	-----------------------------------	-----------------------------	----------------------	-------------------	--------------------	----------------------------------	---

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE 1.1	TYPE OF INCIDENT Building fire
CODE 4.2	PROPERTY CLASSIFICATION Apartment house
CODE 4.1.4	PROPERTY CLASSIFICATION 2 unit apartment house

C. PROPERTY TYPE (PAGE 41)

CODE 2	STRUCTURE BUILDING OR VEHICLE Building Type 5
CODE 5	STRUCTURE BUILDING OR VEHICLE - CONSTRUCTION TYPE Heat from hot object

D. EXTENT OF DAMAGE (PAGE 43)

CODE 1	EXTENT OF DAMAGE - FIRE Confined to material first ignited
CODE 1	EXTENT OF DAMAGE - FIRE Confined to material first ignited
CODE 1	EXTENT OF DAMAGE - WATER Confined to material first ignited
ESTIMATED LOSS - PROPERTY 0	ESTIMATED LOSS - CONTENTS 0

E. LOCATION & CAUSE (PAGE 49)

CODE 1 0 2	LEVEL OF DAMAGE Second floor
CODE 2 1	SOURCE OF HEAT Stove
CODE 5 9	FORM OF HEAT CAUSING INCIDENT Heat from hot object
CODE 7.3	ACT OR OMISSION CAUSING INCIDENT Unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE 2 4	AREA OF ORIGIN Kitchen
CODE 6 7	TYPE OF MATERIAL FIRST IGNITED Paper
CODE 7 5	FORM OF MATERIAL FIRST IGNITED Trash
CODE 0 9	REASON FOR SPREAD Not a factor

G. SPREAD OF FIRE (PAGE 77)

CODE	REASON FOR SPREAD
CODE	TYPE MATERIAL CAUSING SPREAD
CODE	FORM MATERIAL CAUSING SPREAD
CODE	ACT OR OMISSION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 81)

CODE	SPRINKLERS - TYPE
CODE	SPRINKLERS - EFFECTIVENESS
CODE	STANDPIPES - TYPE
CODE	STANDPIPES - EFFECTIVENESS
CODE	PORTABLE ESTABLISHMENTS - TYPE
CODE	PORTABLE ESTABLISHMENTS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

CODE	PRIVATE SPRINKLER - TYPE
CODE	PRIVATE SPRINKLER - EFFECTIVENESS
CODE	SPECIAL HAZARD PROTECTION - TYPE
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS
CODE	SMALL BUSINESS SYSTEM - TYPE
CODE	SMALL BUSINESS SYSTEM - EFFECTIVENESS
CODE	SIGNAL WARRING SYSTEM - METHOD OF ACTIVATION
CODE	SIGNAL WARRING SYSTEM - TYPE
CODE	OTHER FIRE LITING

J. MISCELLANEOUS (PAGE 109)

NO. OF PHOTOGRAPHS	NO. OF DRAWINGS	NO. OF MAPS	NO. OF OTHERS
NO.	NO.	NO.	NO.
IF YOU HAVE ANY SUBMITTED FOR EACH DATE (CHECK ONE IF YES) <input type="checkbox"/>			

Fire insurance policy... State of California... Office of the State Fire Marshal

HILL INSURERS REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL Date 10/18/89 Time 0917

INCIDENT NO 316712

() Box / No. (X) Unit Disp. / Co. No. 72175

Table with columns: OCCUPANT NAME, RELATIONSHIP, ADDRESS, CITY, ZIP, TELEPHONE NO. Includes Sacred Grounds Restaurant and Valerie Hararah.

A INFORMATION (PAGE 17)

Table with columns: POLICY NO, EXPOSURE NO, TIME, MONTH, YEAR, DAY, LOSS IN AMT, LOSS IN COST, LOSS IN VALUE. Includes values like 38005, 3.6.7.7, 0.8.7.7/10, 1.8/18, 9102.

B PROPERTY CLASSIFICATION (PAGE 18)

Table with columns: CODE, DESCRIPTION. Includes 1.11 building fire, 4.01 restaurant, 1.6.11 restaurant.

C PROPERTY TYPE (PAGE 19)

Table with columns: CODE, DESCRIPTION. Includes 1 Building Type.

D EXTENT OF DAMAGE (PAGE 45)

Table with columns: CODE, EXTENT OF DAMAGE. Includes 2 CTACO, 2 CTACD, 2 CTACD.

E LOCATION & CAUSE (PAGE 49)

Table with columns: CODE, LOCATION & CAUSE. Includes 1.01 11 ground floor, 2 11 hot plate, 5 11 hot object, 4.61 combustible too close.

F AREA MATERIALS & SMOKE SPREAD (PAGE 63)

Table with columns: CODE, DESCRIPTION. Includes 2.41 cooking area, 6.31 wood shelf, 7.61 cooking utensils, 0.9 not a factor.

G SPREAD OF FIRE (PAGE 77)

Table with columns: CODE, DESCRIPTION. Includes 0 0 1 not a factor, 0 8 1 not applicable, 2 3 1 cabinet, 7.3 1 unattended.

H PROTECTION FACILITIES (PAGE 81)

Table with columns: CODE, DESCRIPTION. Includes 4 extinguished fire.

I PROTECTION FACILITIES (PAGE 81)

Table with columns: CODE, DESCRIPTION. Includes 0 0 1 not a factor, 0 8 1 not applicable, 2 3 1 cabinet, 7.3 1 unattended.

J MISCELLANEOUS (PAGE 104)

Table with columns: CODE, DESCRIPTION. Includes 4 extinguished fire.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/18/89 Time 0130 0.0.0.6.9
 (X) Box / No. 5512 () Unit Disp. / Co. No.

Occupant name Floris Roldan	Relationship tenant	Address 1138 Valencia	City S F	State CA	Zip 94117	Telephone no. 282 0537
Owner name Hogan & Vest Realty	Address 949 Stockton ST	City SF	State CA	Zip 94107	Telephone no. 421 5117	

A. INFORMATION (PAGE 17)

FD No. 3800500069	Incident No. 01301018	Time 89	Day 10	Month 18	Year 89	City SF	State CA	Zip 94117
--------------------------	------------------------------	----------------	---------------	-----------------	----------------	----------------	-----------------	------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

Code 1.1 Building Fire
Code 4.2.3 12 Units

C. PROPERTY TYPE (PAGE 41)

Code 1 Building Type 5

D. EXTENT OF DAMAGE (PAGE 45)

Code 4 Confined to building	
Code 4	
Code 4	
Estimated loss - contents 2510.00	Estimated loss - structure 710.00

E. LOCATION & CAUSE (PAGE 49)

Code 1.0.2 second floor
Code 2.3 Coffee pot (elect)
Code 5.6 properly operating electrical
Code 7.3 Unattended

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

Code 2.3 Dining room
Code 5.1 Rubber insulation
Code 6.1 electrical insulation
Code 0.4 vertical openings

G. SPREAD OF FIRE (PAGE 77)

Code 0.4 vertical openings
Code 6.3 finished lumber
Code 1.5 interior wall covering
Code 7.3 unattended

H. PROTECTION FACILITIES (PAGE 91)

Code 1
Code 1
Code 1
Code 1
Code 1
Code 1

I. PROTECTION FACILITIES (PAGE 97)

Code 1
Code 1
Code 1
Code 1
Code 1
Code 1

J. MISCELLANEOUS (PAGE 109)

Code 1	Code 1	Code 1	Code 1
Code 1	Code 1	Code 1	Code 1

K. MISCELLANEOUS (PAGE 115)

Code 1	Code 1	Code 1	Code 1
Code 1	Code 1	Code 1	Code 1

Entries contained in this report are intended for use only by the State Fire Marshal, Department of Industrial Relations and the State Fire Marshal's Office of the State Fire Marshal.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL Date 10/19/89 Time 0442

INCIDENT NO
I 4.2.6..9

Box / No. 5000 Unit Disp. / Co. No. E11

DECLARANT NAME Salvation Army	RELATIONSHIP	DATE	TIME
ADDRESS 1500 Valencia	CITY S.F.	ZIP	TELEPHONE NO
OWNER NAME	ADDRESS	CITY	ZIP
MANAGER NAME	ADDRESS	CITY	ZIP

A. INFORMATION (PAGE 7)

POLICE NO <u>3 8 0 0 5</u>	INCIDENT NO <u>4 2 6 9</u>	REPORTING NO <u>0 4 4 2 1 1 0 1 1 9 1 8 9 1 5</u>	CITY <u>S F</u>	STATE <u>CA</u>	ZIP <u>9 4 1 0 6</u>
-------------------------------	-------------------------------	--	--------------------	--------------------	-------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	LOSS DATE
<u>1</u>	<u>11 Building fire</u>	
CODE	PROPERTY CLASSIFICATION	
<u>4</u>		
CODE	PROPERTY CLASSIFICATION	
<u>5.7</u>	<u>71 Furniture repair</u>	

C. PROPERTY TYPE (PAGE 41)

CODE	STRUCTURE	TYPE
<u>1</u>	<u>Building</u>	<u>Type 3</u>

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - TYPE
<u>21</u>	<u>Confined to area</u>
CODE	EXTENT OF DAMAGE - SOURCE
<u>31</u>	<u>Confined to floor</u>
CODE	EXTENT OF DAMAGE - SCOPE
<u>41</u>	<u>Confined to building</u>
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
<u>500.00</u>	<u>500.00</u>

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE
<u>1.0.21</u>	<u>Second floor</u>
CODE	SOURCE OF HEAT CAUSING INCIDENT
<u>9.81</u>	<u>No equip involved</u>
CODE	FORM OF HEAT CAUSING INCIDENT
<u>7.71</u>	<u>Spontaneous ignition</u>
CODE	ACT OR OMISSION CAUSING INCIDENT
<u>4.71</u>	<u>Improper storage</u>

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF ORIGIN
<u>6.51</u>	<u>Shop area</u>
CODE	TYPE OF MATERIAL FIRST IDENTIFIED
<u>8.51</u>	<u>Oily rags</u>
CODE	FORM OF MATERIAL FIRST IDENTIFIED
<u>5.81</u>	<u>Cleaning cloths</u>
CODE	SMOKE SPREAD
<u>0.91</u>	<u>Not a factor</u>

G. SPREAD OF FIRE (PAGE 77)

CODE	SMOKE SPREAD
CODE	TYPE OF SPREAD
CODE	FORM OF SPREAD
CODE	ACT OR OMISSION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 81)

CODE	APPROVALS - TYPE
<u>1</u>	
CODE	APPROVALS - EFFECTIVENESS
<u>1</u>	
CODE	STANDARD - TYPE
<u>1</u>	
CODE	STANDARD - EFFECTIVENESS
<u>1</u>	
CODE	PORTABLE EXTINGUISHERS - TYPE
<u>1</u>	
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS
<u>1</u>	

I. PROTECTION FACILITIES (PAGE 87)

CODE	SMOKE SHUTTERS - TYPE
<u>1</u>	
CODE	SMOKE SHUTTERS - EFFECTIVENESS
<u>1</u>	
CODE	SMOKE SHUTTERS PROTECTION - TYPE
<u>1</u>	
CODE	SMOKE SHUTTERS PROTECTION - EFFECTIVENESS
<u>1</u>	
CODE	SMOKE SHUTTERS SYSTEM - TYPE
<u>1</u>	
CODE	SMOKE SHUTTERS SYSTEM - EFFECTIVENESS
<u>1</u>	

J. MISCELLANEOUS (PAGE 109)

NO. OF REPORTS	NO. OF STATES	NO. OF REPORTS	NO. OF STATES
<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>

Forms contained in this report are prepared for the sole use of the State Fire Marshal. (Information and instructions should be furnished "Public Inquiry" and "Public Release" laws and effect. Any reproduction or use in the absence of authority of the State Fire Marshal's Office, or without approval and consent.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

STATE OF CALIFORNIA OFFICE OF THE STATE FIRE MARSHAL

Date 10/19/89 Time 1313

INCIDENT NO. 7-4-4-R-7

() Box / No. 1243 () Unit Disp. / Co. No.

Incident details form including Incident Name (Burger King), Address (346 Kearny St), City (San Francisco), and Incident Number (94115).

A. INFORMATION (PAGE 17)

Fire Department information including Dispatch No (38005), Incident No (4483), and Date/Time (10/19/89 1313).

B. PROPERTY CLASSIFICATION (PAGE 18)

Property classification details including Code 1.1 Building fire and Code 1.6 Restaurant.

C. PROPERTY TYPE (PAGE 47)

Property type details including Code 7 Building Type.

D. EXTENT OF DAMAGE (PAGE 45)

Extent of damage details including Code 1.1 Confined to material and estimated loss of \$10,000.

E. LOCATION & CAUSE (PAGE 49)

Location and cause details including Code 1.0.3 Ground floor and Code 7.4 Fryer.

F. AREA MATERIALS & SOURCE SPREAD (PAGE 52)

Area materials and source spread details including Code 2.4 Kitchen, Code 2.7 Grease, and Code 2.5 Cooking material.

G. SPREAD OF FIRE (PAGE 71)

Spread of fire details including Code 1.0.3 Ground floor and Code 7.4 Fryer.

H. PROTECTION FACILITIES (PAGE 57)

Protection facilities details including Code 1 Standpipes - Type and Code 1 Portable extinguishers - Type.

I. PROTECTION FACILITIES (PAGE 57)

Protection facilities details including Code 1 Standpipes - Effectiveness and Code 1 Special hazard protection - Effectiveness.

J. MISCELLANEOUS (PAGE 100)

Miscellaneous details including checkboxes for "NO DAMAGE" and "DAMAGE".

Miscellaneous details including checkboxes for "DAMAGE" and "NO DAMAGE".

FIRE INCIDENT REPORT San Francisco Fire Department
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/19/89 Time 0719 INCIDENT NO I.4.3.0.5
 () Box / No. 1336 () Unit Disp. / Co. No.

DECLARANT NAME	RELATIONSHIP	GRADE	TOL	OFF	MAIL
ADDRESS	CITY	STATE	ZIP	TELEPHONE OR MAILING CODE	
1050 Stockton St	San Francisco	CA	94104		
DAMAGED NAME	ADDRESS	CITY	STATE	ZIP	TELEPHONE NO
Al Tiqueria	1056 Stockton St	San Francisco	CA	94104	

A. INFORMATION (PAGE 17)

FIRE DEPT NO	INCIDENT NO	REPORTING NO	TIME	ADDRESS	CITY	STATE	ZIP	COUNTY	ZIP	DATE OF INCIDENT	DATE OF REPORT
38005	I.4.3.0.5		07	1911	Q1918	915		0	0		

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	EXTERIOR DAMAGE
1.11	Building fire	
CODE	PROPERTY CLASSIFICATION (PROPERTY CLASS)	
4.2.21	Flats	

C. PROPERTY TYPE (PAGE 21)

CODE	STRUCTURE	BUILDING OR PEOPLE'S TYPE	EXTERIOR DAMAGE
2	Building Type 5		3

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FIRE
4.1	Confined to building
CODE	EXTENT OF DAMAGE - SMOKE
4.1	Confined to building
CODE	EXTENT OF DAMAGE - WATER
4.1	Confined to building
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
3510.00	510.00

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE
1.0.11	Basement
CODE	SOURCE OF HEAT (CAUSE) (LOCATION)
1.2.1	Water heater
CODE	FORM OF HEAT (CAUSE) (LOCATION)
5.9	Water heater
CODE	ACT OF DAMAGE (CAUSE) (LOCATION)
4.6	Combustible roof clng

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF DAMAGE
9.81	Basement
CODE	TYPE OF MATERIAL, FIRST LISTED
6.71	Paper
CODE	FORM OF MATERIAL, FIRST LISTED
7.51	Trash
CODE	SMOKE SPREAD & SMOKE SPREAD

G. SPREAD OF FIRE (PAGE 77)

CODE	SMOKE SPREAD & SMOKE SPREAD
CODE	FORM MATERIAL, CAUSING SPREAD
CODE	ACT OF DAMAGE (CAUSE) (LOCATION)

H. PROTECTION FACILITIES (PAGE 81)

CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS
CODE	SMOKELESS - TYPE
CODE	SMOKELESS - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 100)

NO. REPORTED	NO. OF DAMAGED	NO. REPORTED	NO. OF DAMAGED

Errors contained in this report are corrected for the use of the State Fire Marshal, California and should not be used for any other purpose. This report is the property of the State Fire Marshal and should be returned to the State Fire Marshal's Office, in person or by mail, if it is not returned to the office.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 19 Oct 89 Time 00:33

INCIDENT NO. 0.4.2.2.1

(x) Box / No. 2158 () Unit Disp. / Co. No.

REPORT MADE BY Copy Rice	RELATIONSHIP tenant	ALARM SOUND <input checked="" type="checkbox"/> NO <input type="checkbox"/>	TELEPHONE NO. TELEPHONE NO. (AREA)
ADDRESS 74 New Montgomery St	CITY San Francisco	ZIP 104.1.05	TELEPHONE NO. (AREA)
REPORT MADE BY	ADDRESS	CITY	ZIP
REPORT MADE BY	ADDRESS	CITY	ZIP

A. INFORMATION (PAGE 17)

FILE NO. 38005	INCIDENT NO. 04221	EPISODE NO.	TIME	DATE	YEAR	MONTH	DAY	QUARTER	DAY	OUT OF JURISDICTION
			0.0.3.3	11	10	10	19	0	15	0

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	EXTENT OF DAMAGE
1 1	building fire	
5 9 .5 1	photocopy firm	

C. PROPERTY TYPE (PAGE 41)

CODE	STRUCTURE	TYPE	USE
1	Building Type 1		

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FLOOR
3 1	confined to floor of origin
CODE	EXTENT OF DAMAGE - ROOMS
3 1	
CODE	EXTENT OF DAMAGE - OTHER
3 1	
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
11.5.010.0.0	1.5.010.0.0

E. LOCATION & CAUSE (PAGE 48)

CODE	LOCATION OF CAUSE
1 0 1 1	ground floor
CODE	SOURCE OF HEAT CAUSING INCIDENT
4 1 1	fixed wiring
CODE	FORM OF HEAT CAUSING INCIDENT
2 2	short circuit
CODE	ACT OF OR BY WHOM CAUSING INCIDENT
8 2 1	earthquake

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE	AREA OF ORIGIN
4 1	storage area
CODE	TYPE OF MATERIAL FIRST IDENTIFIED
6 7	paper
CODE	FORM OF MATERIAL FIRST IDENTIFIED
5 1	stack boxes
CODE	FORM OF MATERIAL SECOND IDENTIFIED
0 7	hardware

G. SPREAD OF FIRE (PAGE 77)

CODE	HOW SPREAD TO OTHER AREAS
0 9	not a factor
CODE	TYPE OF SPREAD CAUSING SPREAD
CODE	FORM OF SPREAD CAUSING SPREAD
CODE	ACT OF OR BY WHOM CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 91)

CODE	SPRINKLERS - TYPE
1	
CODE	SPRINKLERS - EFFECTIVENESS
1	
CODE	STANDPIPS - TYPE
1 1	dry
CODE	STANDPIPS - EFFECTIVENESS
1	not a factor
CODE	PORTABLE EXTINGUISHERS - TYPE
5 1	for classes A,B,C
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS
1	not a factor

I. PROTECTION FACILITIES (PAGE 97)

CODE	FORMS OF PROTECTION - TYPE
CODE	FORMS OF PROTECTION - EFFECTIVENESS
CODE	SPECIAL ALARM PROTECTION - TYPE
CODE	SPECIAL ALARM PROTECTION - EFFECTIVENESS
CODE	SMOKE OR SMOKE SYSTEM
1 1	local
CODE	SMOKE OR SMOKE SYSTEM - FORM OF DETECTION
2	auto/manual
CODE	SMOKE OR SMOKE SYSTEM - TYPE DETECTOR
2 1	smoke

J. MISCELLANEOUS (PAGE 108)

NO. INVOICED	NO. OF STATES	NO. IMPACT	NO. OF STATES
NEW FORMS ADDED	REMOVED	ADDED	REMOVED

Continued description of structure and contents of the fire and one of the same fire department, (structure and contents) must report appropriate "cause" and "origin" information to the authority of origin of reported structure. (State Fire Marshal's Office, or County Fire Marshal's Office, or other authority as appropriate)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

Date 19 Oct 89 Time 12:02 0.4.4.3.8

(K) Box / No. 2252 () Unit Disp. / Co. No.

Occupant Name Anglo Hotel	RELATIONSHIP	ALLOWED TO ENTER	NO. <input checked="" type="checkbox"/>	OFFICER	NO. <input type="checkbox"/>	OFFICER	NO. <input type="checkbox"/>
ADDRESS 241 6th.	ROOM / APT. NO. 731	CITY San Francisco	ST. 1	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.
Occupant Name Nick Patel	ADDRESS 241 6th. Street	CITY S.F.	ST. 1	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.	TELEPHONE NO.

A. INFORMATION (PAGE 17)

TYPE OF FIRE	INCIDENT NO.	APPROX. AGE	TIME	REPORT NO.	DATE	YEAR	DAY	MONTH	DAY	MONTH	YEAR	OUT OF JURISDICTION
3 8 0 0 5	0.4.4.3.8			1 2 0 2 1 0 1 1 0 1 8 0 1 0 6 2 1 0 3								<input type="checkbox"/>

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	GROUP 1	GROUP 2
1 1	Building Fire	<input type="checkbox"/>	<input checked="" type="checkbox"/>
CODE	PROPERTY CLASSIFICATION - INDUSTRIAL		
4.4.11	Hotel, wear round		

C. PROPERTY TYPE (PAGE 18)

CODE	PROPERTY TYPE	GROUP 1	GROUP 2
1	Building Type 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>
CODE	STRUCTURE TYPE		
10.0.8			

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FIRE		
1 1	Confined to material fires ignited		
CODE	EXTENT OF DAMAGE - SMOKE		
1 1			
CODE	EXTENT OF DAMAGE - WATER		
1 1			
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS		
0	5.0		

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF DAMAGE		
1 0.2 1	2nd floor Rm # 731		
CODE	SOURCE OF HEAT		
4 6	light fixture electric lamp		
CODE	FORM OF HEAT		
2.3 1	Short circuit defective		
CODE	ACT OF DAMAGE		
3. 1 1	Abandoned		

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE	AREA OF SMOKE		
2. 1 1	Sleeping area		
CODE	TYPE OF MATERIAL FIRST IGNITED		
7. 2 1	Mattress		
CODE	FORM OF MATERIAL FIRST IGNITED		
3. 1 1	Mattress		
CODE	AREA OF SMOKE SPREAD		
0. 4 1	Vertical Opening		

G. SPREAD OF FIRE (PAGE 77)

CODE	FORM OF SMOKE SPREAD		
CODE	TYPE MATERIAL CAUSING SPREAD		
CODE	FORM MATERIAL CAUSING SPREAD		
CODE	ACT OF SMOKE CAUSING SPREAD		

H. PROTECTION FACILITIES (PAGE 87)

CODE	APPROVED - TYPE		
1			
CODE	APPROVED - EFFECTIVENESS		
1			
CODE	STAMPED - TYPE		
1			
CODE	STAMPED - EFFECTIVENESS		
1			
CODE	PORTABLE ESTABLISHMENT - TYPE		
5	For Classes A,B,C fires		
CODE	PORTABLE ESTABLISHMENT - EFFECTIVENESS		
1	Not a factor		

I. PROTECTION FACILITIES (PAGE 97)

CODE	PRIVATE SMOKE - TYPE		
1			
CODE	PRIVATE SMOKE - EFFECTIVENESS		
1			
CODE	SPECIAL SMOKE PROTECTION - TYPE		
1			
CODE	SPECIAL SMOKE PROTECTION - EFFECTIVENESS		
1			
CODE	SMOKE DETECTION SYSTEM - TYPE		
1			
CODE	SMOKE DETECTION SYSTEM - EFFECTIVENESS		
1			
CODE	SMOKE DETECTION SYSTEM - TYPE OF DETECTION		
1			
CODE	SMOKE DETECTION SYSTEM - TYPE OF DETECTION		
1			

J. MISCELLANEOUS (PAGE 109)

NO. OF DEATHS	NO. OF DEATHS	NO. OF DEATHS	NO. OF DEATHS
0	0	0	0
NO. OF INJURIES	NO. OF INJURIES	NO. OF INJURIES	NO. OF INJURIES
0	0	0	0
NO. OF PROPERTY DAMAGE	NO. OF PROPERTY DAMAGE	NO. OF PROPERTY DAMAGE	NO. OF PROPERTY DAMAGE
0	0	0	0

CODE	WATERMOUNT	CODE	OTHER FACILITIES
1		1	
CODE	EFFECTIVENESS	CODE	EFFECTIVENESS
1		1	

FIRE INCIDENT REPORT **SAN FRANCISCO FIRE DEPARTMENT**
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/19/85 Time 1415 0.4.0.0

EXEMPT FROM THE REPORT AND RECORDING FOR THE STATE OF CALIFORNIA AND SUBSTITUTION FOR THE REPORTING AND RECORDING FOR THE STATE OF CALIFORNIA. ANY REPRESENTATION AS TO THE ACCURACY OR COMPLETENESS OF THE INFORMATION CONTAINED HEREIN IS THE RESPONSIBILITY OF THE REPORTING AGENCY OR INDIVIDUAL.

() Box / No. 1116 (X) Unit Disp. / Co. No. 23 NO. CODE

REPORTING AGENCY American Express Travel Agency	ADDRESS 231 Post St.	CITY San Francisco	STATE CA	ZIP 94108
REPORTING AGENCY Wells Fargo Bank	ADDRESS	CITY	STATE	ZIP

A. INFORMATION (PAGE 17)

INCIDENT NO. 38005	EXPOSURE NO.	DATE	TIME	REPORTING AGENCY	REPORTING AGENCY ADDRESS	REPORTING AGENCY CITY	REPORTING AGENCY STATE	REPORTING AGENCY ZIP
------------------------------	--------------	------	------	------------------	--------------------------	-----------------------	------------------------	----------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	DESCRIPTION
1	Commercial - Office
5.9.1	Business office

C. PROPERTY TYPE (PAGE 41)

CODE	DESCRIPTION
1	Building Type - Single

D. EXTENT OF DAMAGE (PAGE 45)

CODE	DESCRIPTION
2	Confined to area of origin
2	Extent of damage - minor
2	Extent of damage - major
ESTIMATED LOSS - PROPERTY (ESTIMATED LOSS) - CONTENTS	
	150.0

E. LOCATION & CAUSE (PAGE 49)

CODE	DESCRIPTION
1.0.1	General Cause
2.1	Open flame
2.2	Flame spread from adjacent area
3.0	Failure of electrical wiring

F. AREA MATERIALS & SPREAD (PAGE 53)

CODE	DESCRIPTION
5.2	Conduit
5.2.1	TYPE OF MATERIAL FIRST NOTICED
5.2.1	FORM OF MATERIAL FIRST NOTICED

G. SPREAD OF FIRE (PAGE 71)

CODE	DESCRIPTION
1	None observed fire spread
1	Type of fire spread - general
1	Form of fire spread - general
1	Form of fire spread - general

H. PROTECTION FACILITIES (PAGE 91)

CODE	DESCRIPTION
1	None observed
1	None observed
1	None observed
1	None observed
5	Standpipes
5	Standpipes
5	Standpipes
5	Standpipes

I. PROTECTION FACILITIES (PAGE 97)

CODE	DESCRIPTION
1	None observed
1	None observed
1	None observed
1	None observed
1	None observed
1	None observed
1	None observed

J. MISCELLANEOUS (PAGE 109)

CODE	DESCRIPTION
1	None observed

K. MISCELLANEOUS (PAGE 115)

CODE	DESCRIPTION
1	None observed

17th Edition (1/77)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/19/65 Time 1530

(x) Box / No. 1621 (x) Unit Disp. / Co. No.

REPORT MADE AT Sa-tis Cleaners	RELATIONSHIP 	ADDRESS 98th St. S.F.	CITY S.F.	STATE CA	ZIP 94107
REPORT MADE BY 	ADDRESS 	CITY 	STATE 	ZIP 	TELEPHONE NO.

A. INFORMATION (PAGE 17)

FILE NO. 38005	INCIDENT NO. 04544	EXPOSURE NO. 1530	TIME 1019	DATE 10/19/65	TIME 1530	REPORT MADE BY	REPORT MADE AT
----------------	--------------------	-------------------	-----------	---------------	-----------	----------------	----------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT	EXTENT OF DAMAGE
1	1 Building fire	
5	6 Property classification - complete	
5	6 6 Property classification - individual	

C. PROPERTY TYPE (PAGE 41)

CODE	PROPERTY TYPE
1	1 Building Type - Single

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - TOTAL
1	1 confined to material 1st limited
CODE	EXTENT OF DAMAGE - SOURCE
1	1 " " " " " "
CODE	EXTENT OF DAMAGE - WATER
1	1 " " " " " "
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS
	13.0 C

E. LOCATION & CAUSE (PAGE 49)

CODE	LEVEL OF ORIGIN
1	0 Ground floor
CODE	SOURCE OF HEAT CAUSING INCIDENT
5	5 5 Generator
CODE	FORM OF HEAT CAUSING INCIDENT
2	2 2 1 Short circuit's wire, electric
CODE	SET OF DIVISION CAUSING INCIDENT
5	5 . 41 short circuit

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

CODE	MATERIAL TYPE
5	5 1 1 Temporary roof
CODE	TYPE OF MATERIAL FIRST NOTICED
5	5 1 1 rubber
CODE	FORM OF MATERIAL FIRST NOTICED
5	5 1 1 7 vertical insulation
CODE	AREA AFFECTED SMOKE SPREAD
5	5 1 1 " " " " " "

G. SPREAD OF FIRE (PAGE 77)

CODE	AREA AFFECTED FIRE SPREAD
CODE	TYPE OF SPREAD, CAUSING SPREAD
CODE	FORM MATERIAL, CAUSING SPREAD
CODE	SET OF DIVISION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 87)

CODE	PROTECTED - TYPE
CODE	PROTECTED - EFFECTIVENESS
CODE	STANDARD - TYPE
CODE	STANDARD - EFFECTIVENESS
CODE	PORTABLE ESTABLISHED - TYPE
5	5 1 1 5 20 fire
CODE	PORTABLE ESTABLISHED - EFFECTIVENESS
5	5 1 1 established fire

I. PROTECTION FACILITIES (PAGE 87)

CODE	PROTECTIVE DEVICES - TYPE
CODE	PROTECTIVE DEVICES - EFFECTIVENESS
CODE	SPECIAL ALARM PROTECTION - TYPE
CODE	SPECIAL ALARM PROTECTION - EFFECTIVENESS
CODE	SYSTEMS OR WARNING SYSTEM - TYPE
CODE	SYSTEMS OR WARNING SYSTEM - EFFECTIVENESS
CODE	SMOKE DETECTION SYSTEM - SOURCE OF DETECTION
CODE	SMOKE DETECTION SYSTEM - TYPE DETECTION

J. MISCELLANEOUS (PAGE 100)

NO. OF PERSONS	NO. OF DEATHS	NO. OF INJURIES	NO. OF DEATHS

SF-Form 58-66 (7-72)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date: 9 Oct 80 Time: 10:36 INCIDENT NO. 014430
 (X) Box / No. 2252 () Unit Disp. / Co. No.

REPORT MADE BY M. Martinez	PLACEMENT Tenant	CLASS SOURCE	TYPE <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
ADDRESS 172 6th. Avenue # 401	CITY San Francisco	ZIP	TELEPHONE OR TELEX SYMBOL
OWNER'S NAME	ADDRESS	CITY	ZIP
MANAGER'S NAME	ADDRESS	CITY	ZIP

A. INFORMATION (PAGE 17)

DATE OF FIRE 3 8 0 0 5	INCIDENT NO. 0.4.6.3.8	EXPOSURE NO.	TYPE 7	ADDRESS	YEAR 17.9.18.9.4	CODE OF FIRE 4	EXT. OF FIRE 4	EXT. OF EXTINCTION 4	EXT. OF LOSS 4
----------------------------------	----------------------------------	--------------	------------------	---------	----------------------------	-----------------------------	-----------------------------	-----------------------------------	-----------------------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE TYPE OF INCIDENT 1.1 Building fire	PROPERTY CLASSIFICATION (PAGE 18)
CODE PROPERTY CLASS OF NEARBY STRUCTURES	
CODE 4.4 1 Hotel rear porch	

C. PROPERTY TYPE (PAGE 21)

CODE STRUCTURE (BUILDING OR VEHICLE) - PROPERTY TYPE 1 Building Type 3	CODE VEHICLE TYPE (BUILDING OR VEHICLE) - STRUCTURE TYPE
CODE STRUCTURE (BUILDING OR VEHICLE) - STRUCTURE TYPE 1000 4	

D. EXTENT OF DAMAGE (PAGE 45)

CODE EXTENT OF DAMAGE - FIRE 1 Confined to material first ignited	CODE EXTENT OF DAMAGE - SOURCE
CODE EXTENT OF DAMAGE - WATER	
ESTIMATED LOSS - PROPERTY 0	ESTIMATED LOSS - CONTENTS 0

E. LOCATION & CAUSE (PAGE 69)

CODE LEVEL OF ORIGIN 1 0 24 Fourth floor - # 401	CODE SOURCE OF HEAT (CAUSE ORIGIN)
CODE FORM OF HEAT CAUSING INCIDENT 2 1 Stove	
CODE ACT OR OMISSION CAUSING INCIDENT 4 9 Heat from spark	
CODE 7.3 Unattended	

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE AREA OF ORIGIN 2. 4 Kitchen	CODE TYPE OF MATERIAL FIRST NOTICED
CODE FORM OF MATERIAL FIRST NOTICED 5. 7 Food	
CODE MATERIAL CAUSING SPREAD 7. 5 Cooking material	
CODE ACT OR OMISSION CAUSING SPREAD 0. 4 Vertical openings	

G. SPREAD OF FIRE (PAGE 77)

CODE MATERIAL CAUSING SPREAD	CODE TYPE OF MATERIAL CAUSING SPREAD
CODE FORM OF MATERIAL CAUSING SPREAD	
CODE ACT OR OMISSION CAUSING SPREAD	

H. PROTECTION FACILITIES (PAGE 91)

CODE STANDARD - TYPE 1 Wet pipe	CODE STANDARD - EFFECTIVENESS
CODE STANDARD - TYPE 1 Not a factor	
CODE STANDARD - TYPE 4 Dry	
CODE STANDARD - EFFECTIVENESS 1 Not a factor	
CODE PORTABLE EXTINGUISHERS - TYPE 5 For Classes A, B, C fires	CODE PORTABLE EXTINGUISHERS - EFFECTIVENESS
CODE 1 Not a factor	

I. PROTECTION FACILITIES (PAGE 97)

CODE PRIVATE SPRINKLER - TYPE	CODE PRIVATE SPRINKLER - EFFECTIVENESS
CODE SPECIAL RISK PROTECTION - TYPE	CODE SPECIAL RISK PROTECTION - EFFECTIVENESS
CODE SIGNAL SOUNDING SYSTEM - TYPE 1 Local	CODE SIGNAL SOUNDING SYSTEM - EFFECTIVENESS 1 Satisfactory
CODE SIGNAL SOUNDING SYSTEM - TYPE 3 Manual sounding station only	CODE SIGNAL SOUNDING SYSTEM - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 109)

NO. OF PERSONS NO. OF DEATHS	NO. OF PERSONS NO. OF DEATHS
NO. OF PERSONS NO. OF DEATHS	NO. OF PERSONS NO. OF DEATHS

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-20-89 Time 12:08 INCIDENT NUMBER
0,4,8,4,0

() Box / No. _____ (X) Unit Disp. / Co. No E-39

1. OCCUPANT NAME <u>Wilac Blagen</u>	2. RELATIONSHIP	3. ALARM SOURCE	4. POL. <input checked="" type="checkbox"/> <u>XX</u>	5. SPAN <input type="checkbox"/>	6. HAZARD <input type="checkbox"/>	
7. ADDRESS <u>400 Portola Dr. (Small Park area)</u>	8. CITY <u>San Francisco, Ca</u>	9. ZIP <u>94131</u>	10. TELEPHONE NO (LOCAL AREA)			
11. OTHER NAME <u>C F City and City</u>	12. ADDRESS	13. CITY	14. ZIP	15. CENSUS PARCEL NO		
16. PREVIOUS NAME	17. ADDRESS	18. CITY	19. ZIP	20. TELEPHONE NO		

A. INFORMATION (PAGE 17)

1. FIRE DEPT NO <u>38005</u>	2. INCIDENT NO <u>04840</u>	3. EXPOSURE NO	4. TIME	5. MONTH	6. DAY	7. YEAR	8. DISTRICT	9. DISTRICT	10. DISTRICT	11. DISTRICT	12. DISTRICT	13. DISTRICT	14. DISTRICT	15. DISTRICT	16. DISTRICT	17. DISTRICT	18. DISTRICT	19. DISTRICT	20. DISTRICT	21. DISTRICT	22. DISTRICT	23. DISTRICT	24. DISTRICT	25. DISTRICT	26. DISTRICT	27. DISTRICT	28. DISTRICT	29. DISTRICT	30. DISTRICT	31. DISTRICT	32. DISTRICT	33. DISTRICT	34. DISTRICT	35. DISTRICT	36. DISTRICT	37. DISTRICT	38. DISTRICT	39. DISTRICT	40. DISTRICT	41. DISTRICT	42. DISTRICT	43. DISTRICT	44. DISTRICT	45. DISTRICT	46. DISTRICT	47. DISTRICT	48. DISTRICT	49. DISTRICT	50. DISTRICT	51. DISTRICT	52. DISTRICT	53. DISTRICT	54. DISTRICT	55. DISTRICT	56. DISTRICT	57. DISTRICT	58. DISTRICT	59. DISTRICT	60. DISTRICT	61. DISTRICT	62. DISTRICT	63. DISTRICT	64. DISTRICT	65. DISTRICT	66. DISTRICT	67. DISTRICT	68. DISTRICT	69. DISTRICT	70. DISTRICT	71. DISTRICT	72. DISTRICT	73. DISTRICT	74. DISTRICT	75. DISTRICT	76. DISTRICT	77. DISTRICT	78. DISTRICT	79. DISTRICT	80. DISTRICT	81. DISTRICT	82. DISTRICT	83. DISTRICT	84. DISTRICT	85. DISTRICT	86. DISTRICT	87. DISTRICT	88. DISTRICT	89. DISTRICT	90. DISTRICT	91. DISTRICT	92. DISTRICT	93. DISTRICT	94. DISTRICT	95. DISTRICT	96. DISTRICT	97. DISTRICT	98. DISTRICT	99. DISTRICT	100. DISTRICT
---------------------------------	--------------------------------	----------------	---------	----------	--------	---------	-------------	-------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	---------------

B. PROPERTY CLASSIFICATION (PAGE 18)

1. CODE	2. TYPE OF INCIDENT	3. CODE	4. PROPERTY CLASSIFICATION FOR INCIDENTS
<u>1</u>	<u>21</u> Brush		
5. CODE	6. PROPERTY CLASSIFICATION FOR INCIDENTS		
<u>9.3.1</u>	<u>Brush outdoors</u>		

C. PROPERTY TYPE (PAGE 41)

1. CODE	2. STRUCTURE BUILDING OR VEHICLE	3. CONSTRUCTION TYPE	4. CODE	5. STRUCTURE BUILDING OR VEHICLE	6. CONSTRUCTION TYPE
	<u>9</u> Building Type				

D. EXTENT OF DAMAGE (PAGE 43)

1. CODE	2. EXTENT OF DAMAGE - FIRE
<u>2</u>	<u>Confined to area of origin</u>
3. CODE	4. EXTENT OF DAMAGE - SMOKE
<u>1</u>	<u>Confined to material</u>
5. CODE	6. EXTENT OF DAMAGE - WATER
7. ESTIMATED LOSS - PROPERTY	8. ESTIMATED LOSS - CONTENTS
<u>0.0</u>	<u>0.0</u>

E. LOCATION & CAUSE (PAGE 48)

1. CODE	2. LEVEL OF ORIGIN
	<u>1</u>
3. CODE	4. SOURCE OF HEAT CAUSING INCIDENT
5. CODE	6. FORM OF HEAT CAUSING INCIDENT
7. CODE	8. ACT OR OMISSION CAUSING INCIDENT
<u>1</u>	<u>Refer to B.F.I</u>

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

1. CODE	2. AREA OF ORIGIN
3. CODE	4. TYPE OF MATERIAL FIRST INVOLVED
5. CODE	6. FORM OF MATERIAL FIRST INVOLVED
7. CODE	8. AREA AFFECTED BY SPREAD
<u>1</u>	<u>Refer to B.F.I</u>

G. SPREAD OF FIRE (PAGE 77)

1. CODE	2. MAIN MATERIAL CAUSING SPREAD
3. CODE	4. TYPE OF MATERIAL CAUSING SPREAD
5. CODE	6. FORM OF MATERIAL CAUSING SPREAD
7. CODE	8. ACT OR OMISSION CAUSING SPREAD
<u>1</u>	<u>Refer to B.F.I</u>

H. PROTECTION FACILITIES (PAGE 81)

1. CODE	2. SPANNING TYPE
3. CODE	4. SPANNING EFFECTIVENESS
5. CODE	6. STAIRWELL TYPE
7. CODE	8. STAIRWELL EFFECTIVENESS
9. CODE	10. PORTABLE EXTINGUISHER TYPE
11. CODE	12. PORTABLE EXTINGUISHER EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 87)

1. CODE	2. PRIVATE PROTECTION - EFFECTIVENESS
3. CODE	4. SPECIAL TRAINING PROTECTION - TYPE
5. CODE	6. SPECIAL TRAINING PROTECTION - EFFECTIVENESS
7. CODE	8. SPECIAL TRAINING PROTECTION - TYPE
9. CODE	10. SPECIAL TRAINING PROTECTION - EFFECTIVENESS
11. CODE	12. SPECIAL TRAINING PROTECTION - TYPE
13. CODE	14. SPECIAL TRAINING PROTECTION - EFFECTIVENESS

J. MISCELLANEOUS (PAGE 109)

1. CODE	2. OTHER FACILITIES (TYPE THE NUMBER)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/20/89 Time 0213 INCIDENT NO. 4721
 (x) Box / No. 4747 () Unit Disp. / Co. No. _____

1. OCCUPANT NAME VICTOR ROWLEY	RELATIONSHIP OWNER	PHONE SOURCE YES <input type="checkbox"/> NO <input type="checkbox"/>	TELEPHONE NO. 552-6247
2. ADDRESS 848 WALLER STREET	CITY SAN FRANCISCO	STATE CA	ZIP 94117
3. APPLICANT NAME SEE ABOVE	ADDRESS	CITY	STATE
4. DAMAGE NAME	ADDRESS	CITY	STATE

A. INFORMATION (PAGE 17)

1. YEAR OF BIRTH 3 8 0 0 5	2. INCIDENT NO. 4 7 2 1	3. EXPOSURE NO. 0 2 1 3 1 1 0 1 2 0 1 8 0 1 6	4. DISTRICT 0 5	5. OUT OF JURISDICTION <input type="checkbox"/>
--------------------------------------	-----------------------------------	---	---------------------------	--

B. PROPERTY CLASSIFICATION (PAGE 18)

1. CODE 11 1 BUILDING FIRE	2. LOSS DATE <input type="checkbox"/>
3. CODE 4.1 1 DWELLING	

C. PROPERTY TYPE (PAGE 41)

1. CODE 1 Building Type 5	2. LOSS DATE 1 0 0 3
-------------------------------------	--------------------------------

D. EXTENT OF DAMAGE (PAGE 45)

1. CODE 2 CIADO	2. LOSS DATE <input type="checkbox"/>
3. CODE 4 CIBOO	
4. CODE 2 CIADO	
5. ESTIMATED LOSS - PROPERTY 15.00	6. ESTIMATED LOSS - CONTENTS 0.0

E. LOCATION & CAUSE (PAGE 49)

1. CODE 1 0 4 ATTIC SPACES	2. LOSS DATE <input type="checkbox"/>
3. CODE 1 6 WATER HEATER VENT FLUE	
4. CODE 1 2 HEAT FROM GAS FUELED EQUIPMENT	
5. CODE 7 9 USE OF UNINSULATED FLUE PIPE	

F. AREA MATERIALS & SMOKE SPREAD (PAGE 53)

1. CODE 4 3 ATTIC	2. LOSS DATE <input type="checkbox"/>
3. CODE 6 3 WOOD SAWN	
4. CODE 1 1 EXTERIOR ROOF COVERING	
5. CODE 0 7 HORIZONTAL OPENINGS	

G. SPREAD OF FIRE (PAGE 77)

1. CODE	2. LOSS DATE <input type="checkbox"/>
3. CODE	
4. CODE	
5. CODE	

H. PROTECTION FACILITIES (PAGE 81)

1. CODE 1	2. LOSS DATE <input type="checkbox"/>
3. CODE 1	
4. CODE 1	
5. CODE 5 ABC	
6. CODE 2 HELPED TO CONTROL FIRE	

I. PROTECTION FACILITIES (PAGE 87)

1. CODE	2. LOSS DATE <input type="checkbox"/>
3. CODE	
4. CODE	
5. CODE	
6. CODE	
7. CODE	
8. CODE	

J. MISCELLANEOUS (PAGE 100)

1. NO. OF BURNED	2. NO. OF DEATHS	3. NO. OF INJURED	4. NO. OF DEATHS

176 FORM 60-CC (7-79)

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10-20-80 Time 06:57 01217111C

() Box / No. _____ (x) Unit Disp. / Co. No. 200-37 DOE EMB

REPORT MADE AT <u>1000 Thurlow St SFO</u>	RELATIONSHIP Thurlow St	ALARM SOURCE <input type="checkbox"/> TEL <input type="checkbox"/> WIRE <input type="checkbox"/> OTHER <input type="checkbox"/>	
ADDRESS CITY STATE ZIP	TELEPHONE NO. AREA CODE		
REPORT MADE AT ADDRESS CITY STATE ZIP	TELEPHONE NO. AREA CODE		

A. INFORMATION (PAGE 17)

FILE NO. <u>38005</u>	INCIDENT NO. <u>04745</u>	REPORT NO. <u>06577</u>	TIME <u>0120</u>	DATE <u>10</u>	MONTH <u>20</u>	YEAR <u>80</u>	DAY OF WEEK <u>SAT</u>	JURISDICTION
-----------------------	---------------------------	-------------------------	------------------	----------------	-----------------	----------------	------------------------	--------------

B. PROPERTY CLASSIFICATION (PAGE 18)

CODE	TYPE OF INCIDENT <u>1.2 Vehicle Fire</u>	PROPERTY CLASSIFICATION
CODE	PROPERTY CLASSIFICATION	
CODE	PROPERTY CLASSIFICATION	
CODE	PROPERTY CLASSIFICATION	

C. PROPERTY TYPE (PAGE 18)

CODE	PROPERTY TYPE <u>6 Building Type</u>	STRUCTURE TYPE
CODE	PROPERTY TYPE	
CODE	PROPERTY TYPE	
CODE	PROPERTY TYPE	

D. EXTENT OF DAMAGE (PAGE 45)

CODE	EXTENT OF DAMAGE - FIRE <u>2 Confined to area of origin</u>	ESTIMATED LOSS - PROPERTY <u>5,000</u>
CODE	EXTENT OF DAMAGE - FIRE	
CODE	EXTENT OF DAMAGE - WATER	
CODE	EXTENT OF DAMAGE - CONTENTS	

E. LOCATION & CAUSE (PAGE 49)

CODE	LOCATION OF ORIGIN <u>0.6 Vehicle</u>	SOURCE OF HEAT
CODE	LOCATION OF ORIGIN	
CODE	FORM OF HEAT	
CODE	CAUSE OF ORIGIN	

F. AREA MATERIALS & SMOKE SPREAD (PAGE 51)

CODE	AREA OF ORIGIN <u>8.31 Engine Area</u>	TYPE OF MATERIAL FIRST NOTICED <u>1.0 Metal Fuel</u>
CODE	AREA OF ORIGIN	
CODE	FORM OF MATERIAL FIRST NOTICED	
CODE	FORM OF MATERIAL FIRST NOTICED	

G. SPREAD OF FIRE (PAGE 71)

CODE	WIND DIRECTION	WIND VELOCITY
CODE	WIND DIRECTION	
CODE	WIND VELOCITY	
CODE	WIND VELOCITY	

H. PROTECTION FACILITIES (PAGE 91)

CODE	APPLICABLE - TYPE	EFFECTIVENESS
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	

I. PROTECTION FACILITIES (PAGE 97)

CODE	APPLICABLE - TYPE	EFFECTIVENESS
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	
CODE	APPLICABLE - TYPE	

J. MISCELLANEOUS (PAGE 105)

CODE	MISCELLANEOUS	EFFECTIVENESS
CODE	MISCELLANEOUS	
CODE	MISCELLANEOUS	
CODE	MISCELLANEOUS	

THIS INFORMATION IS TO BE USED FOR THE STATE OF CALIFORNIA OFFICE OF THE ATTORNEY GENERAL AND DISTRICT ATTORNEYS UNDER THE PROVISIONS OF THE FIRE INCIDENT REPORT ACT AND THE CALIFORNIA FIRE INCIDENT REPORT ACT, AS AMENDED.		DATE 10/20/89 TIME 1700	INCIDENT NO. 4 IP 14 10
REPORTING AGENCY N/A		RELATIONSHIP	TYPE OF DAMAGE
ADDRESS IFO 400 Partola Dr.		CITY S.F.	TELEPHONE NO.
REPORTING OFFICER		AGENCY	COMMUNITY/PROJECT NO.
REPORTING AGENCY n/a		ADDRESS	TELEPHONE NO.

A. INFORMATION (PAGE 1)

FIRE DEPT. NO. 38005	INCIDENT NO.	REPORTING NO.	TIME	MONTH	DAY	YEAR	LOCAL	DIST	OUT OF JURISDICTION

B. PROPERTY CLASSIFICATION (PAGE 2)

CODE	TYPE OF INCIDENT	PROPERTY CLASSIFICATION
CODE	PROPERTY CLASSIFICATION	
CODE	PROPERTY CLASSIFICATION	

C. PROPERTY TYPE (PAGE 3)

PROPERTY TYPE	STRUCTURE	USE
CODE	STRUCTURE	USE

D. EXTENT OF DAMAGE (PAGE 4)

CODE	EXTENT OF DAMAGE - FUEL
CODE	EXTENT OF DAMAGE - STRUCTURE
CODE	EXTENT OF DAMAGE - WATER
ESTIMATED LOSS - PROPERTY	ESTIMATED LOSS - CONTENTS

E. LOCATION & CAUSE (PAGE 5)

CODE	LEVEL OF ORIGIN
1.0.1	Ground level
CODE	SOURCE OF HEAT CAUSING INCIDENT
9.8.1	No equipment involved
CODE	FORM OF HEAT CAUSING INCIDENT
4.9.1	Spark or open flame
CODE	ACT OR OMISSION CAUSING INCIDENT
1.7.1	Incendiary

F. AREA MATERIALS & SMOKE SPREAD (PAGE 6)

CODE	AREA OF ORIGIN
9.4.1	open park area
CODE	TYPE OF MATERIAL FIRST NOTICED
5.4.1	Grass, leaves, twigs, ect.
CODE	FORM OF MATERIAL FIRST NOTICED
7.4.1	Natural form, brush
CODE	HOW SPREAD DAMAGE SPREAD
0.9.1	Not a factor

G. SPREAD OF FIRE (PAGE 7)

CODE	HOW SPREAD FIRE SPREAD
0.9.1	Not a factor
CODE	TYPE OF MATERIAL CAUSING SPREAD
9.8.1	N/A
CODE	FORM MATERIAL CAUSING SPREAD
7.4.1	Natural form, brush
CODE	ACT OR OMISSION CAUSING SPREAD
1.7.1	Incendiary

H. PROTECTION FACILITIES (PAGE 8)

CODE	SMOKERS - TYPE
CODE	SMOKERS - EFFECTIVENESS
CODE	STAMPED - TYPE
CODE	STAMPED - EFFECTIVENESS
CODE	PORTABLE EXTINGUISHERS - TYPE
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 9)

CODE	CONCRETE DAMAGE - TYPE
CODE	CONCRETE DAMAGE - EFFECTIVENESS
CODE	SPECIAL WEIR PROTECTION - TYPE
CODE	SPECIAL WEIR PROTECTION - EFFECTIVENESS
CODE	SHOULD BE WORKING SYSTEM
CODE	SHOULD BE WORKING SYSTEM - EFFECTIVENESS
CODE	SHOULD BE WORKING SYSTEM - MEANS OF ACTIVATION
CODE	SHOULD BE WORKING SYSTEM - TYPE DETECTOR

J. MISCELLANEOUS (PAGE 10)

NO. DAMAGED	NO. OF DEATHS	NO. DAMAGED	NO. OF DEATHS

Report prepared in this report are...
STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT

Date 10-20-89 Time 07:51

INCIDENT NO. 0.4.7.5.2

(X) Box / No. 6243 () Unit Disp. / Co. No.

REPORT MADE BY: Ms. Mable McDonald
RELATIONSHIP: Renter
ADDRESS: 83 Brookdale Ave. San Francisco, Ca 94134
S.F. Housing Auth. 440 Turk St., S.F.
Mr. Freeman

A. INFORMATION (PAGE 17)

3 80 05 0.4.7.5.2 0.7.5.11102018.916

B. PROPERTY CLASSIFICATION (PAGE 18)

1. 11 Building Fire
4. 2.3 Apts. under 20 units

C. PROPERTY TYPE (PAGE 41)

1. Building Type 3

D. EXTENT OF DAMAGE (PAGE 43)

2. Confined to area of origin
3. Confined to floor of origin
3. Confined to floor of origin

E. LOCATION & CAUSE (PAGE 49)

1 0 2 Second Floor
9 8 No equipment involved
4 5 Match
3 6 Child playing with

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 63)

2. 1 Bedroom
7. 2 Cotton
3. 1 Mattress
0. 4 Vertical openings

G. SPREAD OF FIRE (PAGE 77)

Blank form for fire spread details.

H. PROTECTION FACILITIES (PAGE 81)

Blank form for protection facilities.

I. PROTECTION FACILITIES (PAGE 81)

6. Household
1. Automatic detector
2. Smoke detector

J. MISCELLANEOUS (PAGE 109)

Blank form for miscellaneous information.

FIRE INCIDENT REPORT SAN FRANCISCO FIRE DEPARTMENT
 STATE OF CALIFORNIA
 OFFICE OF THE STATE FIRE MARSHAL Date 10/20/89 Time 18:52 0.4.95.3
 (X) Box / No. 1565 () Unit Disp. / Co. No.

REPORT NAME Richard Leong	RESIDENTIAL tenant	APARTMENT NO. 10	STREET NO. 1424	CITY San Francisco	STATE CA	ZIP 94113	TELEPHONE NO. 333
ADDRESS 1424 Pacific Ave	CITY San Francisco	STATE CA	ZIP 94113	TELEPHONE NO. 333			

A. INFORMATION (PAGE 17)

FILE NO. 38005	INCIDENT NO. 04953	REPORT NO. 185211012	DATE 08910	TIME 1501	TYPE OF DAMAGE 1	EXTENT OF DAMAGE 1	AREA MATERIALS 6	PROTECTION FACILITIES 1	SPREAD OF FIRE 1
----------------	--------------------	----------------------	------------	-----------	------------------	--------------------	------------------	-------------------------	------------------

B. PROPERTY CLASSIFICATION (PAGE 19)

CODE 1.1 Building Fire	PROPERTY CLASSIFICATION
CODE 4.2.3 Apartment 7-20 units	PROPERTY CLASSIFICATION

C. PROPERTY TYPE (PAGE 21)

CODE 2 Building Type	PROPERTY TYPE
CODE 10.0.4	PROPERTY TYPE

D. EXTENT OF DAMAGE (PAGE 45)

CODE 1.1 Confined to material first ignited	EXTENT OF DAMAGE
CODE 2.1 Confined to area first ignited	EXTENT OF DAMAGE
CODE 1.1 Confined to material first ignited	EXTENT OF DAMAGE
ESTIMATED LOSS - PROPERTY 1005.0	ESTIMATED LOSS - CONTENTS 0.0

E. LOCATION & CAUSE (PAGE 49)

CODE 2.0.1 Basement	LOCATION OF DAMAGE
CODE 9.8.1 No equipment involved	CAUSE OF DAMAGE
CODE 3.1 Cigarette	CAUSE OF DAMAGE
CODE 3.1 Discarded material	CAUSE OF DAMAGE

F. AREA MATERIALS & SMOKE SPREAD (PAGE 63)

CODE 4.7 Garage	AREA OF DAMAGE
CODE 6.7 Paper	TYPE OF MATERIAL FIRST IGNITED
CODE 7.5 Rubbish	TYPE OF MATERIAL FIRST IGNITED

G. SPREAD OF FIRE (PAGE 77)

CODE N/A	SPREAD OF FIRE
----------	----------------

H. PROTECTION FACILITIES (PAGE 91)

CODE 1 For charger & B.C. fire	PROTECTION FACILITIES
CODE 1 Not a factor	PROTECTION FACILITIES

I. PROTECTION FACILITIES (PAGE 97)

CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES
CODE	PROTECTION FACILITIES

J. MISCELLANEOUS (PAGE 100)

NO. REPORTED	NO. OF DEATHS	NO. INJURED	NO. OF DEATHS

K. MISCELLANEOUS (PAGE 100)

NO. REPORTED	NO. OF DEATHS	NO. INJURED	NO. OF DEATHS