

NATIONAL CENTER FOR EARTHQUAKE
ENGINEERING RESEARCH

State University of New York at Buffalo



PB95-252326

Pipeline Replacement Feasibility Study:
A Methodology for Minimizing Seismic and Corrosion
Risks to Underground Natural Gas Pipelines

by

R.T. Eguchi, H.A. Seligson and D.G. Honegger

EQE International
Lakeshore Towers
18101 Von Karman Avenue, Suite 400
Irvine, California 92715

Technical Report NCEER-95-0005

March 2, 1995


This research was conducted at EQE International and was partially supported by the National Science Foundation under Grant No. BCS 90-25010 and the New York State Science and Technology Foundation under Grant No. NEC-91029.

NOTICE

This report was prepared by EQE International as a result of research sponsored by the National Center for Earthquake Engineering Research (NCEER) through grants from the National Science Foundation, the New York State Science and Technology Foundation, and other sponsors. Neither NCEER, associates of NCEER, its sponsors, EQE International, nor any person acting on their behalf:

- a. makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe upon privately owned rights; or
- b. assumes any liabilities of whatsoever kind with respect to the use of, or the damage resulting from the use of, any information, apparatus, method or process disclosed in this report.

Any opinions, findings, and conclusions or recommendations expressed in this publication are those of the author(s) and do not necessarily reflect the views of NCEER, the National Science Foundation, the New York State Science and Technology Foundation, or other sponsors.



**NATIONAL CENTER FOR EARTHQUAKE
ENGINEERING RESEARCH**

State University of New York at Buffalo



PB95-252326

**Pipeline Replacement Feasibility Study:
A Methodology for Minimizing Seismic and Corrosion
Risks to Underground Natural Gas Pipelines**

by

R.T. Eguchi, H.A. Seligson and D.G. Honegger

EQE International
Lakeshore Towers
18101 Von Karman Avenue, Suite 400
Irvine, California 92715

Technical Report NCEER-95-0005

REPRODUCED BY
U.S. DEPARTMENT OF COMMERCE
NATIONAL TECHNICAL
INFORMATION SERVICE
SPRINGFIELD, VA 22161

March 2, 1995

This research was conducted at EQE International and was partially supported by the National Science Foundation under Grant No. BCS 90-25010 and the New York State Science and Technology Foundation under Grant No. NEC-91029.

NOTICE

This report was prepared by EQE International as a result of research sponsored by the National Center for Earthquake Engineering Research (NCEER) through grants from the National Science Foundation, the New York State Science and Technology Foundation, and other sponsors. Neither NCEER, associates of NCEER, its sponsors, EQE International, nor any person acting on their behalf:

- a. makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe upon privately owned rights; or
- b. assumes any liabilities of whatsoever kind with respect to the use of, or the damage resulting from the use of, any information, apparatus, method or process disclosed in this report.

Any opinions, findings, and conclusions or recommendations expressed in this publication are those of the author(s) and do not necessarily reflect the views of NCEER, the National Science Foundation, the New York State Science and Technology Foundation, or other sponsors.



**Pipeline Replacement Feasibility Study:
A Methodology for Minimizing Seismic and Corrosion
Risks to Underground Natural Gas Pipelines**

by

R.T. Eguchi¹, H.A. Seligson² and D.G. Honegger³

March 2, 1995

Technical Report NCEER-95-0005

NCEER Task Numbers 93-7301B, 92-3601B and 91-3541B

NSF Master Contract Number BCS 90-25010

and

NYSSTF Grant Number NEC-91029

also prepared for

Southern California Gas Company

Los Angeles, California


- 1 Vice President, EQE International
- 2 Staff Engineer, EQE International
- 3 Principal Engineer, EQE International

NATIONAL CENTER FOR EARTHQUAKE ENGINEERING RESEARCH
State University of New York at Buffalo
Red Jacket Quadrangle, Buffalo, NY 14261

PREFACE

The National Center for Earthquake Engineering Research (NCEER) was established to expand and disseminate knowledge about earthquakes, improve earthquake-resistant design, and implement seismic hazard mitigation procedures to minimize loss of lives and property. The emphasis is on structures in the eastern and central United States and lifelines throughout the country that are found in zones of low, moderate, and high seismicity.

NCEER's research and implementation plan in years six through ten (1991-1996) comprises four interlocked elements, as shown in the figure below. Element I, Basic Research, is carried out to support projects in the Applied Research area. Element II, Applied Research, is the major focus of work for years six through ten. Element III, Demonstration Projects, have been planned to support Applied Research projects, and will be either case studies or regional studies. Element IV, Implementation, will result from activity in the four Applied Research projects, and from Demonstration Projects.



Research tasks in the **Lifeline Project** evaluate seismic performance of lifeline systems, and recommend and implement measures for mitigating the societal risk arising from their failures or disruption caused by earthquakes. Water delivery, crude oil transmission, gas pipelines, electric power and telecommunications systems are being studied. Regardless of the specific systems to be considered, research tasks focus on (1) seismic vulnerability and strengthening; (2) repair and restoration; (3) risk and reliability; (4) disaster planning; and (5) dissemination of research products.

The end products of the **Lifeline Project** will include technical reports, computer codes and manuals, design and retrofit guidelines, and recommended procedures for repair and restoration of seismically damaged systems. The **structures and systems program** constitutes one of the important areas of research in the **Lifelines Project**. Current tasks include the following:

1. Continued testing of lightly reinforced concrete external joints.
2. Continued development of analytical tools, such as system identification, idealization, and computer programs.
3. Perform parametric studies of building response.
4. Retrofit of lightly reinforced concrete frames, flat plates and unreinforced masonry.
5. Enhancement of the IDARC (inelastic damage analysis of reinforced concrete) computer program.
6. Research infilled frames, including the development of an experimental program, development of analytical models and response simulation.
7. Investigate the torsional response of symmetrical buildings.

This report presents a methodology which a utility can use to fold mitigation for seismic hazards into its ongoing repair and replacement program. The methodology was developed specifically for buried pipeline components within the Southern California Gas Company (SoCalGas) system. Both transmission and distribution pipeline systems are considered; however, suggested procedures differ, due in part to the importance and relative lack of redundancy (i.e., interconnectedness) for transmission pipe.

In the past, the SoCalGas repair and replacement program focused on corrosion damage. The new methodology incorporates potential seismic damage as characterized by areas of potential ground failure. As part of this effort, a new procedure for estimating corrosion leakage rates in "data-poor" areas is proposed.

The report describes realistic mitigation procedures for buried pipeline components which is one of the objectives of NCEER's Lifeline Project.

ABSTRACT

This report completes the review of procedures used by the Southern California Gas Company to optimize decisions on pipeline replacement and repair. In addition to discussions with the Engineering Design Department, meetings were also held with representatives from System Planning, Transmission and Distribution. This study was conducted as a joint effort between EQE International and Cornell University. Partial support for this effort was received from the National Center for Earthquake Engineering Research.

This report is comprised of two major parts: (1) a report that discusses a plan for consideration of seismic and corrosion risks under a common program, and (2) a report that summarizes the development of improved corrosion leakage models for the Southern California Gas Company (Appendix B).

The main conclusions of this report are three-fold:

1. It is possible to develop a consistent, company-wide pipe repair/replacement methodology based on minimizing expected costs from corrosion-related failures, and increasing the seismic resistance and safety of the system. For Transmission, this program is based on refining the delineation of areas of potential ground failure (i.e., liquefaction) that are responsible for the majority of the seismic risk. For Distribution, this program is based on using EPOCH (a computer program developed by Distribution to optimize economic decisions on pipe repair/replacement based on corrosion risks) as a major element; additional criteria are applied afterward to decide whether pipes initially identified for repair should be replaced for seismic hazard mitigation purposes.
2. Current methods for predicting pipeline leakage based on corrosion failures appear to be adequate when sufficient repair data are available. Improvements can be made by incorporating the "age dependent" model developed in this study that allows for prediction of leakage rates based on one or two data points. An analysis of repair data found that a key parameter in establishing future corrosion leak rates is the age at which the first leak is discovered. When spurious data were removed from the

data set, it was observed that the rate of increase of leak rates increases with the age at first leak. By incorporating this new parameter, the assessment of future leakage can be expanded to include more pipe, such as an additional 19 percent in the pilot study. It must be cautioned, however, that the analysis performed in this study was for a small area of the total system. Further investigation of other areas would need to be performed in order to verify whether the trends observed in this study are general trends.

3. A number of recommendations are made regarding further steps for this study. The most important recommendation is to extend parts of the Feasibility study so that (1) a procedure for integrating seismic and corrosion risks for distribution pipelines can be tested for a small area of the system, and (2) the details of a more integrated, interdepartmental program can be developed and tested.

TABLE OF CONTENTS

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|--|-------------|
| 1. | INTRODUCTION | 1-1 |
| 2. | INTERACTION WITH SOUTHERN CALIFORNIA GAS | |
| | COMPANY PERSONNEL | 2-1 |
| 2.1 | Project Meetings | 2-1 |
| 2.2 | Information Supplied by SoCalGas | 2-1 |
| 2.3 | Outcome of Interaction | 2-4 |
| 3. | PERCEIVED ISSUES AND CONCERNS | 3-1 |
| 3.1 | Repair vs. Replacement | 3-1 |
| | 3.1.1 Distribution - "Repair vs. Replace" | 3-2 |
| | 3.1.2 Transmission - Prioritized Replacement | 3-2 |
| 3.2 | Seismic vs. Non-Seismic Risks | 3-3 |
| | 3.2.1 Distribution | 3-3 |
| | 3.2.2 Transmission | 3-4 |
| 3.3 | Planning Time Frames | 3-6 |
| 4. | GENERAL METHODOLOGY FOR PIPELINE | |
| | REPLACEMENT DECISIONS | 4-1 |
| 4.1 | Pipeline Replacement Methodology for Transmission | 4-1 |
| | 4.1.1 Review Pipeline Data | 4-1 |
| | 4.1.2 Review System Planning Department's Long Term Goals | 4-3 |
| | 4.1.3 Assess Seismic Hazard and Impact of Outage | 4-3 |
| | 4.1.4 Assess Other Non-Seismic Risks | 4-5 |
| | 4.1.5 Select Replacement Strategy | 4-5 |
| | 4.1.6 Calculate Replacement Costs | 4-6 |
| | 4.1.7 Calculate Priority Factor | 4-6 |

TABLE OF CONTENTS (CONTINUED)

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|---|-------------|
| 4.2 | Pipeline Replacement Methodology for Distribution | 4-6 |
| | 4.2.1 Review Planning Data | 4-8 |
| | 4.2.2 Run EPOCH | 4-8 |
| | 4.2.3 Post-EPOCH Analysis | 4-9 |
| 5. | REFINED PREDICTIVE MODELS FOR CORROSION LEAKAGE | 5-1 |
| 5.1 | Pilot Study Data | 5-1 |
| 5.2 | Assessment of Linear Regression Prediction Technique | 5-2 |
| 5.3 | Alternative Leak Prediction Methodology - the Age Dependent Model | 5-2 |
| 5.4 | Conclusions and Recommendations from the Pilot Study | 5-6 |
| 6. | RECOMMENDED REFINEMENTS FOR IMPROVED DECISION- MAKING CAPABILITIES | 6-1 |
| 6.1 | Mapping and Records | 6-1 |
| 6.2 | Interaction with System Planning | 6-2 |
| 6.3 | Incorporation of Seismic Risks | 6-2 |
| 7. | REFERENCES | 7-1 |

APPENDICES

| | |
|---|--|
| A | Explanation of Least Squares Method |
| B | Results of Distribution Study |
| C | Index Maps to Atlas Sheets and Pipeline Segment Database |
| D | Lead Database |

LIST OF TABLES

| | <u>Page</u> |
|--|-------------|
| 2-1: Summary of Project Meetings | 2-2 |

LIST OF FIGURES

| | |
|--|-----|
| 4-1: General Methodology for Pipeline Replacement Decisions | 4-2 |
| 4-2: Procedure for Incorporating Seismic Hazard Data into Pipeline Repair/Replacement Decisions for Distribution | 4-7 |
| 5-1: Comparison of Leak Rate Prediction from Linear Regression of Data Through 1986 to Actual Post-1986 Performance (from Torrance Area Pilot Study) | 5-4 |
| 5-2: Age Dependent Leak Rate Model for Steel Pipe Installed in 1912 (from Torrance Area Pilot Study) | 5-5 |
| 5-3: Comparison of Leak Rates Predicted from Age Dependent Model to Actual Post-1986 Performance (from Torrance Area Pilot Study) | 5-7 |
| 5-4: Comparison of Predicted Leak Rates from the Dependent Model to Actual Post-1986 Performance for Pipes with Limited Leakage (from Torrance Area Pilot Study) | 5-8 |

SECTION 1 INTRODUCTION

As the cost environment within which gas utilities operate becomes more competitive, issues such as pipe repair versus pipe replacement become more important. Decisions to automatically replace generalized categories of pipe without a cost/benefit analysis are rapidly becoming obsolete, primarily because of excessive costs. At the same time, the ability to assess future risks associated with pipeline failure are becoming more keenly developed. The use of well-managed databases has allowed utility companies to examine in detail the probability or likelihood of experiencing certain kinds of pipe failures. This information, combined with an assessment of the impact of these failures, has allowed gas utilities to compare the benefits and risks of adopting alternative strategies for pipe repair and replacement. In general, the actual strategy for repair or replacement will depend on the particular characteristics of the utility and the goals of their replacement program.

In June of 1992, the Southern California Gas Company (SoCalGas) authorized EQE International and Cornell University to perform an independent assessment of current SoCalGas pipe repair and replacement strategies. The primary focus of this program was on risk assessment, and economic and safety issues related to pipe repair/replacement. Because a large part of this effort dealt with an analysis of risks associated with earthquakes, partial funding for this project was provided by the National Center for Earthquake Engineering Research (NCEER).

The intent of this study is to help SoCalGas develop a company-wide strategy for replacement of current and future steel pipelines within its system. To accomplish this, the study has been divided into two phases: feasibility and implementation. This particular report summarizes the feasibility phase in which a general methodology for making decisions regarding steel pipeline integrity has been developed. In addition, a portion of this methodology has been applied to a small area within the SoCalGas system. Whereas the Cornell report emphasizes pipe repair/replacement for transmission and distribution supply lines, the EQE report concentrates on distribution pipelines. In the implementation phase, the general methodology will be refined, tested for additional portions of the system, and

implemented with SoCalGas engineers as a continuing program to assess pipeline conditions and set cost-effective priorities for steel pipeline repair and replacement.

The following tasks were performed to meet the objectives of the feasibility phase:

1. Review current programs being used by the Transmission and Distribution Departments of SoCalGas for prioritizing pipe repair and replacement.
2. Recommend improvements in existing methodologies, and suggest ways of integrating these improvements to form a more consistent, systematic approach to planning.
3. Review and refine risk models to reflect more accurately the risks associated with different pipe repair and replacement strategies.
4. Suggest ways of utilizing more detailed information on the location of potential liquefaction areas in estimating future earthquake risks to pipelines.
5. Develop a framework for a comprehensive system integrity and pipe repair/replacement methodology.

In general, these tasks parallel those completed by Cornell University for transmission and distribution supply pipelines.

This report is organized into six major sections, including this introduction. Section 2 discusses the interaction of the project team with SoCalGas personnel. A number of meetings were held between EQE, Professor T.D. O'Rourke of Cornell University and SoCalGas personnel from the Engineering Design, System Planning, Transmission and Distribution Departments to discuss the objectives and status of the various tasks. Section 3 identifies important issues and concerns regarding the development of a system-wide pipe repair/replacement program. Issues such as pipe repair vs. replacement, seismic vs. non-seismic risks, and short-term vs. long-term planning are discussed. Section 4 discusses a general methodology for combining the risks from various hazards or effects. Separate discussions are given for transmission and distribution systems. Section 5 presents the major contribution of the feasibility study, i.e., the development of improved corrosion leakage models. Using data from a portion of the SoCalGas system, an analysis

was made of current techniques for predicting future leaks due to corrosion. As a result of this analysis, several recommendations were made with regard to better use of the data and new models for estimating corrosion related leakage. The results of this corrosion study are documented in detail in a separate report that is attached here as an appendix. Finally, Section 6 recommends future steps in this study. One important recommendation is to extend the feasibility study to allow for a more complete integration of risks (i.e., earthquake and corrosion) in establishing pipe repair and replacement priorities. This analysis would be applied to the same pilot area selected for the corrosion analysis.

SECTION 2

INTERACTION WITH SOUTHERN CALIFORNIA GAS COMPANY PERSONNEL

An important part of this project was the interaction between the project team and SoCalGas personnel. This interaction was important in understanding the priorities assigned by each SoCalGas department to each of the project tasks. Additionally, this interaction was used to refine the objectives and scope of critical tasks. The following subsections discuss the meetings that were held throughout the project, information that was received from SoCalGas, and the outcome of this interaction.

2.1 PROJECT MEETINGS

Numerous project meetings were held to solicit input from the various SoCalGas departments. Meetings held early in the project schedule (August 5 and September 10, 1992) to help define the focus of the study included representatives from Distribution, Engineering, Planning and Transmission. Several interim meetings (September 29, and October 12, 1992) emphasized the pilot distribution system corrosion leakage analysis. Later meetings summarized preliminary project results and functioned as project status updates (November 10 and December 23, 1992, and January 19, 1993). Table 2-1 summarizes the general purpose of each meeting, and lists EQE, SoCalGas, and Cornell personnel in attendance.

2.2 INFORMATION SUPPLIED BY SOCALGAS

During the course of the project meetings, various documents and studies prepared by SoCalGas were identified for our review. These documents described current programs and methodologies used by SoCalGas to prioritize pipeline replacement. These include:

- Value Chain Analysis of the Pre-WWII Transmission Pipeline Replacement Program, SoCalGas (Transmission), November, 1991
- Underground Piping System Replacement Assessment, G.E. Strang, SoCalGas (Engineering), May, 1986

Table 2-1
SUMMARY OF PROJECT MANAGERS

| DATE | GENERAL PURPOSE | MEETING LOCATION | EQE | CORNELL | SoCalGas* |
|----------|---|------------------------------|---------------------------------------|----------|--|
| 8/5/92 | Project Kick-Off Meeting Orientation to SoCalGas Issues | SoCalGas - LA | Eguchi Honegger | O'Rourke | Ackart (T) Becker-Castle (R) Butler (D) Conley (D) Constantine (E) Gailing (T) Haynes (E) Moore (E) Nose' (E) Saad (T) Sam (E) Stevens (E) Wellman (D) |
| 9/10/92 | Follow-up to Kick-Off Meeting - Refinement of Issues/Scope | SoCalGas - LA | Eguchi Honegger Seligson | | Conley (D) Hammer (D) Mansdorfer (T) McNorgan (E) Stevens (E) Wellman (E) |
| 9/29/92 | Meeting to collect data for pilot study (corrosion leakage) | SoCalGas - Torrance Division | Eguchi Honegger Seligson Shu | | Blood (D) Conley (D) Hammer (D) Jordan (D) Moore (E) |
| 10/12/92 | Follow-up meeting to refine study area data | SoCalGas - Torrance Division | Seligson Shu | | Blood (D) Hammer (E) |
| 11/10/92 | Project Team Meeting - Status Report | EQE - Irvine | Eguchi Honegger Seligson Shu | O'Rourke | McNorgan (E) Moore (E) |
| 12/23/92 | Presentation of preliminary results for pilot study | SoCalGas - LA | Eguchi Seligson Shu | | Becker-Castle (R) Conley (D) Dowell (E) Gailing (E) Haynes (E) Madariage (E) Moore (E) |
| 1/19/93 | Discussion for report outline, Confirmation of deliverables | EQE - Irvine | Eguchi Seligson Shu | | Dowell (E) |

Table 2-1 (Continued)
SUMMARY OF PROJECT MANAGERS

| DATE | GENERAL PURPOSE | MEETING LOCATION | EQE | CORNELL | SoCalGas* |
|--------|-----------------|------------------|--------------------|----------|---|
| 7/8/93 | | SoCalGas - LA | Eguchi Seligson | O'Rourke | Becker-Castle (R) Conley (D) Gailing (E) Haynes (E) McNorgan (E) Stevens (E) |

* Note: (D) = Distribution (E) = Engineering (P) = Planning
 (R) = Research (T) = Transmission

- "Engineering Report, Special Pipeline Replacement Program, - 1994 Rate Case", SoCalGas (Engineering), June, 1992.
- A sample data sheet and flow chart describing EPOCH (Efficient Pipeline Operation in a Competitive Habitat), the economic repair-replace decision-making program under development by Distribution.
- Annual report for calendar year 1992, Gas Distribution System.

In addition, other reference material identified by Transmission staff was provided:

- J.F. Kiefner and P.H. Vieth (1991), "Methods for Prioritizing Pipeline Maintenance and Rehabilitation", Pipeline Risk Assessment, Rehabilitation and Repair Conference.
- W.E. Martinsen and J.B. Cornwell (1991), "Use and Misuse of Historical Pipeline Failure Data", Pipeline Risk Assessment, Rehabilitation and Repair Conference.
- W.K. Muhlbauer (1991), Dow Chemical Company, "RIPS - a Pipeline Safety Evaluation System", Pipeline Risk Assessment, Rehabilitation and Repair Conference.
- N.A. Townsend and G.B. Fearnough (1986), British Gas Corporation, "Controlling Risk From U.K. Gas Transmission Pipelines", 7th Symposium on Line Pipe Research, American Gas Association.

2.3 OUTCOME OF INTERACTION

As a result of the discussions with various SoCalGas personnel and review of relevant background material, the project team was able to:

- identify the general framework within which any SoCalGas pipeline replacement program must operate

- understand replacement programs and strategies currently in place at SoCalGas, and evaluate current risk assessment techniques
- identify issues of importance to the various departments (see Section 3.0)
- identify operational differences between distribution and transmission that might impact implementation of a uniform pipe replacement strategy (see Section 3.1)
- understand the linkages between Distribution, Transmission, and System Planning (see Section 3.3)
- identify areas where the project team might make significant contributions to existing procedures (see Section 5.0).

One of the more important outcomes of this interaction was the decision to refocus development efforts from economic modelling to risk assessment. During the initial stages of this project, it was pointed out that a significant internal effort was being undertaken by Distribution to develop a computer program capable of making decisions regarding pipe repair or replacement based on economic considerations. Because of the proprietary nature of that program, few details were provided to the project team on the algorithms used to forecast leaks caused by corrosion or the methods used to calculate costs and benefits. As a result, it was collectively decided that EQE's efforts should focus on an independent development of corrosion leakage models, and that recommendations be provided on how best to utilize the repair data available to SoCalGas engineers.

In order to provide some guidance to SoCalGas on how current methods for pipe repair/replacement can be integrated with methods that focus on seismic risks, a general methodology has been developed. This methodology, discussed in Section 4.0, emphasizes a prioritized replacement program for transmission and distribution supply lines, and an optimization program for pipe repair/replacement for Distribution built around the current Distribution corrosion program EPOCH.



SECTION 3

PERCEIVED ISSUES AND CONCERNS

In the course of this project, several issues relevant to the development of a consistent replacement strategy were identified. It was clear from discussions with SoCalGas personnel, that the issue of pipe repair and replacement was perceived differently by the various departments. The departments that are directly impacted by the issue of pipe repair/replacement include:

- System Planning
- Transmission
- Distribution
- Engineering Design

Addressing the pipe repair/replacement problem from a company-wide basis requires an understanding of the relevant issues for each department. It is possible that issues affecting one department may, in fact, not be considered significant by the other departments. One reason for these differences may be the level of risk associated with pipeline failure. The risk resulting from failures on transmission lines, for example, may be considered more significant than a distribution main failure, thus necessitating a stronger safety component. Another reason for implementing different replacement strategies may relate to the number and frequency of repairs made on each system. Because numerous repairs are made to the distribution system each year, the cost to maintain the system becomes a critical factor. Therefore, strategies to reduce the overall economic cost of maintaining the system become more important.

The following discussions underscore some of the major issues that must be addressed to formulate a company-wide approach to pipe repair/replacement. In general, these issues fall into three categories: pipe repair versus pipe replacement, seismic versus non-seismic risks, and varying time frames for planning.

3.1 REPAIR VS. REPLACEMENT

In order to develop a single pipeline replacement methodology that would be applicable to both transmission and distribution, it is instructive to identify our

understanding of operational differences with respect to pipeline replacement that could impact implementation.

3.1.1 Distribution - "Repair vs. Replace"

Routine repair/replacement decisions for Distribution piping are generally reactive - Distribution responds when a leak is reported or found as part of scheduled surveys. Serious leaks (Codes 1 and 2) are repaired immediately, or within two weeks, while less serious leaks (Code 3) that require action within one year, become part of the "Repair vs. Replace" decision-making process. That is, pipeline replacement is only an option for pipeline segments with Code 3 leakage pending. Currently, SoCalGas is in the process of implementing EPOCH, a computer program which quantifies the cost of repair and replacement alternatives for Distribution piping. The results of EPOCH provide the repair/replace decision, as well as a basis for prioritization of projects.

In response to CPUC suggestions, a limited number of distribution pipeline classes have been identified for inclusion in a special pipeline replacement program.

Attention by the CPUC Staff to "reportable incidents" involving main or service failures has increased since 1980. The Staff has suggested planned removal of "families" of gas facilities unless the company demonstrates that the "reportable" incident involved unusual conditions unlikely to be repeated in the future (Strang, 1986).

Classes slated for replacement include certain plastic services, copper mains and services, cast iron mains, bare steel main in conduit, and Pre-World War II supply lines in urban areas. Replacement priorities have been set according to safety concerns, continuity of service and certain economic factors, such as "... prevention of cost from incidents, judgements and assessments" (Strang, 1986)

3.1.2 Transmission - Prioritized Replacement

For high pressure transmission lines, any failure is a significant incident, and not a simple leak. Failures are promptly repaired, and replacement is not a viable option in response to this type of failure. In other words, there is no "routine" pipeline replacement program for transmission pipelines. Replacements are performed on a

systematic basis; certain vulnerable or mechanically deficient classes of pipe, or pipe in areas of perceived seismic hazard have been identified and are scheduled for long-term replacement. These replacement programs have been authorized by the CPUC. With regard to pre-World War II pipe, the Value Chain Analysis report stated,

As of the early 1980's... it was recognized that the condition of some of this pipe had deteriorated. Also, several reports by consultants indicated that the poor weld quality in pipelines built prior to WWII made them significantly more susceptible to failures during earthquakes. As a result, the Company sought and received authorization from the CPUC for capital expenditures over and above traditional levels to fund a special replacement program.

Priorities are set based on relative risk and the level of approved funding. Transmission's approach is, therefore, generally pro-active - replacements are made in anticipation of possible high cost, high impact failures. Other replacements are made in response to planning issues, such as anticipated or actual changing demands.

3.2 SEISMIC VS. NON-SEISMIC RISKS

Because of the difference in the nature of transmission and distribution systems, different risks will dominate, and failures will have different impacts. Pipeline failures are generally attributed to one of several causes: corrosion, third party damage, material failure, construction defects, or seismic loads. These causes may be grouped into predictable and non-predictable failures. Corrosion effects are generally predictable, while third party damage, construction defects and material failure are not. The unpredictable failure modes, are, for the most part, controllable. The damage caused by seismic loads is certainly quantifiable, but the probability of occurrence must be taken into consideration as well.

3.2.1 Distribution

Gas distribution systems are usually extensive, highly netted, highly redundant networks of mostly small diameter, medium pressure pipe. SoCalGas distribution mains are primarily steel (64.8% as of the end of 1992, according to the annual

report for calendar year 1992), with the remainder comprised of plastic (35.1%), and cast iron (0.01%). Distribution supply lines, which essentially function as transmission lines, are treated in this discussion as transmission lines. Because most repairs can be made to low pressure lines while under pressure, leakage or failure of an individual pipe will have little impact on supply to the surrounding area.

The majority of repairs required by the distribution system are caused by corrosion. For example, a detailed study of a small area within the City of Torrance revealed that 70% of the repairs made between 1970 and 1991 were attributed to corrosion. It is reported that

Company-initiated leakage surveys, routine inspection procedures and pipe replacements in advance of public improvements largely identify and control hazardous conditions which develop slowly over time. Serious leaks, which generate immediate hazards, are primarily related to: 1) materials defects which take years to cause failure; 2) accidental damage by outside forces; or 3) significant events initiated by earthquakes (Strang, 1986).

The majority of risks for Distribution i.e., corrosion risks, are being addressed through the routine pipe repair/replacement program. The remaining risks (material deficiencies and earthquake vulnerability) are currently being included qualitatively under the Special Pipeline Replacement Program.

3.2.2 Transmission

Gas transmission systems are generally non-netted, high pressure systems with limited redundancy. SoCalGas transmission pipelines are exclusively made of steel, and are typically large in diameter. The impact of failure of transmission pipelines, as well as distribution supply lines, may not be insignificant. The transmission system transports gas from out of state, to and from storage fields, and from local producers.

The distribution supply system, operating at higher pressures and larger diameters <than the remainder of the distribution system>, is operationally critical to continued supply during peak demands or emergency conditions. In many cases, these supply lines constitute single sources of supply to large areas, many

within the central city, i.e. Hollywood, Beverly Hills (Strang, 1986).

Corrosion leakage is not expected to be a problem for SoCalGas transmission lines, because of the high priority placed on cathodic protection and monitoring. Between the years of 1983 and 1990, the transmission system averaged only 24 leaks per year, or 0.007 leaks per mile (or 0.004 leaks per km) of pipe per year (SoCalGas, 1991). This can be contrasted to figures for steel without cathodic protection in the distribution system. For the 12 year period between 1973 and 1984, bare steel in the distribution system averaged 1.18 repairs per mile (or 0.73 repairs per km) per year, and coated steel averaged 0.45 repairs per mile (or 0.28 repairs per km) per year (estimated from data provided in Strang, 1986). The transmission system suffers corrosion leakage up to 170 times slower than the unprotected steel in the distribution system.

According to a study by U.K. Gas, rupture of high pressure transmission lines caused by corrosion is unlikely at stress levels below 58% of SMYS (SoCalGas, 1991), and most of the older SoCalGas lines are operated well below this threshold.

The more significant risk to the transmission system are the non-predictable failures - "sudden failure due to unusual loading conditions, usually earthquakes, related to poor construction techniques or materials" (SoCalGas, 1991) Certain pipe classes have been identified as having vulnerable welds. These pipes have failed in the past under unusual loads. Unusual loading conditions include (SoCalGas, 1991):

- pipeline exposure in cold temperatures causing contraction and weld failure,
- use of construction equipment over pipelines cracking welds,
- train derailment, and
- earthquake loads.

The risk and impact of failure due to earthquake loads has been addressed qualitatively by Transmission in the Value Chain Analysis (SoCalGas, 1991). Vulnerable classes of pipe have been identified for replacement based on location through identified seismic hazard zones in areas of population concentration, where the impact of failure would be most significant. Priorities are based on safety, cost, and reliability of delivery.

3.3 PLANNING TIME FRAMES

Because Distribution and Transmission are governed by different risks and replacement procedures, the time frame for replacement planning varies significantly.

Distribution is primarily concerned with the predictable effects of corrosion, and time limitations with respect to public works moratoriums. As a result, the time frame within which Distribution currently operates is five years, as reflected in EPOCH. Links to the System Planning Department are limited - projects require System Planning review only if the cost exceeds \$200,000 or if the project crosses divisional boundaries. It is presumed that Distribution consults the "Master Plan" in designing replacement projects.

On the other hand, because transmission replacement projects involve large capital outlays, it is more closely tied to System Planning. Replacements proceed in anticipation of infrequent earthquake events, in response to anticipated changing loads, and in response to construction projects impacting the pipeline right-of-way. The planning time frame is by necessity, significantly longer than that of Distribution.

SECTION 4

GENERAL METHODOLOGY FOR PIPELINE REPLACEMENT DECISIONS

In this section, a general methodology is outlined for making optimal decisions regarding pipeline replacement. Whereas other parts of this study have focused on individual methods of quantifying seismic or corrosion-related risks, this section begins to define how these risks can be balanced in an overall risk reduction program.

The methodology for optimizing pipeline replacement decisions can be described by seven basic steps, as diagrammed in Figure 4-1. The basic steps apply to both Transmission and Distribution, but the implementation will vary depending upon each department's operation. In each of the first four steps, a weighting factor (based on guidelines to be developed by EQE, Cornell University and SoCalGas) is used to facilitate project prioritization. These factors, designated as P (Pipe factor), D (Demand factor), S (Seismic hazard factor), and O (Other, non-seismic factor) are described in the following sections.


4.1 PIPELINE REPLACEMENT METHODOLOGY FOR TRANSMISSION

Various transmission pipelines have been identified for replacement through a systematic review of pipeline class and location. Other factors may be incorporated into the assessment in a consistent manner.

4.1.1 Review Pipeline Data

This task entails a review of pipeline data for the segment under consideration. Pipeline material (i.e., weld-type), age, diameter, pressure, and cathodic protection are all key factors. Additional emphasis would be placed on operational history. A review of each individual pipeline's operational history might allow for consideration of poor performers in otherwise acceptable pipe classes.

This step also includes determining whether the pipe segment is considered vulnerable or mechanically deficient, or falls into a class of pipe included in previously established long-term replacement programs. All of the information gathered is used to estimate the pipeline data weighting factor (the "P" factor).



2HD 400nb/SCG-FG41

Figure 4-1: General Methodology for Pipeline Replacement Decisions

4.1.2 Review System Planning Department's Long-Term Goals

This phase of the methodology entails checking with System Planning to determine whether the segment under consideration is within or serves an area of changing demand, and is scheduled for upsizing, downsizing, or abandonment. Currently, this data is contained in a hard-copy "Master Plan". This information is used to select replacement pressures or diameters, as well as to compute a "Demand" weighting factor ("D" Factor).

This process could be streamlined with the implementation of Geographic Information System (GIS) methods. A digital map could be developed by System Planning identifying areas of "Planning Concern". Such a map would be "dynamic" and reflect on-going system alterations, identify areas of expected growth or development, and include information on expected loads and service requirements. This map could be made available to Transmission such that a quick on-screen review would indicate future requirements for any pipe in question. Alternatively, if the pipe falls within an area of "Planning Concern", it could be a "flag" requiring a project review by the System Planning Department.

Transmission line replacement is more closely tied to the goals of Planning than Distribution line replacement. Transmission, by nature, must more directly address changing regional demands. System Planning Department input during review of existing lines helps identify the optimal size, pressure and location for a given pipeline. Possible links to distribution projects should also be taken into consideration. This may be accomplished through examination of hard copy plans, on-screen maps or direct System Planning Department input.

4.1.3 Assess Seismic Hazard and Impact of Outage

The main stimulus for transmission line replacement is anticipation of sudden failure due to seismic hazards. Detailed delineation of these hazards is essential for development of a multi-risk decision-making procedure. The implementation of this step presupposes the existence of seismic hazard maps at a scale appropriate for application to the transmission system. Some mapping has been performed in previous studies by consultants, but additional maps would be required. Justification of such expenditures might come in the form of savings gained by reducing the size of hazard areas as currently identified, and the corresponding

reduction in the amount of pipe to be replaced. Because a consistent company-wide approach is preferable, the most likely proponent of systematic hazard mapping would be the System Planning Department. While the areal extent of useful maps varies significantly between Transmission and Distribution, a program to identify hazard areas significant to both systems would, in the long run, save money as well as improve safety and system reliability.

Possible candidate hazards for mapping include surface fault rupture, liquefaction susceptibility, landslide, lateral spread, and strong ground shaking. Information is currently available on the topics of landslide, liquefaction and surface fault rupture. Consideration of these seismic hazards, if available in digital form, would be straightforward to implement. For example, the California Division of Mines and Geology (CDMG) has an on-going program to map active and potentially-active fault traces within the state at a scale of 1 inch = 2,000 feet. These maps are developed and published under the auspices of the Alquist-Priolo Special Studies Zone Act of 1972, and are readily available. Such maps could be consulted in hard-copy map form, or be digitized for automatic on-line overlay. Strong ground shaking maps, if required, could be developed in either probabilistic or scenario-based forms.

For this step in the methodology, available seismic hazard maps are consulted to determine if the pipe segment under study crosses any of the various hazard zones. In conjunction with relative pipeline vulnerability data, this information is used to identify optimal repair/replacement techniques, and replacement material. Alternatively, the presence of the seismic hazard may activate the requirement for a review by System Planning.

The impact of pipeline outage is also considered. If the pipeline in question is a critical transmission or supply line, whose outage would isolate numerous customers, consideration is given to possible relocation, additional redundancy, or placement of isolation valves to limit outage and speed restoration. Such an assessment requires information on service areas, supply, and redundancy. The seismic hazard information and impact assessment are utilized to develop the seismic hazard or "S" weighting factor.

4.1.4 Assess Other Non-Seismic Risks

Additional risks threatening transmission pipelines may be addressed in this step of the methodology. Although the VCA report dismissed the other identified "unusual load" risks for the system as a whole, there may be certain pipeline segments wherein these risks should be considered. Other, as yet unidentified risks, could be easily added into the assessment as well. Any such conditions would be incorporated here into the "Other" risk or "O" Factor.

4.1.5 Select Replacement Strategy

Based on the planning goals, seismic hazard and other risk exposure, an optimal replacement strategy for the transmission line under review is developed. Possible strategies include:

- Do not replace at this time
- Do not replace, but perhaps increase monitoring to track some operational deficiency
- Replace with a specified material, diameter and pressure to address planning concerns within a certain time frame
- Relocate pipeline to avoid seismic hazard (that is, install an alternate line and abandon the more hazardous route)
- Develop an alternate "creative" replacement solution including cooperative planning efforts with Distribution. If the pipeline was subject to a System Planning review, an alternate replacement solution may have been suggested. For example, a System Planning review may indicate that an upgrade of a distribution line would allow for the abandonment of the transmission line scheduled for replacement. A cooperative replacement program would allow for cost savings and system optimization.

4.1.6 Calculate Replacement Costs


This task includes all the cost calculations. Based on local cost data, as well as information on future public works projects, the cost of the replacement strategy as specified by the preceding needs and risk assessments is calculated. The results of this step allow for replacement prioritization that incorporates long-term planning goals, as well as risk reduction measures.

4.1.7 Calculate Priority Factor

The four weighting factors estimated in tasks 1 - 4 are combined to develop one overall weighting factor associated with the replacement strategy. This priority factor allows for the relative ranking of various replacement projects based on the needs and risk assessment. The development of criteria for the Transmission priority factor is a critical element in the application of this methodology. Because of the large expense associated with transmission line replacements, and limited capital budgets, the priority factor will essentially determine the sequence of pipeline replacements. For this reason, substantial attention should be given to the development of guidelines for priority factor calculation, with input and general approval from System Planning and Engineering Design, as well as Transmission and Distribution. While the guidelines are expected to vary between the two operational units, the general approach should be consistent.

4.2 PIPELINE REPLACEMENT METHODOLOGY FOR DISTRIBUTION

The methodology for pipeline replacement for distribution lines is presented in Figure 4-2. The methodology is built around the use of EPOCH, a computer program developed by Distribution to optimize decisions with respect to repair/replacement of pipelines affected by corrosion. Additional elements proposed in this study are steps to insure that opportunities to improve seismic safety through replacement are not lost. These steps are discussed in the following subsections.



2HD 400nb/SCG-Fg42

Figure 4-2: Procedure for Incorporating Seismic Hazard or System Enhancement Data into Pipeline Repair/Replacement Decisions for Distribution

4.2.1 Review Planning Data

In this step, two types of planning data are reviewed. First, data identifying future changes to the system are reviewed. When changes are anticipated or planned, this information may be used by Distribution to help decide when and how replacement of a particular pipe segment should be accomplished.

In the case of seismic hazards, maps could be available for planning purposes to identify opportunities to improve the seismic safety of the system. Based on criteria that would be established by Engineering and Distribution, any significant benefit, with respect to seismic safety, resulting from replacement would be noted.

One possible basis for this criteria could be the degree of seismic hazard and the seismic vulnerability of the pipe segment. Certain combinations of these two parameters would lead to significant seismic safety benefits through replacement. The results of this review, combined with the results from EPOCH, could lead to replacement decisions that incorporate not only economic considerations but safety considerations as well.

4.2.2 Run EPOCH

In this step, the computer program EPOCH would be run to identify the economic benefits of repair versus replacement. This analysis would be run with the updated models for corrosion leakage. Based on the results of this analysis, pipelines would be classified into one of three categories according to economic considerations:

1. Pipelines that should be replaced.
2. Pipelines that should be repaired.
3. Pipelines that are marginal, i.e., the cost difference between the two options is considered small, and the pipeline could either be replaced or repaired.

In general, the assignment to each of these categories will be based on the expected costs associated with mitigating the effects of corrosion. Categories 1 and 2 should reflect firm decisions based primarily on minimizing future costs. Category 3 can result in 1 or 2, with the addition of information on future growth plans or seismic hazard levels.

4.2.3 Post-EPOCH Analysis

If the results of EPOCH suggest that the best mitigation option is to replace the pipe, then replacement incorporates prudent decisions regarding seismic design or future growth.

If the results of EPOCH indicate that repair rather than replacement is, by far, the best option or strategy, then seismic design and other considerations should be postponed until that pipe segment is re-evaluated.

If, however, the results of EPOCH fall into category 3, that is, a borderline decision to repair or replace, then the results of the seismic and planning review could be used to encourage replacement, if significant benefits would result. If however, no benefits are identified, repair is warranted. By incorporating this added step, Distribution will realize the following benefits:

1. Maintain EPOCH as the primary decision tool for deciding the repair or replacement issue.
2. In marginal cases, decisions can be made to improve the safety and reliability of the system.
3. The integration of this added step would insure that Distribution maintains a proactive program to balance all risks in their evaluations.

In order to test this strategy as an effective method for considering all risks, it is recommended that this procedure be tested in a small portion of the SoCalGas service area. In testing this procedure, the results from both the current seismic study and the corrosion analysis would be used. One possible area for this evaluation would be the Torrance area on which both the Cornell and EQE studies have focused.

SECTION 5

REFINED PREDICTIVE MODELS FOR CORROSION LEAKAGE

During the course of this study, a topic identified by Distribution as requiring further investigation was the development of a more comprehensive corrosion leakage model. Although current methods for predicting corrosion leakage appear to be effective when sufficient repair data are available, there are numerous cases where sufficient data do not exist. For these cases, alternative methods were sought.

To evaluate the current procedure utilized by Distribution to project future leakage due to corrosion, a detailed analysis was performed on a small portion of the Distribution system. The purpose of this pilot study was to determine if an alternate model to predict leakage could be developed from available information. This section presents a brief summary of the pilot study results - the full text of the report is contained in Appendix B.

5.1 PILOT STUDY DATA

The pilot area chosen was a small area within the City of Torrance. This area was selected because it is representative of somewhat older areas experiencing problems related to corrosion. Pipeline maps, including atlas sheets, leak history and leak detection survey maps were collected for the 5 atlas sheet study area. In addition, Distribution supplied a detailed data file, extracted from their Leak Repair Order (LRO) database, that contained repair information recorded for the period 1970-1992.

The majority of recorded main leaks were associated with individual homogeneous (with respect to age, material, diameter, cathodic protection) pipeline segments. A comparison of the leak history maps to the LRO data led to the conclusion that the history maps may provide an incomplete picture of actual segment leakage over time. Only 66% of noted main repairs from the LRO data were shown on the plotted history maps.

5.2 ASSESSMENT OF LINEAR REGRESSION PREDICTION TECHNIQUE

The linear regression technique currently used by Distribution to predict future pipeline leakage was tested (See Appendix A for an explanation of the Linear Regression or Least Squares Statistical Method). Cumulative leak rates (cumulative leaks per 1000 feet of pipe) for individual pipeline segments were plotted versus pipeline age. (Equivalent leaks per kilometer can be computed by multiplying leak rates in thousands of feet by 3.28). A "best-fit" line was developed and plotted, to predict subsequent leakage. Figure 5-1 provides sample results for pipe installed in 1912. As can be seen in the figure, linear regression techniques yield good predictions when sufficient data exists. For the test cases, half of the predictions were within 10% of actual, while 70% were within 27%. The major weakness of this approach is that future performance predictions cannot be made reliably when data are limited (i.e., one historic leak occurrence).

5.3 ALTERNATIVE LEAK PREDICTION METHODOLOGY - THE AGE DEPENDENT MODEL

To enhance prediction in those cases where limited historical leakage exists, an alternate "age dependent" predictive model was developed, based on the pipeline's age at instance of first leak¹. It was noted from an analysis of the Torrance data, that the rate at which leak rates increase tended to increase with age at first leak. That is, leak rates increased more quickly on older pipe segments than on newer ones. A regression model relating slope of the leak rate to age at first leak in log-linear space was developed for several sample classes of pipe. Figure 5-2 presents a sample model, for steel pipe installed in 1912.


It must be noted here that pipeline segments with high leak rates at younger ages that were subsequently replaced were removed from this data set. This action is explained by noting that the models being developed would be used on pipe with normal corrosion performance, i.e., not exhibiting excessive repairs in short performance periods. In essence, this led to the elimination of all pipe repair data

¹ Note that this leak is the first recorded leak listed in the Leak Repair Order (LRO) database, which begins after 1970. Leaks that may have been repaired prior to 1970 are not included in the present analysis.


associated with pipes that had been replaced between 1970 - 1992. Appendix A discusses more fully the rationale behind this action.

The age dependent model was tested for the same pipeline segments used in the assessment of linear regression techniques. This comparison is graphically

Segment 9-6A




Segment 9-14A




5-4

Segment 10-39A



Segment 16-4



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986

Figure 5-1: Comparison of Leak Rate Prediction from Linear Regression of Data through 1986 to Actual Post-1986 Performance (Pipe Installed in 1912)




Figure 5-2: Age Dependent Leak Rate Model for Steel Pipe Installed in 1912

displayed in Figure 5-3. This alternative model was shown to be as good as the linear regression model for segments with extensive leakage histories. The model was also evaluated for pipeline segments with minimal leakage histories, as shown in Figure 5-4. This evaluation showed that the model is able to predict leakage within 15% of actual performance in the majority of cases (2/3) for segments with limited historical leakage.

5.4 CONCLUSIONS AND RECOMMENDATIONS FROM THE PILOT STUDY

Several conclusions and recommendations resulted from the pilot study assessment of leakage prediction techniques. These are repeated here:


Conclusions from the Torrance pilot study:

- 1) The current method of leakage prediction is effective when sufficient leak data exists (i.e., at least three years with leakage)
- 2) Utilizing the leak history maps to represent historical leakage may underestimate leakage because the map updating procedure which entails physical patching often obscures data, and reporting practices may have varied over time. Other sources of data are available, including the Leak Repair Order database, which includes every pipeline repair made since 1970.
- 3) An alternative method (the age dependent model) for verifying linear regression predictions and/or estimating pipeline leakage based on limited leakage data can be developed.


In addition to the above conclusions, the following recommendations are made:

- 1) Since the pilot area used in this study was relatively small, a second analysis is recommended to confirm the trends developed in this first phase. This recommendation should only be implemented if the ability to estimate future leak rates based on limited data is important from the standpoint of the EPOCH program.

Segment 9-6A




Segment 9-14A




5-7

Segment 10-39A



Segment 16-4




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986 — Age Dependent Model Prediction


2HD 400nb/S-6A-L

Figure 5-3: Comparison of Leak Rates Predicted from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1912)

Segment 15-13




Segment 9-13



5-8

Segment 9-13A



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Age Dependent Model Prediction

2HD 400nb/15-13-R

Figure 5-4: Comparison of Predicted Leak Rates from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1927 with Limited Leakage)

- 2) If further study is justified in this area, two areas are suggested for further study. The first area should be similar, although larger in size, to the Torrance area analyzed in the first phase. The purpose of this assessment will be to confirm the trends observed in the pilot study. In general, the models developed would have the most applicability to these older areas. A second, newer area should be selected to determine if similar models can be developed for other parts of the service area.

- 3) The same type of analysis could be applied to other pipe classes. Although most corrosion problems appear to affect pre-1936 bare pipe without cathodic protection, there are a limited number of other pipe classes that are also affected by corrosion. One such candidate pipe class is poorly coated steel pipe, without cathodic protection, installed between 1941 and 1957.

SECTION 6

RECOMMENDED REFINEMENTS FOR IMPROVED DECISION-MAKING CAPABILITIES

In this section, recommended refinements to improve SoCalGas's company-wide replacement decision-making capability are presented. Three areas are highlighted: Mapping and Records, Interaction with System Planning, and Incorporation of Seismic Risks.

6.1 MAPPING AND RECORDS

During the course of this study, possible improvements for future record keeping practices as well as several schemes to take advantage of the proposed GIS system were identified.

It was noted as a result of the Distribution pilot study that the utilization of leak history maps as the basis of future leakage predictions may be misleading due to possible incomplete recordation of leaks. Improvements in the record keeping process may be as simple as developing official guidelines for leak recordation, including a simple box to check on the leak repair order form. When this data is entered into the LRO database, it will then be possible to tell if the leak has been noted on the map, and a reminder generated if it has not.

With the implementation of a SoCalGas GIS, certain features could be incorporated into the GIS design to enhance operations of Distribution, Transmission and System Planning. For Distribution record-keeping purposes, the leak history map could be digitized, and be available for on-screen leak notation. The dynamic quality of the map would reflect daily activities, and be available to more than one user at a time. In addition, a database consisting of all information currently in the LRO database could be linked to the map file, allowing for inspection of detailed leak information simply by selecting the noted leak location. Eventually, such information could be tied to EPOCH to allow for retrieval of leakage information on specific pipeline segments automatically.

The GIS would also be an efficient platform to allow timely review of System Planning information during the replacement evaluation process. The development

of digital seismic hazard maps, and various planning maps such as "Master Plan" maps, load maps, or areas of "Planning Concern" would speed up the review process. These planning maps would be "dynamic", available on-line, and able to reflect on-going system alterations.

6.2 INTERACTION WITH SYSTEM PLANNING

A significant opportunity exists to link the efforts of Transmission and System Planning, and Distribution and System Planning. For the tasks of recording proposed changes to the system, or maintaining detailed data on seismic hazards, it seems appropriate for the System Planning Department to play a key role. Presumably, detailed data on proposed changes to the system are already being maintained by System Planning. This information, if available in a convenient format for all users, could be accessed by the other departments. This would insure that system information is used consistently by all departments.

With respect to seismic hazard conditions, if detailed maps are developed and maintained by Planning, decisions regarding opportunities for improving seismic safety can be made in a consistent manner by all departments. At this point, the following maps been further investigated:

- Potential Surface Fault Rupture Maps (Alquist-Priolo Fault Maps)
- Liquefaction Susceptibility or Potential Maps (Refinements made by Professor T. O'Rourke of Cornell University)
- Maps identifying areas of significant strong ground motion amplification (e.g., areas overlying soft soils, or deep alluvial deposits)

6.3 INCORPORATION OF SEISMIC RISKS

An area deserving special attention is the incorporation of seismic risks into Distribution planning efforts. As outlined in Section 4.2., a methodology for incorporating seismic risks into the current pipe/replacement format is recommended. Performing this task would help to insure that not only are

economic considerations addressed in pipe replacement, but safety and reliability as well.

It was further recommended that this procedure be tested in the Torrance area where extensive work has already been performed by the Project Team on seismic and corrosion problems.

SECTION 7 REFERENCES

- O'Rourke, T.D. and M. C. Palmer (1994), "Feasibility Study of Replacement Procedures and Earthquake Performance Related to Gas Transmission Pipelines," NCEER Report No. 94-0012.
- Southern California Gas Company (1991), "Value Chain Analysis of the Pre-WWII Transmission Pipeline Replacement Program."
- Southern California Gas Company (1992), "Annual Report for Calendar Year 1992; Gas Distribution System."
- Strang, G.E. (1986), "Underground Piping System Replacement," Southern California Gas Company Engineering Report.



APPENDIX A

EXPLANATION OF LEAST SQUARES METHOD

If a number of data point pairs (x,y) exist and are assumed to be linearly related, the "best-fit" line through these points can be determined using a "least squares" approach. According to the principle of least squares, "... a line provides a good fit to the data if the vertical distances (deviations) from the observed points are small. The measure of goodness of fit is the sum of the squares of these deviations. The best-fit line is then the one having the smallest possible sum of squared deviations" (Devore, 1982). In other words, a "least-squares" fit or a simple linear regression analysis is the process of defining the constants m and b to fill the equation of the line, $y = mx + b$, such that the variance between the actual (observed) value of y , and the value predicted by the equation is minimized.

In practice, for a given data set $\{(x_1, y_1) \dots (x_n, y_n)\}$, the constants defining the equation of the best-fit line may be determined as follows:

$$m = \frac{n \sum(x_i y_i) - (\sum x_i)(\sum y_i)}{n \sum x_i^2 - (\sum x_i)^2}, \quad \text{and}$$

$$b = \frac{\sum y_i - m \sum x_i}{n}$$

where;

n = number of (x,y) pairs

REF:

Devore, Jay L. (1982), Probability and Statistics for Engineering and the Sciences, Brooks/Cole Publishing Company, Belmont, California

APPENDIX B
RESULTS OF DISTRIBUTION STUDY:
“AN ASSESSMENT OF CORROSION LEAKAGE MODELS-APPLICATION TO
SOUTHERN CALIFORNIA GAS COMPANY DISTRIBUTION PIPELINES”

In June of 1992, the Southern California Gas Company (SoCalGas) entered into an agreement with EQE International and Cornell University to perform an independent assessment of current SoCalGas pipe repair and replacement strategies. The overall program focused on risk assessment, economic and safety issues. The purpose of this particular report is to summarize the project team's investigation of current SoCalGas leak prediction methods for distribution piping, and to suggest ways of improving these methods. Other topics related to earthquake risk and safety, and cost-benefit methods for determining pipe replacement are discussed in other project reports.

The estimation of future pipeline leaks is a concern shared by many owners and operators of natural gas distribution systems. The decision to replace or repair a damaged line often depends upon how the cost to replace compares to the anticipated costs of future repairs without replacement. Generally, the models that are used to estimate future leak rates are based on past pipeline repair data. Statistical models are developed that correlate expected leak rates with pipe material types, pipe age and corrosion protection. As with most models of this type, predictions are generally reliable as long as ample data is available.

Some of the factors that contribute to poor pipeline performance or damage are high soil corrosivities, high pipe-to-soil potentials, mechanical deficiencies, such as improperly screwed joints, and accidents caused by third party damage. In most cases, however, the only failures that can reasonably be predicted are corrosion-related failures.

Modern procedures for corrosion control are generally quite effective. Physical application of pipe coatings to steel pipe extends the life of the pipe many years. Cathodic protection applied to bare and coated steel pipes can also mitigate the effect of corrosion. In addition, many operating companies are installing pipe whose materials are not susceptible to corrosion, i.e., plastic. In summary,

corrosion failures appear to be limited to older pipes that were installed without corrosion protection.

The Southern California Gas Company distribution system currently serves 4.65 million customers (P&GJ, 1992) throughout the southern California area. The company has been in existence since the early 1920s. In these early periods, it was common for bare steel pipe without cathodic protection to be installed.

In order to address the corrosion problem, Distribution initiated an aggressive program of cathodic protection and pipe repair and replacement. To determine whether particular pipe segments ought to be replaced or repaired, SoCalGas has developed an in-house computer program, Efficient Pipeline Operation in a Competitive Habitat (EPOCH), that forecasts future leaks and repair costs. The methodology considers three options using a five-year time frame; pipe replacement, repair and installation of cathodic protection, and repair without cathodic protection. An economic analysis compares the estimated costs associated with each of these options.

One of the areas that has concerned SoCalGas personnel is (1) whether the company is maximizing the use of all available pipe repair data, and (2) whether the statistical models that were being developed for use in the EPOCH program were reasonable predictors of future performance. These issues are addressed in the present report.

The rest of this appendix comprises five sections. Section B.1 describes the data received from SoCalGas Distribution. Included is a discussion of available data for the pilot study area where pipeline repair statistics were analyzed. Section B.2 discusses the development of the pipeline databases. The characteristics of exposed distribution pipelines in the study area are discussed in detail. Section B.3 reviews the current SoCalGas Distribution procedure for estimating future corrosion leaks and tests it with data collected in the pilot study area. Section B.4 presents an alternate corrosion prediction model that incorporates the age of first leak as a model parameter. The results show that the inclusion of this new parameter in the development of corrosion prediction models increases the number of cases in which corrosion predictions can be made. Finally, the major conclusions of this study are presented along with recommendations to further improve corrosion prediction modeling for all of SoCalGas's distribution pipelines.

B.1 DATA RECEIVED FROM SOCALGAS

Data received from SoCalGas may be divided into two categories: general system information, and information specific to the Torrance study area.

B.1.1 System Information

A review of general system information was performed to determine the relation of the small study area to the overall system. The primary source of piping information was a 1986 Engineering Department report entitled "Underground Piping System Replacement Assessment". Included in this report is a piping system breakdown by pipeline family, summarized for non-service facilities in Table B-1.

| Table B-1 SoCalGas Pipe Families (Not Including Services) | | | | | | |
|--|---------|------------------|---------------------|------------------------|----------------------|------|
| Pipe Material | Coating | Installation Era | Cathodic Protection | Length of Pipe (Miles) | Length of Pipe (Kms) | % |
| Steel | Bare | Pre-1936 | Not Specified | 2,285 | 1,420 | 6.3 |
| | | Post-1936 | Unprotected | 2,897 | 1,801 | 8.0 |
| | | Post-1936 | Protected | 173 | 108 | 0.5 |
| | Coated | 1936-1949 | Not Specified | 4,585 | 2,850 | 12.6 |
| | | 1949-1971 | Unprotected | 4,830 | 3,002 | 13.3 |
| | | 1949-1971 | Protected | 9,780 | 6,078 | 26.9 |
| Post-1971 | | Protected | 3,625 | 2,253 | 10.0 | |
| Plastic | | | 8,050 | 5,003 | 22.2 | |
| Copper | | | 60 | 37 | 0.2 | |
| Cast Iron | | | 58 | 36 | 0.2 | |
| TOTAL MAINS | | | | 36,343 | 22,588 | |

B.1.2 Torrance Study Area Data

Detailed data for the selected study area within the City of Torrance was provided by Distribution and the South Coastal Division. The study area was limited to five SoCalGas atlas sheets - Torrance 9, 10, 15, 16 and 17. The boundary of the study area is shown on Figure B-1. For each of these atlas sheets, the following mapped information was collected:

- atlas sheets indicating pipeline material, diameter, date of installation, cathodic protection (CP) and pressure
- leak history maps (scale: 1 inch = 100 feet), which indicate the location and date of repairs attributed to corrosion, material failure, and construction defects. (The notation of mechanical leak repairs is optional.) This map set is updated upon pipe replacement by physically covering previous information by fastening a xerox of the revised atlas sheet pipe section directly to the history map.
- records of recent leak detection surveys

In addition to the mapped information, the SoCalGas Leak Repair Order (LRO) database for the 5 listed atlas sheets was provided. The LRO database covers the years 1970 through 1992, and includes the repair location, leak code, leak cause, repair date, and miscellaneous pipeline information (diameter, material, year of installation, main/service, etc.). A total of 491 main leaks are listed for the 5 subject atlas sheets.




Figure B-1: Torrance Study Area

B.2 ANALYSIS OF TORRANCE AREA DATA

The analysis of the Torrance study area required the development of two complimentary databases; a pipeline segment database and a segment leak database. The correlation of the two data sets allows for the comparison of pipe leakage according to material, diameter, age, and unit length.

B.2.1 Development of Pipeline Segment Database

For each atlas sheet, individual pipeline segments were defined to be homogeneous with respect to pipeline diameter, material, cathodic protection, and age. That is, a change in material or diameter would be reflected by the definition of a separate segment. Only mains were included (i.e., no service pipe), and pipe coating was not part of the data available from the collected information. For each segment, the total length in feet was scaled from the leak history maps. Small index maps identifying pipeline segment names and locations, as well as a printout of the pipeline segment database are provided in Appendix C.

A total of approximately 20 miles (32.2 kms) of main are located within the study area - 26% plastic, 27% steel without CP, and 47% steel with CP. Detailed descriptions of each pipe group are as follows:

- The plastic pipe in use in this area is primarily 2 inches in diameter. All plastic piping was installed after 1978.
- Two-thirds of the steel pipe that is currently not under CP was installed prior to 1936. The remainder was installed prior to 1971, when it became the company standard that all steel pipe should be coated, and put under CP within one year of installation.
- Half of the steel pipe with CP was installed prior to 1971, but information detailing when the segment was actually put under CP was not among the available data, and may be some time after installation.
- While no specific coating information was available for the pipelines in the Torrance area, some generalizations may be

made according to historic installation practices (Strang, 1986). Pipe installed prior to 1936 may be assumed bare. All steel pipe installed after 1971 are required to be cathodically protected. According to SoCalGas data, approximately 82% of steel mains in place, as of the end of 1992, are coated, while the remaining 18% are bare (SoCalGas Annual Report for Calendar Year 1992). (The majority of this uncoated pipe is not cathodically protected.) For installation between the years of 1936 to 1941, and after 1958, the coated pipe may be assumed to have a "good" coating, while those put in place between the years of 1942-1957 may be considered to have "poor" coating (Strang, 1986).

The distribution of pipe types within the study area may be compared to system-wide statistics to determine if the selected study area is a representative sample.

- System-wide, 35% of all mains are plastic. Within the Torrance study area, 26% of mains are plastic.
- The Torrance study area has a higher percentage of steel pipe under cathodic protection than the system average. Approximately 56% of steel pipe is under cathodic protection system-wide (SoCalGas, 1992), while within the Torrance area, about 63% of the steel pipe has CP.
- The study area has a higher percentage of older and newer steel pipe than the system average. Overall, most of the system (79%) was installed between 1936 and 1970 (Strang, 1986), while that percentage for the study area is 48%. 8% of all SoCalGas steel mains were installed prior to 1936 vs. 26% of the steel pipe in the Torrance study area. Similarly, 13% of the system was installed in 1971 or after (Strang, 1986), vs. 26% for the study area.

B.2.2 Leak Assignments

Having identified pipeline segments and their characteristics, it was necessary to associate leak repairs as reported in the LRO database with individual pipeline segments. This required physically locating each repair in the LRO database on the leak history map or atlas sheet, according to address or location. This task was facilitated through the use of address map book pages from the City of Torrance, indicating street addresses for various lots. Verification of leak assignments made on the basis of location was possible, to some extent, through cross-referencing of pipeline data tabulated in the LRO database. For example, if the LRO location was an intersection containing two perpendicular pipes, assignment could usually be made by matching the pipe diameter or installation date in the LRO database with the same information in the pipeline segment database. In this way, virtually all main leaks were associated with an individual pipeline segment. A printout of this leak database is provided in Appendix D.

Of the 491 main leaks indicated in the LRO database, 32 were unlocatable. For some of these repairs, the address/location was a vague description, and the local pipes were similar enough to make a definitive assignment impossible. In other cases, repair addresses were physically on a different atlas sheet not included in the study area. Of the remaining 459 leaks, 70% (322 leaks) were attributed to corrosion, 1% (5 leaks) to material failure, and 2% (8 leaks) to construction defects. An additional 19% (88 leaks) were classified as "other" causes. This category includes mechanical leaks such as thread leaks. The remainder were classified as "outside or third party damage" (2%) or "unknown" causes (6%) which includes cases of repair or replacement when the leak itself was not physically exposed.

Because the LRO data included all leak repairs made between the years of 1970 and 1992, it was possible to determine pipe characteristics for pipeline segments that were subsequently replaced. For example, a pipeline segment replaced in 1986 will likely have its history concealed on the leak history map, but the LRO for years prior to 1986 will indicate the pipeline material, diameter and original installation date. This information was used to determine the "previous" pipe information for various pipeline segments, and allowed the "previous" pipeline segments and their leaks to be included in the leakage analysis. This information is included in the pipeline segment database in Appendix C.

B.2.3 Summary of Corrosion Leakage Data

Steel pipeline segments may be grouped into various categories, as follows:

- A) Steel pipe under CP
- B) Steel pipe without CP, installed pre-1936 (considered bare)
- C) Steel pipe without CP, installed between 1936 and 1971 (predominantly coated)
 - C1) 1936 - 1940, and 1958 - 1970 - "good" coating
 - C2) 1941 - 1957 - "poor" coating

For the steel pipe, The majority of the 322 corrosion repairs recorded in the LRO were assigned to Category B pipe (278 repairs, or 86%), making this data set the most suitable for detailed analysis. The remainder were distributed as follows;

- Category A - 24 repairs (7%)
- Category C2 - 15 repairs (5%)
- Category C1 - 5 repairs (2%)

B.2.4 Comparison of LRO Data to the Leak History Maps

By physically plotting all listed repairs onto the leak history maps, it was possible to assess the completeness of the data as plotted by SoCalGas. According to SoCalGas personnel (personal communication with Mr. Ron Hammer, November, 1992), all repairs of leaks caused by corrosion, material failure, or construction defects should be posted on the leak history maps (leak causes 1 - 3, 9 and 10, respectively in the LRO database). Posting of mechanical or joint leaks is optional (these leaks are included in LRO leak cause 11 - "Other").

To make a comparison between the history maps and the LRO database, only those pipeline segments whose history for the years 1970 to 1992 is visible on the leak history maps may be used. That is, only segments that were not replaced during that time period, and have not had their leak history concealed are included. Of the 322 corrosion leaks included in the LRO database, 178 are on pipeline sections with visible history. Approximately 66% of these repairs were actually plotted on the maps by SoCalGas. Percentages according to leak code are as follows:

- approximately 58% of all Code 1 leaks on visible sections were noted on the map,
- approximately 69% of all Code 2 leaks, and
- approximately 68% of all Code 3 leaks.

While few of the repairs within the LRO database were caused by construction defects or material failure, virtually none of these repairs were indicated on visible segments. In addition, it appears that only 17% of repairs due to "other" causes on visible segments are plotted (plotting of these repairs is optional).

It is possible, therefore, that using leak data from the leak history map may provide an incomplete picture of actual segment leakage over time. While the history maps do contain information prior to the 1970 start date of the LRO database, it does not appear that the mapped information is a comprehensive record.

B.2.5 General Approach for Calculating Leak Rates

Cumulative leak rates, or the total number of historic leaks developed by a pipeline segment per unit length, can form the basis for the prediction of future pipeline performance. Using pipeline characteristics and leak data, it was possible to develop cumulative leak rate histories for individual pipeline segments, and alternatively, to group all pipe of a particular category together to develop a "system" leak rate curve for that pipe class. Leak rates were developed according to pipe age at the time of leak occurrence. For the system analysis, pipe and associated leaks were aggregated according to the categories listed in Section B.2.3.

B.3 ASSESSMENT OF SIMPLE LINEAR REGRESSION APPROACH FOR LEAK PREDICTION

Currently, the repair/replace decision-making program utilized by SoCalGas includes the ability to predict future leakage from available pipeline data. Historical leakage data is taken from the leak history maps, and a standard least squares fit of the data is used to project future leakage on individual pipeline segments. This section discusses the method used to test the validity of this approach.


B.3.1 Test Method

To test the validity of a simple linear regression model for pipeline leakage, the following procedure was used:


- Historical leakage from the LRO database was used. This database is considered to be more comprehensive for post-1970 data because no data is lost during the map update process. The database was segregated into two data sets: data through 1986, and post-1986 data.
- A simple linear regression was performed on the data set through 1986. Cumulative leak rates (cumulative leaks per 1,000 feet of pipe) for individual pipeline segments were plotted versus pipeline age. A "best-fit" line was developed to predict subsequent leakage.
- Actual post-1986 performance was plotted and compared to predicted performance.

For the pre-1936 steel pipe data set (accounting for 86% of all corrosion leaks in the LRO database), 10 non-replaced segments had sufficient data to be included in the assessment. To be included, pipeline segments had to meet three critical requirements: 1) the segment must not have been replaced, 2) the segment must have sufficient data through 1986 to perform a linear regression (at least 2 years with reported leakage), and 3) actual post-1986 leakage data must exist to compare to the prediction. Figures B-2 through B-5 present the test results for the 10 segments, in three data sets; pipe installed in 1912 (Figures B-2 and


Segment 9-6A




Segment 9-14A



Segment 10-39A




Segment 16-4



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986

Figure B-2: Comparison of Leak Rate Prediction from Linear Regression of Data through 1986 to Actual Post-1986 Performance (Pipe Installed in 1912)


Segment 16-16




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data --- Least Squares Fit of Data Through 1986

Figure B-3: Comparison of Leak Rate Prediction from Linear Regression of Data through 1986 to Actual Post-1986 Performance (Pipe Installed in 1912)

Segment 10-19D




Segment 16-15



B-14

Segment 16-17




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986


2HD 400nb/10-19DL2

Figure B-4: Comparison of Leak Rate Prediction from Linear Regression of Data through 1986 to Actual Post-1986 Performance (Pipe Installed in 1913)

Segment 10-12C



Segment 15-8A



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986

Figure B-5: Comparison of Leak Rate Prediction from Linear Regression of Data through 1986 to Actual Post-1986 Performance (Pipe Installed in 1927)

B-3), 1913 (Figure B-4) and 1927 (Figure B-5). These three pipe categories represent roughly 60% of all non-replaced pre-1936 steel pipe. (The remaining 40% is divided among 14 different installation years.)

B.3.2 Results

As shown in the figures, the linear regression technique is a good predictor of actual performance when sufficient data exists (i.e., more than three data points), but the accuracy tends to decrease with decreasing data. For the 10 sample segments, 50% of the predictions at the age of last recorded post-86 leak were within 10% of the actual performance. Figure B-6 presents the distribution of the difference between predicted and actual performance for the straight line regression technique. It should be noted, however, that only pipeline segments with leakage in at least two years are included in this prediction assessment. No prediction can be made for segments with only one leak.

B.3.3 Strengths and Weaknesses of Simple Linear Regression Model

Strengths and weaknesses of the linear regression approach may be summarized as follows:

Strengths:

- With sufficient data, the linear regression model provides a good predictor of future pipeline leak rates.
- By incorporating each individual segment's leakage history in the analysis, it is possible to include localized factors that might influence leak rates.
- The method is simple to develop and easy to use.

Weaknesses:

- This method can not predict future performance based on limited data (i.e., 1 data point).
- Accuracy decreases with fewer data points.




Figure B-6: Percent Difference Between Predicted and Actual Leak Rates using Simple Linear Regression techniques

- A least squares regression model developed from data on the leak history maps may not include all available data, and accuracy of prediction may be reduced.

B.4 DEVELOPMENT OF ALTERNATIVE LEAK PREDICTION METHODOLOGY: AGE DEPENDENT MODEL

Because the simple linear regression approach had several weaknesses, the possibility of developing a supplemental approach to leak prediction based on available data was explored. A variety of approaches were taken, and an alternative leak prediction model was developed. This section describes the development of the supplemental "age dependent" model. In this particular context, age is defined as the age of the pipe at the first observed leak. Note, that the database used in this study begins in 1970; therefore, it is possible that earlier leaks (before 1970) occurred which were not included in this analysis.

B.4.1 Development of the System Curve

For all pre-1936 steel pipe, the total number of leaks, and the age at which they occurred were tabulated using the 1970 - 1992 LRO data. Similarly, the total amount of pipe of a particular age in the ground was determined. For example, a steel pipeline segment installed in 1913 would contribute to the appropriate steel family for ages 57 - 79. If listed repairs occurred in 1975, 1980 and 1984, these leaks would contribute to ages 62, 67, and 71. Pipe that was replaced at some point during the 22 years of detailed data must be treated somewhat differently. In order to reflect the fact that the pipe is removed from the ground, the corresponding data must also be removed from the database. If the example pipe referenced above was replaced in 1986, its length would only contribute through age 73. In addition, its leaks must also be removed following replacement.

Figure B-7 presents cumulative leak rates versus age for replaced and non-replaced pre-1936 steel pipe without cathodic protection. As is evident in the figure, the trends reflected by the two categories of pipe are quite different. For the replaced pipe, the trend reflects a series of upward and downward slopes. In large part, the downward trends are attributed to pipeline replacement, and associated removal of data. In addition, the initial cumulative leak rates for replaced pipe (i.e., for ages 45 to 55) are higher than those for non-replaced pipe for the same age range.






Figure B-7: Cumulative Corrosion Leak Rates for Pre-1936 Steel Pipe without Cathodic Protection

According to discussions with SoCalGas personnel, some types of steel pipe experience rapid increases in repair rates, even at fairly young ages. Because of these high rates of initial repair, these pipelines were replaced even though the pipes were quite young. Since the focus of this particular study is to develop methods to identify when to repair and when to replace pipe based on long-term data, it was decided to exclude the replaced pipe information. The decision to replace pipe with extremely high repair rates usually does not require a sophisticated cost-benefit analysis. Where cost-benefit analysis can play a meaningful role is in deciding whether replacement will offset long-term repair costs.

It is important to note that the combination of the two curves in Figure B-7 reflect the total performance of pre-1936 steel pipe in this particular area. It is difficult to determine whether the higher slopes in the replaced pipe actually reflect leaks that occurred at earlier pipe ages since the data set that was used in this study only begins in 1970. In order to resolve this issue, i.e., higher slopes at earlier pipe ages, it would be prudent to investigate repair data beginning before 1970, and perhaps data from other parts of the system.

It may be possible that the trends observed in this study are unique to this particular service area. Therefore, before the models can be used for other areas, more analysis would have to be performed to justify the current trends and to determine whether they are system wide. This particular recommendation should be implemented only if SoCalGas personnel find the ability to estimate future leak rates based on one or two data points important.

Having plotted individual segment performance for the assessment of the linear regression model, it was noted that the slope of the best fit line appeared to increase with increasing age of first leak. That is, it appeared that the rate of increase in leak rate was higher for leaks striking older pipe. Figure B-8 displays individual pipeline segment leakage histories for the ten sample segments plotted with the non-replaced system curve. The general trend appears to be increasing slope with increasing age at first leak.



2HD 400nb/SYS-1912

Figure B-8: Plot of Individual Pipe Segment Leakage Histories on the Cumulative Corrosion Leak Rate Curve

B.4.2 Development of Age Dependent Model

It was clear that the predictive model should capture this variation with age at first leak, as well as reflect differences in installation practices over time. The resulting model relates slope of the leak rate to age at first leak, for pipe installed in various years. For this pilot application, pipe installed in the years 1912, 1913 and 1927 were used to represent pipe in the pre-1936 steel class. (As mentioned before, these sub-classes represent 60% of all non-replaced pre-1936 steel pipe without cathodic protection.)

For each pipeline segment installed in a given year, the slope of the best fit line for leak rate data through 1986 (developed for the linear regression analysis) was plotted against age at first leak. This data appeared to be linear in semi-log space, so a regression analysis was performed to determine the log-linear best fit line. For the 1912 and 1927 data sets, these lines were determined by 5 and 3 data points, respectively. Figure B-9 and B-10 present the resultant leak rate models for these installation years. The 1913 data set produced only 2 data points, which were deemed insufficient to develop a reliable best-fit line. In this case, the data from 1912, 1913 and 1927 were merged into one data set to develop a generalized leak rate model to be used in predictions for the 1913 data. This model is presented in Figure B-11.

B.4.3 Testing of Age Dependent Model

The testing of the age dependent model consisted of two basic tasks: 1) evaluate the performance of the age dependent model for segments with extensive leakage history (for which the linear regression model works well), and 2) evaluate its performance for segments with minimal leakage history (for which no linear regression model can be developed).

B.4.3.1 EVALUATION OF AGE DEPENDENT MODEL FOR SEGMENTS WITH EXTENSIVE LEAKAGE HISTORIES

To test the accuracy of the predictive model for segments with extensive leakage, the same 10 segments used for testing the linear regression model were utilized. For each pipeline segment, the age at first leak was used to determine the slope of the predictor line from the age dependent leak models (Figures B-9 through B-11).




Figure B-9: Age Dependent Leak Rate Model for Steel Pipe Installed in 1912




Figure B-10: Age Dependent leak Rate Model for Steel Pipe Installed in 1927




Figure B-11: General Age Dependent Leak Rate Model for Pre-1936 Steel Pipe

From the point of first leak, a line with this slope was drawn. Figures B-12 through B-15 present the results of this evaluation. On each figure, the solid line represents the age dependent model prediction, while the dashed line represents the linear regression prediction.


In most cases, the age dependent model is approximately as good or a better predictor than the linear regression model. The average difference between actual and predicted performance for these 10 pipeline segments is 25.7% for the age dependent model, versus 29.5% for the simple linear regression. Figure B-16 presents the distribution of the difference between predicted and actual performance for both the age dependent model (solid bars) and the straight line regression technique (hatched bars).

B.4.3.2 EVALUATION OF AGE DEPENDENT MODEL FOR SEGMENTS WITH MINIMAL LEAKAGE HISTORIES


While the previous comparison shows that using the age dependent model is roughly equivalent to using the linear regression model, it only applies to pipeline segments with leaks in at least two years. For pipeline segments that have just begun to leak, and have had only one recorded year with leakage, the linear regression technique can not be used to predict future performance, but the age dependent model can. Within the current database, the number of such segments is not insignificant. Figure B-17 shows the distribution of non-replaced pre-1936 steel pipeline segments according to the number of years with leakage (1970 - 1992). As shown in this figure, 45% of the segments could utilize the linear regression model (i.e., 2 or more years with leakage), and 36% have not yet suffered leakage. The remaining 19% have suffered only one leak to date, and could utilize the age dependent model for future leakage prediction.

Six sample segments (installed in 1912, 1913 and 1927) with one leak in the years through 1986, and at least one leak after 1986 have been identified. For these segments, the age dependent model was utilized to predict future leakage. These predictions are shown in Figures B-18 (pipe installed in 1912), B-19 (1913) and B-20 (1927). The results of these predictions are, for the most part, fairly accurate. In fact, in 2/3 of the cases, the predicted leakage is within 15% of actual performance.


Segment 9-6A




Segment 9-14A



Segment 10-39A



Segment 16-4




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986 — Age Dependent Model Prediction

2HD 400b/s-6A-L

Figure B-12: Comparison of Leak Rates Predicted from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1912)


Segment 16-16




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986 — Age Dependent Model Prediction

Figure B-13: Comparison of Leak Rates Predicted from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1912)


Segment 10-19D



Segment 16-15



Segment 16-17




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986 — Age Dependent Model Prediction


Figure B-14: Comparison of Leak Rates Predicted from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1913)

2HD 400nb/10-19D-L

Segment 10-12C



Segment 15-8A



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Least Squares Fit of Data Through 1986 — Age Dependent Model Prediction

Figure B-15: Comparison of Leak Rates Predicted from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1927)




Figure B-16: Percent Difference Between Predicted and Actual Number of Leaks





Figure B-17: Distribution of Pipe Segments by Number of Years with Leak Occurrences


Segment 15-3A




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Age Dependent Model Prediction

Figure B-18: Comparison of Predicted Leak Rates from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1912 with Limited Leakage)

Segment 9-3




Segment 9-14C




Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Age Dependent Model Prediction

Figure B-19: Comparison of Predicted Leak Rates from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1913 with Limited Leakage)


Segment 15-13



Segment 9-13



Segment 9-13A



Legend: ■ Leak Data Through 1986 * Post-1986 Leak Data — Age Dependent Model Prediction

2HD 400nb/15-13-R

Figure B-20: Comparison of Predicted Leak Rates from the Age Dependent Model to Actual Post-1986 Performance (Pipe Installed in 1927 with Limited Leakage)

B.5 CONCLUSIONS AND RECOMMENDATIONS

The assessment of pipeline data in the Torrance study area has led to the following conclusions:

- 1) The current method of leakage prediction is effective when sufficient leak data exists (i.e., at least three years with leakage)
- 2) Utilizing the leak history maps to represent historical leakage may underestimate leakage because the map updating procedure often obscures data, and reporting practices may have varied over time. Other sources of data are available, including the Leak Repair Order database, which includes every pipeline repair made since 1970.
- 3) An alternative method (the age dependent model) for verifying linear regression predictions and/or estimating pipeline leakage based on limited leakage data can be developed.

In addition to the above conclusions, the following recommendations are made:

- 1) Since the pilot area used in this study was relatively small, a second analysis is recommended to confirm the trends developed in this first phase. This recommendation is considered significant only if the ability to predict future leaks based on limited data is considered important.
- 2) Two areas are suggested for further study. The first area should be similar, although larger in size, to the Torrance area analyzed in the first phase. The purpose of this assessment will be to confirm the trends observed in the pilot study. In general, the models developed would have the most applicability to these older areas. A second, newer area should be selected to determine if similar models can be developed for other parts of the service area.

- 3) The same type of analysis could be applied to other pipe classes. Although most corrosion problems appear to affect pre-1936 bare pipe without cathodic protection, there are a limited number of other pipe classes that are also affected by corrosion. One such candidate pipe class is poorly coated steel pipe, without cathodic protection, installed between 1941 and 1957.

B.6 REFERENCES

P&GJ (1992), "The 12th Annual Pipeline and Gas Journal 500 Report", Pipeline and Gas Journal, September.

Southern California Gas Company (1992), "Annual Report for Calendar Year 1992; Gas Distribution System."


Strang, G.E. (1986), "Underground Piping System Replacement", Southern California Gas Company Engineering Department Report.


APPENDIX C

- INDEX MAPS TO ATLAS SHEETS


and

- PIPELINE SEGMENT DATABASE







Schematic Index Map for Atlas Sheet Torrance 10



Schematic Index Map for Atlas Sheet Torrance 15



Schematic Index Map for Atlas Sheet Torrance 16



Schematic Index Map for Atlas Sheet Torrance 17

<----- CURRENT PIPELINE INFORMATION -----> <----- PREVIOUS PIPELINE INFORMATION ----->

| Seg # | Pipeline Segment# | Material | Diameter | Year Installed | Pressure | CP | Length in feet | Material | Diameter | Year Installed | Age at Repl. | CP | |
|-------|-------------------|----------|----------|----------------|----------|----|----------------|----------|----------|----------------|--------------|----|---|
| 1 | Tor 09-1 | S | | 2 | 71 | M | Y | 825 | S | 2 | 13 | 58 | N |
| 2 | Tor 09-2 | S | | 3 | 56 | M | Y | 460 | | | | | |
| 3 | Tor 09-2A | S | | 2 | 18 | M | N | 45 | | | | | |
| 4 | Tor 09-3 | S | | 2 | 13 | M | N | 125 | | | | | |
| 5 | Tor 09-3A | P | | 3 | 85 | M | N | 50 | | | | | |
| 6 | Tor 09-4A | S | | 3 | 76 | M | Y | 195 | S | 3 | 12 | 64 | N |
| 7 | Tor 09-4B | P | | 2 | 85 | M | N | 250 | S | 3 | 12 | 73 | N |
| 8 | Tor 09-4C | P | | 3 | 85 | M | N | 625 | S | 3 | 12 | 73 | N |
| 9 | Tor 09-5 | P | | 2 | 86 | M | N | 275 | S | 2 | 13 | 73 | N |
| 10 | Tor 09-5A | P | | 2 | 86 | M | N | 75 | | | | | |
| 11 | Tor 09-6 | S | | 2 | 12 | M | N | 600 | | | | | |
| 12 | Tor 09-6A | S | | 2 | 12 | M | N | 310 | | | | | |
| 13 | Tor 09-7 | S | | 1 | 66 | M | N | 100 | | | | | |
| 14 | Tor 09-8 | S | | 2 | 49 | M | N | 310 | | | | | |
| 15 | Tor 09-9 | S | | 2 | 54 | M | N | 200 | | | | | |
| 16 | Tor 09-10 | S | | 3 | 49 | M | N | 570 | | | | | |
| 17 | Tor 09-10A | S | | 3 | 62 | M | Y | 400 | S | 3 | 12 | 50 | N |
| 18 | Tor 09-11 | S | | 3 | 70 | M | N | 350 | S | 3 | 12 | 58 | N |
| 19 | Tor 09-12 | P | | 2 | 86 | M | N | 335 | | | | | |
| 20 | Tor 09-12A | S | | 2 | 73 | M | Y | 80 | | | | | |
| 21 | Tor 09-13 | P | | 2 | 90 | M | N | 300 | S | 2 | 27 | 63 | N |
| 22 | Tor 09-13A | S | | 2 | 27 | M | N | 185 | | | | | |
| 23 | Tor 09-13B | S | | 2 | 36 | M | N | 1200 | | | | | |
| 24 | Tor 09-14 | S | | 6 | 82 | M | Y | 855 | S | 6 | 13 | 69 | N |
| 25 | Tor 09-14A | S | | 6 | 12 | M | N | 810 | | | | | |
| 26 | Tor 09-14B | S | | 6 | 72 | M | Y | 26 | | | | | |
| 27 | Tor 09-14C | S | | 6 | 13 | M | N | 400 | | | | | |
| 28 | Tor 09-14D | S | | 6 | 73 | M | N | 350 | S | 6 | 25 | 48 | N |
| 29 | Tor 09-14E | S | | 2 | 45 | M | N | 37 | | | | | |
| 30 | Tor 09-15 | S | | 2 | 73 | M | Y | 300 | S | 8 | 12 | 61 | N |
| 31 | Tor 09-16 | S | | 2 | 51 | M | N | 375 | | | | | |
| 32 | Tor 09-16A | S | | 2 | 47 | M | N | 155 | | | | | |
| 33 | Tor 09-17 | P | | 2 | 87 | M | N | 475 | | | | | |
| 34 | Tor 09-18 | S | | 8 | 22 | M | N | 400 | | | | | |
| 35 | Tor 09-19 | S | | 4 | 12 | M | N | 120 | | | | | |
| 36 | Tor 09-20 | P | | 1 | 80 | M | N | 80 | | | | | |
| 37 | Tor 09-21 | S | | 8 | 60 | M | N | 285 | | | | | |
| 38 | Tor 09-22 | S | | 2 | 51 | M | N | 10 | | | | | |
| 39 | Tor 09-22A | S | | 2 | 40 | M | N | 130 | | | | | |
| 40 | Tor 09-22B | P | | 2 | 83 | M | N | 100 | | | | | |
| 41 | Tor 09-23 | S | | 3 | 51 | M | Y | 260 | | | | | |
| 42 | Tor 09-24 | P | | 3 | 89 | M | N | 1025 | | | | | |
| 43 | Tor 09-25 | P | | 3 | 89 | M | N | 900 | | | | | |
| 44 | Tor 09-26 | S | | 8 | 45 | M | N | 260 | | | | | |
| 45 | Tor 09-30A | S | | 8 | 45 | M | N | 50 | | | | | |
| 46 | Tor 09-30B | S | | 8 | 56 | M | N | 10 | | | | | |
| 47 | Tor 09-31 | S | | 3 | 13 | M | N | 90 | | | | | |
| 48 | Tor 09-32 | S | | 2 | 36 | M | N | 20 | | | | | |
| 49 | Tor 10-1 | S | | 2 | 51 | M | Y | 475 | | | | | |
| 50 | Tor 10-2 | S | | 2 | 51 | M | Y | 465 | | | | | |
| 51 | Tor 10-3 | S | | 2 | 51 | M | Y | 630 | | | | | |
| 52 | Tor 10-4 | S | | 2 | 35 | M | N | 460 | | | | | |
| 53 | Tor 10-5A | S | | 2 | 27 | M | N | 75 | | | | | |
| 54 | Tor 10-5B | S | | 2 | 35 | M | N | 85 | | | | | |
| 55 | Tor 10-5C | S | | 2 | 37 | M | N | 100 | | | | | |
| 56 | Tor 10-5D | S | | 2 | 39 | M | Y | 105 | | | | | |
| 57 | Tor 10-5E | S | | 2 | 41 | M | Y | 125 | | | | | |
| 58 | Tor 10-5F | S | | 2 | 56 | M | Y | 120 | | | | | |
| 59 | Tor 10-6 | P | | 2 | 83 | M | N | 500 | S | 3 | 24 | 59 | N |
| 60 | Tor 10-7 | S | | 2 | 27 | M | N | 330 | | | | | |
| 61 | Tor 10-7A | S | | 2 | 26 | M | N | 190 | | | | | |
| 62 | Tor 10-7B | P | | 2 | 83 | M | N | 275 | | | | | |
| 63 | Tor 10-8 | P | | 2 | 83 | M | N | 160 | S | 2 | 26 | 57 | N |

<----- CURRENT PIPELINE INFORMATION -----> <----- PREVIOUS PIPELINE INFORMATION ----->

| Seg # | Pipeline Segment# | Material | Diameter | Year Installed | Pressure | CP | Length in feet | Material Diameter | Year Installed | Age at Repl. | CP | | |
|-------|-------------------|-----------|----------|----------------|----------|----|----------------|-------------------|----------------|--------------|----|----|---|
| 64 | Tor 10-8A | S | | 2 | 51 | M | Y | 405 | | | | | |
| 65 | Tor 10-8B | S | | 2 | 24 | M | N | 75 | | | | | |
| 66 | Tor 10-9 | P | | 2 | 85 | M | N | 250 | S | 2 | 24 | 61 | N |
| 67 | Tor 10-10 | S | | 8 | 83 | H | Y | 2205 | | | | | |
| 68 | Tor 10-11 | S | | 2 | 78 | M | Y | 540 | S | 2 | 24 | 54 | N |
| 69 | Tor 10-12A | S | | 1 | 43 | M | N | 50 | | | | | |
| 70 | Tor 10-12B | S | | 3 | 28 | M | N | 100 | | | | | |
| 71 | Tor 10-12C | S | | 3 | 27 | M | N | 850 | | | | | |
| 72 | Tor 10-12D | P | | 3 | 82 | M | N | 400 | S | 2 | 24 | 58 | N |
| 73 | Tor 10-12E | S | | 3 | 74 | M | Y | 265 | | | | | |
| 74 | Tor 10-12F | S | | 4 | 45 | M | Y | 45 | | | | | |
| 75 | Tor 10-12G | S | | 3 | 56 | M | Y | 385 | | | | | |
| 76 | Tor 10-12H | S | | 4 | 45 | M | N | 50 | | | | | |
| 77 | Tor 10-12I | S | | 2 | 13 | M | Y | 500 | | | | | |
| 78 | Tor 10-13 | P | | 2 | 85 | M | N | 715 | S | 2 | 28 | 57 | N |
| 79 | Tor 10-14 | P | | 2 | 78 | M | N | 550 | S | 2 | 29 | 49 | N |
| 80 | Tor 10-14A | S | | 2 | 39 | M | N | 185 | | | | | |
| 81 | Tor 10-15* | S | | 2 | 27 | M | N | 395 | | | | | |
| 82 | Tor 10-15A | S | | 2 | 29 | M | N | 355 | | | | | |
| 83 | Tor 10-16 | S | | 2 | 24 | M | N | 375 | | | | | |
| 84 | Tor 10-16A | S | | 2 | 17 | M | N | 380 | | | | | |
| 85 | Tor 10-17 | S | | 2 | 25 | M | N | 320 | | | | | |
| 86 | Tor 10-18A | S | | 2 | 17 | M | N | 860 | | | | | |
| 87 | Tor 10-18B | S | | 2 | 74 | M | Y | 50 | | | | | |
| 88 | Tor 10-18C | S | | 2 | 17 | M | N | 20 | | | | | |
| 89 | Tor 10-19A | S | | 2 | 78 | M | Y | 375 | | | | | |
| 90 | Tor 10-19B | S | | 2 | 74 | M | Y | 525 | S | 2 | 17 | 57 | N |
| 91 | Tor 10-19C | S | | 4 | 56 | M | Y | 335 | | | | | |
| 92 | Tor 10-19D | S | | 2 | 13 | M | N | 1010 | | | | | |
| 93 | Tor 10-20A | S | | 2 | 17 | M | N | 325 | | | | | |
| 94 | Tor 10-20B | NO RECORD | | | | | | | | | | | |
| 95 | Tor 10-20C | S | | 2 | 17 | M | N | 370 | | | | | |
| 96 | Tor 10-21 | P | | 2 | 78 | M | N | 740 | S | 2 | 16 | 62 | N |
| 97 | Tor 10-22 | S | | 2 | 75 | M | Y | 325 | | | | | |
| 98 | Tor 10-22A | S | | 2 | 73 | M | Y | 270 | | | | | |
| 99 | Tor 10-23 | S | | 2 | 70 | M | Y | 290 | | | | | |
| 100 | Tor 10-23A | S | | 2 | 73 | M | Y | 430 | | | | | |
| 101 | Tor 10-24 | S | | 2 | 72 | M | Y | 375 | | | | | |
| 102 | Tor 10-24A | P | | 3 | 83 | M | N | 720 | S | 2 | 27 | 56 | N |
| 103 | Tor 10-25 | P | | 2 | 86 | M | N | 1125 | S | 2 | 27 | 59 | N |
| 104 | Tor 10-26 | P | | 2 | 86 | M | N | 1125 | S | 2 | 27 | 59 | N |
| 105 | Tor 10-27 | P | | 2 | 86 | M | N | 1110 | S | 2 | 27 | 59 | N |
| 106 | Tor 10-28 | P | | 2 | 85 | M | N | 70 | | | | | |
| 107 | Tor 10-29 | P | | 2 | 86 | M | N | 80 | | | | | |
| 108 | Tor 10-30 | P | | 2 | 86 | M | N | 110 | | | | | |
| 109 | Tor 10-31 | P | | 2 | 86 | M | N | 95 | | | | | |
| 110 | Tor 10-32 | P | | 2 | 86 | M | N | 280 | | | | | |
| 111 | Tor 10-33 | P | | 2 | 81 | M | N | 125 | | | | | |
| 112 | Tor 10-34 | P | | 2 | 86 | M | N | 120 | | | | | |
| 113 | Tor 10-35 | S | | 2 | 66 | M | N | 220 | | | | | |
| 114 | Tor 10-35A | P | | 2 | 86 | M | N | 500 | S | 2 | 21 | 65 | N |
| 115 | Tor 10-36 | S | | 2 | 71 | M | Y | 495 | S | 2 | 22 | 49 | N |
| 116 | Tor 10-37 | S | | 2 | 38 | M | N | 120 | | | | | |
| 117 | Tor 10-37A | S | | 2 | 19 | M | N | 200 | | | | | |
| 118 | Tor 10-37B | S | | 2 | 18 | M | N | 135 | | | | | |
| 119 | Tor 10-38 | S | | 2 | 45 | M | N | 100 | | | | | |
| 120 | Tor 10-39 | P | | 2 | 78 | M | N | 204 | S | 3 | 37 | 41 | N |
| 121 | Tor 10-39A | S | | 3 | 12 | M | N | 800 | | | | | |
| 122 | Tor 10-40A | S | | 3 | 45 | M | Y | 465 | | | | | |
| 123 | Tor 10-40D | P | | 2 | 86 | M | N | 1475 | S | 2 | 21 | 65 | N |
| 124 | Tor 10-40E | P | | 2 | 78 | M | N | 360 | S | 2 | 22 | 56 | N |
| 125 | Tor 10-41 | S | | 4 | 39 | M | Y | 425 | | | | | |
| 126 | Tor 10-100 | S | | 2 | 12 | M | N | 185 | | | | | |

<----- CURRENT PIPELINE INFORMATION -----> <----- PREVIOUS PIPELINE INFORMATION ----->

| Seg # | Pipeline Segment# | Material | Diameter | Year Installed | Pressure | CP | Length in feet | Material | Diameter | Year Installed | Age at Repl. | CP |
|-------|-------------------|----------|----------|----------------|----------|----|----------------|----------|----------|----------------|--------------|----|
| 127 | Tor 10-101 | S | 4 | 39 | M | Y | 150 | | | | | |
| 128 | Tor 10-101B | S | 4 | 27 | M | Y | 15 | | | | | |
| 129 | Tor 10-102 | P | 2 | 84 | M | N | 120 | S | 2 | 21 | 63 | N |
| 130 | Tor 15-1 | S | 4 | 71 | H | Y | 500 | | | | | |
| 131 | Tor 15-2 | P | 2 | 83 | M | N | 475 | | | | | |
| 132 | Tor 15-3 | S | 2 | 39 | M | N | 210 | | | | | |
| 133 | Tor 15-3A | S | 2 | 27 | M | N | 310 | | | | | |
| 134 | Tor 15-3B | P | 2 | 91 | M | N | 185 | | | | | |
| 135 | Tor 15-3C | S | 2 | 51 | M | Y | 390 | | | | | |
| 136 | Tor 15-4 | S | 8 | 79 | H | Y | 350 | S | 8 | 20 | 59 | N |
| 137 | Tor 15-4A | S | 8 | 45 | H | N | 1320 | | | | | |
| 138 | Tor 15-4B | S | 8 | 91 | H | Y | 225 | S | 8 | 24 | 67 | N |
| 139 | Tor 15-4C | S | 8 | 83 | H | Y | 340 | | | | | |
| 140 | Tor 15-5 | S | 8 | 85 | M | Y | 290 | | | | | |
| 141 | Tor 15-6 | S | 4 | 56 | M | Y | 905 | | | | | |
| 142 | Tor 15-7 | S | 2 | 57 | M | Y | 325 | | | | | |
| 143 | Tor 15-7A | S | 2 | 78 | M | Y | 310 | | | | | |
| 144 | Tor 15-8 | S | 4 | 45 | M | N | 24 | | | | | |
| 145 | Tor 15-8A | S | 4 | 27 | H | N | 1325 | | | | | |
| 146 | Tor 15-8B | S | 2 | 55 | H | N | 90 | | | | | |
| 147 | Tor 15-9 | P | 2 | 86 | M | N | 275 | S | 2 | 27 | 59 | N |
| 148 | Tor 15-9A | P | 2 | 84 | M | N | 50 | | | | | |
| 149 | Tor 15-10 | P | 2 | 86 | M | N | 260 | S | 2 | 27 | 59 | N |
| 150 | Tor 15-11 | S | 1 | 73 | M | Y | 95 | | | | | |
| 151 | Tor 15-12 | S | 2 | 27 | M | N | 225 | | | | | |
| 152 | Tor 15-12A | S | 2 | 41 | M | N | 165 | | | | | |
| 153 | Tor 15-12B | S | 3 | 24 | M | N | 250 | | | | | |
| 154 | Tor 15-12C | S | 3 | 12 | M | N | 275 | | | | | |
| 155 | Tor 15-12D | P | 2 | 84 | M | N | 320 | | | | | |
| 156 | Tor 15-13 | S | 2 | 12 | M | N | 600 | | | | | |
| 157 | Tor 15-14 | P | 4 | 91 | M | N | 240 | | | | | |
| 158 | Tor 15-14A | S | 4 | 51 | M | Y | 150 | | | | | |
| 159 | Tor 15-14B | S | 4 | 91 | M | Y | 35 | | | | | |
| 160 | Tor 15-14C | S | 4 | 73 | M | Y | 110 | | | | | |
| 161 | Tor 15-14D | S | 4 | 73 | M | Y | 2810 | | | | | |
| 162 | Tor 15-15 | S | 2 | 24 | M | N | 150 | | | | | |
| 163 | Tor 15-15B | S | 2 | 13 | M | N | 300 | | | | | |
| 164 | Tor 15-16 | S | 2 | 51 | M | Y | 236 | | | | | |
| 165 | Tor 15-16A | S | 3 | 55 | M | Y | 1010 | | | | | |
| 166 | Tor 15-16B | S | 3 | 56 | M | Y | 340 | | | | | |
| 167 | Tor 15-16C | P | 2 | 85 | M | N | 149 | | | | | |
| 168 | Tor 15-17 | S | 2 | 69 | M | Y | 490 | | | | | |
| 169 | Tor 15-17A | S | 2 | 40 | M | Y | 95 | | | | | |
| 170 | Tor 15-17B | S | 2 | 46 | M | Y | 95 | | | | | |
| 171 | Tor 15-18 | S | 2 | 74 | M | Y | 100 | | | | | |
| 172 | Tor 15-18A | S | 2 | 50 | M | N | 80 | | | | | |
| 173 | Tor 15-18B | S | 2 | 74 | M | Y | 50 | | | | | |
| 174 | Tor 16-1 | P | 2 | 86 | M | N | 625 | S | 2 | 12 | 74 | N |
| 175 | Tor 16-2 | P | 2 | 86 | M | N | 250 | | | | | |
| 176 | Tor 16-3 | S | 3 | 50 | M | N | 40 | | | | | |
| 177 | Tor 16-3A | S | 3 | 59 | M | N | 55 | | | | | |
| 178 | Tor 16-4 | S | 3 | 12 | M | N | 495 | | | | | |
| 179 | Tor 16-4A | S | 3 | 67 | M | N | 35 | | | | | |
| 180 | Tor 16-5 | S | 2 | 50 | M | Y | 135 | | | | | |
| 181 | Tor 16-5A | S | 2 | 50 | M | Y | 235 | | | | | |
| 182 | Tor 16-5B | S | 2 | 67 | M | Y | 25 | | | | | |
| 183 | Tor 16-6 | S | 2 | 48 | M | Y | 105 | | | | | |
| 184 | Tor 16-7 | S | 2 | 54 | M | Y | 370 | | | | | |
| 185 | Tor 16-7A | S | 3 | 13 | M | Y | 50 | | | | | |
| 186 | Tor 16-9 | S | 2 | 40 | M | Y | 160 | | | | | |
| 187 | Tor 16-10 | S | 6 | 82 | M | Y | 435 | S | 6 | 13 | 69 | N |
| 188 | Tor 16-11 | S | 6 | 41 | M | Y | 360 | | | | | |
| 189 | Tor 16-11A | S | 6 | 84 | M | Y | 25 | | | | | |

<----- CURRENT PIPELINE INFORMATION -----> <----- PREVIOUS PIPELINE INFORMATION ----->

| Seg # | Pipeline Segment# | Material | Diameter | Year Installed | Pressure | CP | Length in feet | Material | Diameter | Year Installed | Age at Repl. | CP |
|-------|-------------------|----------|----------|----------------|----------|----|----------------|----------|----------|----------------|--------------|----|
| 190 | Tor 16-12 | S | 6 | 41 | M | Y | 125 | | | | | |
| 191 | Tor 16-13 | P | 2 | 86 | M | N | 275 | S | 4 | 18 | 68 | N |
| 192 | Tor 16-14 | S | 6 | 73 | M | Y | 3010 | S | 4 | 12 | 61 | N |
| 193 | Tor 16-14A | S | 6 | 60 | M | Y | 300 | | | | | |
| 194 | Tor 16-15 | P | 4 | 89 | M | N | 1380 | S | 4 | 13 | 76 | N |
| 195 | Tor 16-15A | S | 4 | 51 | M | Y | 130 | | | | | |
| 196 | Tor 16-15B | S | 6 | 70 | M | Y | 450 | | | | | |
| 197 | Tor 16-16 | S | 3 | 12 | M | N | 920 | | | | | |
| 198 | Tor 16-16A | S | 2 | 70 | M | Y | 160 | | | | | |
| 199 | Tor 16-16B | S | 2 | 51 | M | Y | 75 | | | | | |
| 200 | Tor 16-16C | S | 2 | 77 | M | Y | 275 | S | 2 | 13 | 64 | N |
| 201 | Tor 16-16D | S | 2 | 13 | M | N | 210 | | | | | |
| 202 | Tor 16-17 | P | 2 | 91 | M | N | 900 | S | 2 | 13 | 78 | N |
| 203 | Tor 16-17A | P | 2 | 91 | M | N | 60 | S | 2 | 57 | 34 | N |
| 204 | Tor 16-18 | S | 2 | 74 | M | Y | 860 | S | 3 | 13 | 61 | N |
| 205 | Tor 16-19 | S | 2 | 72 | M | Y | 160 | | | | | |
| 206 | Tor 16-19A | S | 2 | 91 | M | Y | 70 | | | | | |
| 207 | Tor 16-20 | S | 2 | 72 | M | Y | 275 | | | | | |
| 208 | Tor 16-21 | P | 2 | 80 | M | N | 1025 | S | 2 | 12 | 68 | N |
| 209 | Tor 16-21A | S | 4 | 58 | M | Y | 610 | | | | | |
| 210 | Tor 16-22 | S | 2 | 68 | M | Y | 1635 | | | | | |
| 211 | Tor 16-23 | S | 4 | 50 | M | Y | 1635 | | | | | |
| 212 | Tor 16-24 | S | 2 | 69 | M | Y | 500 | | | | | |
| 213 | Tor 16-25 | P | 2 | 86 | M | N | 85 | | | | | |
| 214 | Tor 16-26 | S | 2 | 69 | M | Y | 880 | | | | | |
| 215 | Tor 16-26A | S | 2 | 58 | M | Y | 295 | | | | | |
| 216 | Tor 16-27 | S | 2 | 48 | M | Y | 160 | | | | | |
| 217 | Tor 16-28 | S | 2 | 74 | M | Y | 275 | S | 2 | 13 | 61 | N |
| 218 | Tor 16-29 | S | 2 | 74 | M | Y | 125 | | | | | |
| 219 | Tor 17-1 | S | 2 | 68 | M | Y | 240 | | | | | |
| 220 | Tor 17-2 | P | 2 | 86 | M | N | 75 | | | | | |
| 221 | Tor 17-3 | P | 2 | 79 | M | N | 700 | | | | | |
| 222 | Tor 17-4 | S | 2 | 50 | M | Y | 60 | | | | | |
| 223 | Tor 17-4A | S | 2 | 50 | M | Y | 170 | | | | | |
| 224 | Tor 17-4B | S | 2 | 48 | M | Y | 135 | | | | | |
| 225 | Tor 17-5 | P | 2 | 79 | M | N | 300 | S | 2 | 23 | 56 | N |
| 226 | Tor 17-5A | P | 2 | 81 | M | N | 65 | S | 2 | 23 | 58 | N |
| 227 | Tor 17-6 | P | 4 | 81 | M | N | 920 | S | 4 | 22 | 59 | N |
| 228 | Tor 17-6A | S | 4 | 22 | M | N | 570 | | | | | |
| 229 | Tor 17-6B | S | 4 | 79 | M | Y | 530 | S | 4 | 26 | 53 | N |
| 230 | Tor 17-6C | S | 2 | 79 | M | Y | 330 | | | | | |
| 231 | Tor 17-7 | S | 4 | 50 | M | Y | 550 | | | | | |
| 232 | Tor 17-8 | S | 2 | 47 | M | N | 120 | | | | | |
| 233 | Tor 17-8B | S | 3 | 30 | M | N | 220 | | | | | |
| 233 | Tor 17-8A | S | 3 | 34 | M | N | 250 | | | | | |
| 234 | Tor 17-9 | S | 4 | 23 | M | N | 360 | | | | | |
| 235 | Tor 17-9A | S | 4 | 30 | M | N | 35 | | | | | |
| 236 | Tor 17-10 | P | 2 | 84 | M | N | 485 | S | 2 | 47 | 37 | N |
| 237 | Tor 17-11 | S | 1 | 43 | M | Y | 450 | | | | | |
| 238 | Tor 17-12 | S | 2 | 48 | M | Y | 250 | | | | | |
| 239 | Tor 17-12A | S | 2 | 41 | M | Y | 430 | | | | | |
| 240 | Tor 17-13 | S | 2 | 13 | M | N | 300 | | | | | |
| 241 | Tor 17-13A | S | 2 | 59 | M | Y | 185 | | | | | |
| 242 | Tor 17-14 | S | 4 | 58 | M | Y | 600 | | | | | |
| 243 | Tor 17-14A | S | 2 | 16 | M | N | 260 | | | | | |
| 244 | Tor 17-15 | S | 2 | 65 | M | Y | 325 | | | | | |
| 245 | Tor 17-16A | S | 3 | 79 | M | Y | 15 | | | | | |
| 246 | Tor 17-16B | S | 3 | 69 | M | Y | 845 | | | | | |
| 247 | Tor 17-16E | S | 1 | 70 | M | Y | 100 | | | | | |
| 248 | Tor 17-16F | P | 2 | 87 | M | N | 225 | | | | | |
| 249 | Tor 17-17 | P | 2 | 78 | M | N | 900 | S | 2 | 16 | 62 | N |
| 250 | Tor 17-18 | S | 2 | 41 | M | Y | 415 | | | | | |
| 251 | Tor 17-19 | S | 2 | 42 | M | Y | 465 | | | | | |

<----- CURRENT PIPELINE INFORMATION -----> <----- PREVIOUS PIPELINE INFORMATION ----->

| Seg # | Pipeline Segment# | Material | Diameter | Year Installed | Pressure | CP | Length in feet | Material | Diameter | Year Installed | Age at Repl. | CP |
|-------|-------------------|----------|----------|----------------|----------|----|----------------|----------|----------|----------------|--------------|----|
| 252 | Tor 17-20 | S | 2 | 48 | M | Y | 540 | | | | | |
| 253 | Tor 17-20A | S | 2 | 52 | M | Y | 120 | | | | | |
| 254 | Tor 17-20B | S | 2 | 49 | M | Y | 100 | | | | | |
| 255 | Tor 17-21 | P | 2 | 82 | M | N | 240 | | | | | |
| 256 | Tor 17-22 | P | 2 | 85 | M | N | 1200 | | | | | |
| 257 | Tor 17-23 | S | 3 | 49 | M | Y | 1200 | | | | | |
| 258 | Tor 17-24 | S | 2 | 50 | M | Y | 350 | | | | | |
| 259 | Tor 17-24A | S | 3 | 49 | M | Y | 170 | | | | | |
| 260 | Tor 17-24B | S | 3 | 56 | M | Y | 350 | | | | | |
| 261 | Tor 17-25 | S | 3 | 49 | M | Y | 250 | | | | | |
| 262 | Tor 17-25A | S | 2 | 62 | M | Y | 120 | | | | | |
| 263 | Tor 17-26 | S | 2 | 72 | M | Y | 260 | | | | | |
| 264 | Tor 17-27* | P | 2 | 88 | M | N | 590 | S | 2 | 13 | 75 | N |
| 265 | Tor 17-27A | S | 2 | 65 | M | N | 50 | | | | | |
| 266 | Tor 17-27B | S | 2 | 13 | M | N | 70 | | | | | |
| 267 | Tor 17-28 | S | 1 | 65 | M | Y | 325 | | | | | |
| 268 | Tor 17-29 | S | 2 | 56 | M | Y | 635 | | | | | |
| 269 | Tor 17-30 | S | 6 | 70 | M | Y | 1165 | | | | | |
| 270 | Tor 17-31 | S | 4 | 23 | M | N | 775 | | | | | |
| 271 | Tor 17-31A | S | 2 | 49 | M | Y | 75 | | | | | |
| 272 | Tor 17-31B | S | 2 | 47 | M | Y | 70 | | | | | |
| 273 | Tor 17-31C | S | 4 | 81 | M | Y | 30 | S | 4 | 49 | 32 | N |
| 274 | Tor 17-32 | S | 8 | 49 | M | N | 2180 | | | | | |
| 275 | Tor 17-32A | S | 8 | 81 | M | Y | 150 | | | | | |
| 276 | Tor 17-33 | S | 4 | 59 | M | Y | 710 | | | | | |
| 277 | Tor 17-34 | S | 3 | 59 | M | Y | 70 | | | | | |
| 278 | Tor 17-35 | S | 2 | 52 | M | N | 165 | | | | | |
| 279 | Tor 17-36A | S | 2 | 49 | M | N | 90 | | | | | |
| 280 | Tor 17-36B | S | 2 | 47 | M | N | 50 | | | | | |
| 281 | Tor 17-40 | S | 2 | 22 | M | N | 190 | | | | | |

106241

APPENDIX D
LEAK DATABASE

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRIO | Address or Location | SIZE (inches) | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline Segment Number | Pipeline Info (C=CURRENT P=PREVIOUS) |
|-------------------|-------------|-----------|---------------------------------|---------------|-------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|-------------------------|--------------------------------------|
| | | | | | | | | | | | | | | | |
| 76 | -683118 | TOR0009 | 2 ALLEY W/O CRAVENS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1913 | 03/01/1976 | 03/01/1976 | TOR09-001 | C |
| 88 | -60020 | TOR0009 | 1 1318 CRAVENS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1971 | 08/18/1988 | 08/18/1988 | TOR09-003 | P |
| 78 | -929595 | TOR0009 | 2 2014 TORRANCE BLVD | 300 | 3 | 1 | 1 | 1 | 1 | 4 | 1912 | 01/01/1978 | 01/01/1978 | TOR09-004B | P |
| 79 | -51170 | TOR0009 | 3 1313 POST AVE | 300 | 3 | 1 | 1 | 1 | 1 | 4 | 1912 | 01/01/1979 | 01/01/1979 | TOR09-004B | P |
| 80 | -2246 | TOR0009 | 3 2014 TORRANCE BLVD | 300 | 3 | 1 | 1 | 1 | 1 | 4 | 1956 | 09/11/1980 | 04/11/1981 | TOR09-004C | P |
| 85 | -36725 | TOR0009 | 2 1411 POST AV | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1930 | 08/14/1985 | 05/14/1985 | TOR09-005 | P |
| 87 | -12424 | TOR0009 | 1 1444 POST AVE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1922 | 08/21/1987 | 08/21/1987 | TOR09-006 | C |
| 92 | -82157 | TOR0009 | 3 1417 EL PRADO AV | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1900 | 08/06/1992 | 08/06/1992 | TOR09-006 | C |
| 82 | -27790 | TOR0009 | 2 1269 SARTORI | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1912 | 09/14/1982 | 09/14/1982 | TOR09-006A | C |
| 92 | -82235 | TOR0009 | 3 1265 SARTORI | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1912 | 08/12/1992 | 08/17/1992 | TOR09-006A | C |
| 77 | -818772 | TOR0009 | 3 ALLEY E/O CRAVENS & S/O POST | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1912 | 01/01/1977 | 01/01/1977 | TOR09-006A | C |
| 75 | -74457 | TOR0009 | 1 1414 CEAVENS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1912 | 03/01/1975 | 03/01/1975 | TOR09-006A | C |
| 80 | -2070 | TOR0009 | 2 1414 CRAVENS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1950 | 10/22/1980 | 10/22/1980 | TOR09-009 | C |
| 89 | -60031 | TOR0009 | 1 923 VAN NESS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1927 | 08/22/1989 | 08/22/1989 | TOR09-013 | P |
| 77 | -84488 | TOR0009 | 1 923 VAN NESS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1972 | 12/01/1977 | 12/01/1977 | TOR09-013 | P |
| 83 | -30134 | TOR0009 | 3 1971 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 07/21/1983 | 07/21/1983 | TOR09-013A | C |
| 80 | -095788 | TOR0009 | 3 925 VAN NESS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1936 | 12/18/1980 | 07/18/1981 | TOR09-013B | C |
| 80 | -09578A | TOR0009 | 1 925 VAN NESS | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1936 | 12/18/1980 | 12/18/1980 | TOR09-013B | C |
| 84 | -51241 | TOR0009 | 1 923 VAN NESS AVE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1939 | 03/07/1984 | 03/07/1984 | TOR09-013B | C |
| 84 | -38639 | TOR0009 | 1 923 VAN NESS AVE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1939 | 03/07/1984 | 03/07/1984 | TOR09-013B | C |
| 77 | -876992 | TOR0016 | 3 1500 CABRILLO | 600 | 6 | 1 | 1 | 1 | 1 | 4 | 1913 | 08/01/1977 | 08/01/1977 | TOR09-014 | P |
| 81 | -11919 | TOR0009 | 3 1502 CABRILLO AVE | 600 | 6 | 1 | 1 | 1 | 1 | 4 | 1925 | 09/28/1981 | 02/28/1982 | TOR09-014 | P |
| 79 | -994782 | TOR0009 | 1 908 VAN NESS | 600 | 6 | 1 | 1 | 1 | 1 | 4 | 1912 | 07/01/1979 | 07/01/1979 | TOR09-014A | C |
| 89 | -40448 | TOR0009 | 3 N/E COR VAN NESS & MULLEN AV | 600 | 6 | 1 | 1 | 1 | 1 | 4 | 1912 | 08/22/1989 | 08/22/1990 | TOR09-014A | C |
| 89 | -40451 | TOR0009 | 3 1820 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1947 | 08/24/1989 | 08/24/1990 | TOR09-016A | C |
| 76 | -683120 | TOR0009 | 1 1820 TORRANCE BLVD. | 200 | 2 | 1 | 1 | 1 | 1 | 2 | 1947 | 02/01/1976 | 02/01/1976 | TOR09-016A | C |
| 86 | -90074 | TOR0009 | 3 N/W 1/S 213TH ST & BOW | 300 | 3 | 1 | 1 | 1 | 4 | 2 | 1951 | 03/21/1986 | 03/21/1987 | TOR09-023 | C |
| 84 | -56813 | TOR0009 | 3 N/W CORNER WESTERN & 213TH ST | 800 | 8 | 1 | 1 | 1 | 1 | 2 | 1945 | 03/12/1984 | 02/12/1985 | TOR09-026 | C |
| 91 | -15032 | TOR0009 | 1 NW 213 & WESTERN | 800 | 8 | 1 | 1 | 1 | 1 | 2 | 1945 | 08/19/1991 | 08/19/1991 | TOR09-026 | C |
| 86 | -26051 | TOR0010 | 2 2512 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 1 | 2 | 1935 | 01/06/1986 | 01/06/1986 | TOR10-004 | C |
| 82 | -21994 | TOR0010 | 3 2558 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 2 | 1935 | 06/11/1982 | 04/11/1983 | TOR10-004 | C |
| 84 | -51787 | TOR0010 | 3 1324 DATE AVE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1927 | 08/28/1984 | 08/28/1984 | TOR10-005A | C |
| 85 | -36251 | TOR0010 | 2 1326 DATE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1927 | 05/31/1985 | 06/14/1985 | TOR10-005A | C |
| 88 | -20573 | TOR0010 | 3 2515 EL DORADO ST | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 12/01/1988 | 02/01/1989 | TOR10-007A | C |
| 75 | -686462 | TOR0010 | 3 1606 CRENSHAW BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 02/01/1975 | 02/01/1975 | TOR10-008 | P |
| 84 | -39655 | TOR0010 | 2 2555 SONOMA | 200 | 2 | 1 | 1 | 1 | 1 | 3 | 1951 | 11/26/1984 | 11/26/1984 | TOR10-008A | C |
| 84 | -39583 | TOR0010 | 2 2555 SONOMA | 200 | 2 | 1 | 1 | 1 | 1 | 3 | 1951 | 11/14/1984 | 11/14/1984 | TOR10-008A | C |
| 82 | -22002 | TOR0010 | 3 1512 DATE AVE | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1924 | 06/11/1982 | 04/11/1983 | TOR10-009 | P |
| 78 | -936778 | TOR0010 | 3 2555 SONOMA | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1927 | 07/01/1978 | 07/01/1978 | TOR10-009 | P |
| 84 | -51799 | TOR0010 | 3 1508 DATE AV | 200 | 2 | 1 | 1 | 1 | 1 | 2 | 1924 | 08/30/1984 | 08/30/1984 | TOR10-009 | P |
| 88 | -20569 | TOR0010 | 3 2371 TORRANCE BLVD | 300 | 3 | 1 | 1 | 1 | 1 | 4 | 1927 | 12/01/1988 | 08/01/1989 | TOR10-012C | C |
| 84 | -31444 | TOR0010 | 1 1027 ACACIA | 300 | 3 | 1 | 1 | 1 | 1 | 4 | 1927 | 11/15/1984 | 11/15/1984 | TOR10-012C | C |
| 86 | -60325 | TOR0010 | 3 2413 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1927 | 11/26/1986 | 10/26/1987 | TOR10-012C | C |
| 82 | -28741 | TOR0010 | 3 1104 AMAPOLA | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1924 | 06/09/1982 | 06/09/1982 | TOR10-012D | P |
| 78 | -976417 | TOR0010 | 1 2313 TORR BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 06/01/1978 | 06/01/1978 | TOR10-012D | P |
| 78 | -933750 | TOR0010 | 2 2305 TORR BL. | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 07/01/1978 | 07/01/1978 | TOR10-012D | P |
| 78 | -976416 | TOR0010 | 1 2305 TORR BLVD. | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1926 | 07/01/1978 | 07/01/1978 | TOR10-012D | P |
| 78 | -976419 | TOR0010 | 1 2306-2308 TORR BLVD | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1921 | 06/01/1978 | 06/01/1978 | TOR10-012D | P |
| 78 | -933831 | TOR0010 | 1 1103 PORTOLA AVE | 300 | 3 | 1 | 1 | 1 | 1 | 2 | 1956 | 06/01/1978 | 06/01/1978 | TOR10-012G | C |
| 84 | -7092 | TOR0010 | 3 1019 BEECH | 200 | 2 | 1 | 1 | 1 | 1 | 4 | 1928 | 11/15/1984 | 12/15/1984 | TOR10-013 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK Prio | Address or Location | DIAMETER SIZE (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline info | |
|-------------------|-------------|-----------|----------------------------------|------------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|----------------|------------------------|
| | | | | | | | | | | | | | Segment Number | (C=CURRENT P=PREVIOUS) |
| 78 - 990162 | TOR0010 | 1 | 811-815 BEECH AVE. | 200 | 1 | 1 | 1 | 1 | 4 | 1928 | 06/01/1978 | 06/01/1978 | TOR10-013 | P |
| 85 - 36295 | TOR0010 | 2 | 815 BEECH | 200 | 1 | 1 | 1 | 1 | 4 | 1928 | 06/10/1985 | 06/10/1985 | TOR10-013 | P |
| 78 - 990160 | TOR0010 | 1 | 917 BEECH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 06/01/1978 | 06/01/1978 | TOR10-013 | P |
| 82 - 28689 | TOR0010 | 1 | 812 CRENSHAW BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 06/01/1982 | 06/01/1982 | TOR10-013 | P |
| 82 - 28685 | TOR0010 | 1 | 811 BEECH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 05/28/1982 | 05/28/1982 | TOR10-013 | P |
| 84 - 31385 | TOR0010 | 3 | 1020 CRENSHAW BLVD | 200 | 2 | 1 | 1 | 1 | 2 | 1928 | 10/26/1984 | 10/26/1984 | TOR10-013 | P |
| 78 - 25266 | TOR0010 | 3 | 1007 BEECH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 10/01/1978 | 10/01/1978 | TOR10-013 | P |
| 78 - 990179 | TOR0010 | 1 | 1015-1023 ACACIA | 200 | 2 | 1 | 1 | 1 | 4 | 1929 | 06/01/1978 | 06/01/1978 | TOR10-014 | P |
| 82 - 21995 | TOR0010 | 3 | ACACIA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 06/03/1982 | 06/03/1982 | TOR10-015 | P |
| 82 - 28711 | TOR0010 | 1 | 1103 AMAPOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 06/03/1982 | 06/03/1982 | TOR10-016 | C |
| 78 - 25273 | TOR0010 | 3 | 2310 SIERRA ST | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 10/01/1978 | 10/01/1978 | TOR10-016 | C |
| 82 - 28778 | TOR0010 | 1 | 1103 AMAPOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1925 | 06/17/1982 | 06/17/1982 | TOR10-016 | C |
| 84 - 7389 | TOR0010 | 3 | 1006 SIERRA PL | 200 | 2 | 1 | 1 | 1 | 4 | *1925 | 12/05/1984 | 10/05/1985 | TOR10-017 | C |
| 90 - 9683 | TOR0010 | 2 | 1012 SIERRA PL | 200 | 2 | 1 | 1 | 1 | 4 | 1925 | 12/05/1984 | 12/19/1984 | TOR10-017 | C |
| 90 - 2618 | TOR0010 | 1 | 918 S COTA AV | 200 | 2 | 1 | 1 | 1 | 4 | 1900 | 03/05/1990 | 03/05/1990 | TOR10-018A | C |
| 77 - 866151 | TOR0010 | 3 | I/S SIERRA & PORTOLA AV | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 10/31/1990 | 07/31/1991 | TOR10-018A | C |
| 78 - 933640 | TOR0010 | 3 | I/S COTA & SIERRA ST | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 01/01/1977 | 01/01/1977 | TOR10-018A | C |
| 88 - 20572 | TOR0010 | 2 | 917-19 PORTOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 07/01/1978 | 07/01/1978 | TOR10-018A | C |
| 86 - 37759 | TOR0010 | 3 | SONOMA & ALLEY W/COTA | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 12/01/1988 | 08/01/1989 | TOR10-0190 | C |
| 87 - 40318 | TOR0010 | 3 | S/E COR ELDRADO & ALLEY W/O COTA | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 12/01/1988 | 08/01/1989 | TOR10-0190 | C |
| 87 - 8421 | TOR0010 | 1 | 1417 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 01/06/1986 | 01/06/1986 | TOR10-0190 | C |
| 83 - 50134 | TOR0010 | 3 | 1507 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 01/26/1987 | 01/26/1987 | TOR10-0190 | C |
| 82 - 28749 | TOR0010 | 2 | 1421 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 01/27/1987 | 01/27/1988 | TOR10-0190 | C |
| 82 - 22001 | TOR0010 | 3 | 1411 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 02/14/1983 | 02/14/1983 | TOR10-0190 | C |
| 86 - 3426 | TOR0010 | 3 | 1417 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 06/09/1982 | 06/09/1982 | TOR10-0190 | C |
| 83 - 29995 | TOR0010 | 3 | INT ALLEY W/O COTA & N/PL ELDR | 200 | 2 | 1 | 1 | 1 | 2 | 1913 | 06/11/1982 | 06/11/1983 | TOR10-0190 | C |
| 83 - 36942 | TOR0010 | 3 | 1421 COTA AVE | 200 | 2 | 1 | 1 | 1 | 3 | 1966 | 03/21/1986 | 03/21/1987 | TOR10-0190 | C |
| 83 - 50141 | TOR0010 | 2 | 1225 COTA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 05/27/1983 | 05/27/1983 | TOR10-0190 | C |
| 78 - 933832 | TOR0010 | 2 | 1403 COTA | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 09/18/1985 | 09/18/1985 | TOR10-0190 | C |
| 84 - 39710 | TOR0010 | 3 | 1418 AMAPOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 02/15/1983 | 02/15/1983 | TOR10-0190 | C |
| 78 - 909637 | TOR0010 | 3 | 1103 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 06/01/1978 | 06/01/1978 | TOR10-020A | C |
| 78 - 976413 | TOR0010 | 3 | 1103 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 12/03/1984 | 12/03/1984 | TOR10-020A | C |
| 78 - 976424 | TOR0010 | 1 | 1007-1011 ARLINGTON | 200 | 2 | 1 | 1 | 1 | 4 | 1978 | 09/01/1978 | 09/01/1978 | TOR10-020A | C |
| 78 - 818735 | TOR0010 | 2 | 824 PORTOLA ALLEY E/O | 200 | 2 | 1 | 1 | 1 | 4 | 1916 | 06/01/1978 | 06/01/1978 | TOR10-021 | P |
| 82 - 21717 | TOR0010 | 3 | 921 ARLINGTON | 200 | 2 | 1 | 1 | 1 | 4 | 1916 | 06/01/1978 | 06/01/1978 | TOR10-021 | P |
| 82 - 27456 | TOR0010 | 3 | 1303 BEACH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 06/16/1982 | 09/16/1982 | TOR10-024A | P |
| 82 - 50012 | TOR0010 | 3 | 1303 BEECH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 06/15/1982 | 06/15/1982 | TOR10-024A | P |
| 82 - 28774 | TOR0010 | 3 | 1230 CRENSHAW BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 12/17/1982 | 12/17/1982 | TOR10-024A | P |
| 78 - 933839 | TOR0010 | 3 | 1303 BEECH AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 06/16/1982 | 06/16/1982 | TOR10-024A | P |
| 78 - 25269 | TOR0010 | 3 | 6217 ACACIA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 06/01/1978 | 06/01/1978 | TOR10-025 | P |
| 78 - 990166 | TOR0010 | 3 | 2414 SONOMA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 10/01/1978 | 10/01/1978 | TOR10-025 | P |
| 79 - 102951 | TOR0010 | 1 | 1217-1221 ACACIA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 06/01/1978 | 06/01/1978 | TOR10-025 | P |
| 78 - 25276 | TOR0010 | 3 | SE COR SONOMA & ALY W/ACACIA | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 10/01/1979 | 10/01/1979 | TOR10-025 | P |
| 77 - 915778 | TOR0010 | 3 | 2414 SONOMA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 09/01/1978 | 09/01/1978 | TOR10-025 | P |
| 81 - 11324 | TOR0010 | 3 | 1423 ACACIA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1925 | 07/01/1977 | 07/01/1977 | TOR10-025 | P |
| 78 - 990168 | TOR0010 | 1 | 2415 SONOMA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 05/14/1981 | 07/14/1981 | TOR10-025 | P |
| 84 - 39666 | TOR0010 | 1 | 1503 MADRID | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 06/01/1978 | 06/01/1978 | TOR10-025 | P |
| 84 - 51840 | TOR0010 | 3 | 1503 MADRID AVE | 200 | 2 | 1 | 1 | 1 | 2 | 1927 | 11/27/1984 | 11/27/1984 | TOR10-026 | P |
| | | | | | | | | | | 1927 | 09/11/1984 | 09/11/1984 | TOR10-026 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRTIO | Address or Location | DIAMETER SIZE (Inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline info | |
|-------------------|-------------|------------|------------------------------------|------------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|----------------|---------------------------------|
| | | | | | | | | | | | | | Segment Number | Pipeline (C=CURRENT P=PREVIOUS) |
| 79 | 51442 | TOR0010 | 3 1313 AMAPOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1923 | 02/01/1979 | 02/01/1979 | TOR10-027 | P |
| 78 | 25265 | TOR0010 | 3 1303 AMAPOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 10/01/1978 | 10/01/1978 | TOR10-027 | P |
| 82 | 28757 | TOR0010 | 1 1217 AMAPOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/11/1982 | 06/11/1982 | TOR10-027 | P |
| 84 | 31233 | TOR0010 | 3 1229 PORTOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 09/06/1984 | 09/06/1984 | TOR10-035A | P |
| 82 | 27434 | TOR0010 | 1 1303 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/10/1982 | 06/10/1982 | TOR10-035A | P |
| 82 | 27433 | TOR0010 | 1 1215 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/10/1982 | 06/10/1982 | TOR10-035A | P |
| 84 | 39705 | TOR0010 | 1 1217 PORTOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 12/03/1984 | 12/03/1984 | TOR10-035A | P |
| 82 | 28759 | TOR0010 | 3 1229 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/11/1982 | 06/11/1982 | TOR10-035A | P |
| 84 | 39659 | TOR0010 | 1 1217 PORTOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1920 | 11/27/1984 | 11/27/1984 | TOR10-035A | P |
| 78 | 990154 | TOR0010 | 1 1307 PORTOLA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/01/1978 | 06/01/1978 | TOR10-035A | P |
| 83 | 50544 | TOR0010 | 3 ALLEY W/O PORTOLA & ELDORADO AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1971 | 07/01/1983 | 07/01/1983 | TOR10-036 | C |
| 84 | 39653 | TOR0010 | 1 1228 ARLINGTON AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1938 | 11/26/1984 | 11/26/1984 | TOR10-037 | C |
| 83 | 22414 | TOR0009 | 3 ALLEY W/O ENGRACIA S/O TORRANCE | 200 | 2 | 1 | 1 | 1 | 4 | 1918 | 02/15/1983 | 02/15/1984 | TOR10-037B | C |
| 76 | 683487 | TOR0010 | 3 1527 POST AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1924 | 08/01/1976 | 08/01/1976 | TOR10-039A | C |
| 90 | 2620 | TOR0010 | 3 1412 ENGRACIA AV | 300 | 3 | 1 | 1 | 1 | 4 | 1917 | 10/31/1990 | 06/30/1991 | TOR10-039A | C |
| 92 | 82276 | TOR0010 | 3 1442 S ENGRACIA AV | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 02/04/1988 | 05/04/1988 | TOR10-039A | C |
| 88 | 20031 | TOR0010 | 3 1404 ENGRACIA AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1900 | 08/17/1992 | 08/17/1992 | TOR10-039A | C |
| 78 | 26537 | TOR0010 | 3 1412 ENGRACIA AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 02/01/1978 | 12/01/1978 | TOR10-039A | C |
| 84 | 39628 | TOR0010 | 1 2368 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 11/20/1984 | 11/20/1984 | TOR10-040D | P |
| 84 | 39628 | TOR0010 | 1 2206 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 11/20/1984 | 11/20/1984 | TOR10-040D | P |
| 84 | 39636 | TOR0010 | 1 2224 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 4 | 1935 | 11/21/1984 | 11/21/1984 | TOR10-040D | P |
| 84 | 39652 | TOR0010 | 2 2304 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 11/27/1984 | 11/27/1984 | TOR10-040D | P |
| 84 | 39664 | TOR0010 | 1 2304 TORR BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 11/27/1984 | 11/27/1984 | TOR10-040D | P |
| 84 | 39651 | TOR0010 | 1 2308 TORR | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 11/23/1984 | 11/23/1984 | TOR10-040D | P |
| 84 | 39635 | TOR0010 | 1 2212 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 11/23/1984 | 11/23/1984 | TOR10-040D | P |
| 78 | 976418 | TOR0010 | 1 1213 COTA AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 11/21/1984 | 11/21/1984 | TOR10-040D | P |
| 84 | 39776 | TOR0010 | 3 2306 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1917 | 12/12/1984 | 12/12/1984 | TOR10-040D | P |
| 84 | 39631 | TOR0010 | 1 2260 TORRANCE BL | 200 | 2 | 1 | 1 | 1 | 4 | 1935 | 11/20/1984 | 11/20/1984 | TOR10-040D | P |
| 78 | 25275 | TOR0010 | 3 2166 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/01/1978 | 06/01/1978 | TOR10-040D | P |
| 75 | 719454 | TOR0010 | 3 2208 TORRANCE BLVD. | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 08/01/1975 | 08/01/1975 | TOR10-040E | P |
| 78 | 909566 | TOR0010 | 1 2172 TORR BL. | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 04/01/1978 | 04/01/1978 | TOR10-040E | P |
| 78 | 976079 | TOR0010 | 1 2166 TORR BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 10/01/1978 | 10/01/1978 | TOR10-040E | P |
| 78 | 25274 | TOR0010 | 3 2154 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 10/01/1978 | 10/01/1978 | TOR10-040E | P |
| 75 | 685902 | TOR0010 | 3 2208 TORRANCE BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 08/01/1975 | 08/01/1975 | TOR10-040E | P |
| 78 | 915722 | TOR0010 | 1 2172 TORR BL | 200 | 2 | 1 | 1 | 1 | 4 | 1922 | 04/01/1978 | 04/01/1978 | TOR10-040E | P |
| 78 | 990155 | TOR0010 | 1 2214 TORR BLVD | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 06/01/1978 | 06/01/1978 | TOR10-040E | P |
| 84 | 7450 | TOR0010 | 1 ON TORRANCE BL 12' W/W AMAPOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 09/11/1984 | 09/11/1984 | TOR10-102 | P |
| 84 | 7454 | TOR0010 | 1 ON TORRANCE BLVD 64' W/O AMAPOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1921 | 09/11/1984 | 09/11/1984 | TOR10-102 | P |
| 89 | 60021 | TOR0015 | 2 1724 DATE X CARSON | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 08/17/1989 | 08/17/1989 | TOR15-003A | C |
| 77 | 844465 | TOR0015 | 1 1726 DATE AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 08/01/1977 | 08/01/1977 | TOR15-003A | C |
| 78 | 909584 | TOR0015 | 1 CRENSHAW BL. & TOLEDO ST. | 800 | 8 | 1 | 1 | 1 | 4 | 1920 | 05/01/1978 | 05/01/1978 | TOR15-004 | P |
| 89 | 40349 | TOR0015 | 3 N/E CRN JEFFERSON/CRENSHAW | 800 | 8 | 1 | 1 | 1 | 4 | 1945 | 08/15/1989 | 08/15/1990 | TOR15-004A | C |
| 81 | 18634 | TOR0015 | 1 2341 JEFFERSON | 400 | 4 | 1 | 1 | 1 | 4 | 1920 | 06/12/1981 | 06/12/1981 | TOR15-008A | C |
| 75 | 719033 | TOR0015 | 1 OAK ST & JEFFERSON | 400 | 4 | 1 | 1 | 1 | 4 | 1927 | 01/01/1975 | 01/01/1975 | TOR15-008A | C |
| 85 | 35613 | TOR0015 | 1 2341 JEFFERSON | 400 | 4 | 1 | 1 | 1 | 4 | 1927 | 03/18/1985 | 03/18/1985 | TOR15-008A | C |
| 77 | 915774 | TOR0015 | 1 N/E COR OAK & JEFFERSON ST | 400 | 4 | 1 | 1 | 1 | 4 | 1927 | 07/01/1977 | 07/01/1977 | TOR15-008A | C |
| 86 | 38784 | TOR0015 | 2 2341 JEFFERSON ST | 400 | 4 | 1 | 1 | 1 | 4 | 1927 | 06/04/1986 | 06/18/1986 | TOR15-008A | C |
| 86 | 3255 | TOR0015 | 3 2303 JEFFERSON AVE | 400 | 4 | 1 | 1 | 1 | 4 | 1927 | 02/11/1986 | 02/11/1987 | TOR15-008A | C |
| 77 | 886063 | TOR0015 | 3 1633 ACACIA | 200 | 2 | 1 | 1 | 1 | 4 | 1928 | 12/01/1977 | 12/01/1977 | TOR15-009 | P |
| 83 | 22793 | TOR0015 | 3 BEHIND 1622 ACACIA | 200 | 2 | 1 | 1 | 1 | 4 | 1927 | 08/22/1983 | 04/22/1984 | TOR15-010 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRIO | Address or Location | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline Segment Number | Pipeline info (C=CURRENT P=PREVIOUS) |
|-------------------|-------------|-----------|-----------------------------------|-------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|-------------------------|--------------------------------------|
| | | | | | | | | | | | | | | |
| 84 - 51085 | TOR0015 | 1 | 1614 ACACIA AV | 200 | 1 | 1 | 1 | 1 | 4 | 1927 | 01/04/1984 | 01/04/1984 | TOR15-010 | P |
| 91 - 15091 | TOR0015 | 3 | 1621 S AMAPOLA AVE | 200 | 1 | 1 | 1 | 1 | 4 | 1956 | 10/03/1991 | 10/03/1991 | TOR15-012 | C |
| 91 - 7741 | TOR0015 | 1 | 1542 POST AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1912 | 08/15/1991 | 08/15/1991 | TOR15-013 | C |
| 81 - 11620 | TOR0015 | 3 | POST AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1912 | 07/07/1981 | 09/07/1981 | TOR15-013 | C |
| 86 - 3132 | TOR0015 | 1 | 1/S ALLEY N/CARSON ST & ALLEY W | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 01/20/1986 | 01/20/1986 | TOR15-015 | C |
| 89 - 40331 | TOR0015 | 3 | 2264 SONOMA ST | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 08/28/1989 | 02/28/1990 | TOR15-015 | C |
| 86 - 38890 | TOR0015 | 3 | 1627 AMAPOLA | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 06/23/1986 | 06/23/1986 | TOR15-015 | C |
| 86 - 37850 | TOR0015 | 2 | 1/S ALLEY N/CARSON ST & ALLEY | 200 | 2 | 1 | 1 | 1 | 4 | 1924 | 01/20/1986 | 01/20/1986 | TOR15-015 | C |
| 84 - 39787 | TOR0009 | 3 | 1512 EL PRADO AVE | 200 | 2 | 1 | 1 | 1 | 2 | 1950 | 12/14/1984 | 12/14/1984 | TOR16-001 | P |
| 84 - 30764 | TOR0016 | 2 | 1515 ARLINGTON | 200 | 2 | 1 | 1 | 1 | 4 | 1912 | 03/09/1984 | 03/09/1984 | TOR16-001 | P |
| 80 - 1869 | TOR0016 | 3 | 1528 EL PRADO | 200 | 2 | 1 | 1 | 1 | 2 | 1912 | 06/18/1980 | 07/18/1980 | TOR16-001 | P |
| 84 - 39786 | TOR0009 | 3 | 1512 EL PRADO AV | 200 | 2 | 1 | 1 | 1 | 2 | 1950 | 12/14/1984 | 12/14/1984 | TOR16-001 | P |
| 83 - 50532 | TOR0016 | 3 | 1613 CRAVENS AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 06/24/1983 | 06/24/1983 | TOR16-004 | C |
| 81 - 18595 | TOR0016 | 2 | 1617 CRAVENS | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 06/03/1981 | 06/03/1981 | TOR16-004 | C |
| 82 - 21742 | TOR0016 | 2 | 1613 1/2 CRAVEN | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 06/07/1982 | 06/21/1982 | TOR16-004 | C |
| 90 - 10100 | TOR0016 | 3 | 1613 CRAVENS AV | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 12/27/1990 | 01/27/1991 | TOR16-004 | C |
| 77 - 876993 | TOR0016 | 3 | 1600 CABRILLO | 600 | 6 | 1 | 1 | 1 | 4 | 1941 | 07/13/1983 | 07/13/1983 | TOR16-012 | C |
| 83 - 50588 | TOR0016 | 3 | N/E CORNER BORDER AVE & CARSON | 600 | 6 | 1 | 1 | 1 | 2 | 1941 | 08/01/1977 | 08/01/1977 | TOR16-010 | P |
| 77 - 908168 | TOR0016 | 1 | 1/S CAZSON/BORDER AT RR CROSSING | 600 | 6 | 1 | 1 | 1 | 2 | 1941 | 06/01/1977 | 06/01/1977 | TOR16-012 | C |
| 83 - 37786 | TOR0016 | 2 | N/E CORNER BORDER AVE & CARSON AV | 600 | 6 | 1 | 1 | 1 | 4 | 1941 | 03/18/1980 | 03/18/1980 | TOR16-012 | C |
| 80 - 8376 | TOR0016 | 1 | 1905 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 05/15/1984 | 02/15/1985 | TOR16-015 | P |
| 84 - 56785 | TOR0016 | 3 | 1740 ABALONE AV | 400 | 4 | 1 | 1 | 1 | 3 | 1913 | 05/01/1986 | 05/01/1987 | TOR16-015 | P |
| 86 - 3583 | TOR0016 | 3 | 1805 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 09/01/1976 | 09/01/1976 | TOR16-015 | P |
| 79 - 848781 | TOR0016 | 3 | 1740 ABALONE AVE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 08/01/1979 | 08/01/1979 | TOR16-015 | P |
| 76 - 150273 | TOR0016 | 3 | 1740 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 07/01/1976 | 07/01/1976 | TOR16-015 | P |
| 76 - 848756 | TOR0016 | 3 | 1905 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 05/01/1986 | 05/01/1987 | TOR16-015 | P |
| 86 - 3584 | TOR0016 | 3 | 1907 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 06/04/1981 | 06/04/1982 | TOR16-015 | P |
| 81 - 11367 | TOR0016 | 3 | OPPOSITE OF 1744 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 06/04/1981 | 10/04/1981 | TOR16-015 | P |
| 81 - 11366 | TOR0016 | 3 | 1809 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 08/01/1979 | 08/01/1979 | TOR16-015 | P |
| 79 - 150271 | TOR0016 | 3 | 1820 ABALONE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 05/08/1987 | 05/08/1987 | TOR16-015 | P |
| 87 - 11771 | TOR0016 | 2 | 1915 ABALONE AVE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 08/01/1977 | 08/01/1977 | TOR16-015 | P |
| 77 - 876989 | TOR0016 | 3 | 1905 ABALONE AVE | 400 | 4 | 1 | 1 | 1 | 4 | 1913 | 05/04/1988 | 06/04/1988 | TOR16-015A | C |
| 79 - 150270 | TOR0016 | 3 | ABALONE AVE 60' N/N PL 220TH ST | 400 | 4 | 1 | 1 | 1 | 4 | 1968 | 05/08/1986 | 05/08/1986 | TOR16-016 | C |
| 88 - 20159 | TOR0016 | 3 | 1907 ABALONE AVENUE | 400 | 4 | 1 | 1 | 1 | 4 | 1912 | 07/01/1976 | 07/01/1976 | TOR16-016 | C |
| 86 - 38623 | TOR0016 | 2 | 1962 CARSON | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 07/01/1975 | 07/01/1975 | TOR16-016 | C |
| 76 - 844796 | TOR0016 | 2 | 1720 GRAMERCY AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 05/02/1988 | 05/02/1988 | TOR16-016 | C |
| 73 - 570305 | TOR0016 | 1 | 1719 GRAMERCY AVE | 300 | 3 | 1 | 1 | 1 | 4 | 1912 | 06/04/1981 | 07/04/1981 | TOR16-016 | C |
| 88 - 55465 | TOR0016 | 1 | 1715 CABRILLO AVE | 300 | 3 | 1 | 1 | 1 | 6 | 1912 | 08/01/1978 | 08/01/1978 | TOR16-016 | C |
| 81 - 11368 | TOR0016 | 3 | 1/S CABRILLO & ALLEY S/CARSON | 300 | 3 | 1 | 1 | 1 | 1 | 1912 | 08/01/1975 | 08/01/1975 | TOR16-016 | C |
| 78 - 935947 | TOR0016 | 3 | 1/S OF ALLEY S OF CARSON/ANDRE A | 300 | 3 | 1 | 1 | 1 | 4 | 1913 | 06/16/1980 | 06/16/1980 | TOR16-016 | C |
| 75 - 719465 | TOR0016 | 1 | 2029 BORDER | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 12/19/1990 | 12/19/1991 | TOR16-017 | P |
| 80 - 8833 | TOR0016 | 2 | 2113 BORDER AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 03/26/1986 | 03/26/1986 | TOR16-017 | P |
| 90 - 10090 | TOR0016 | 3 | 1733 BORDER AV | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 12/19/1990 | 12/19/1990 | TOR16-017 | P |
| 86 - 38316 | TOR0016 | 3 | 1820 CABRILLO | 200 | 2 | 1 | 1 | 1 | 4 | 1913 | 03/12/1990 | 11/12/1990 | TOR16-017 | P |
| 90 - 10088 | TOR0016 | 3 | 218TH ST & BORDER AV | 200 | 2 | 1 | 1 | 1 | 4 | 1968 | 10/01/1978 | 10/01/1978 | TOR16-021 | P |
| 78 - 2300 | TOR0016 | 3 | ALLEY W/O BORDER AV | 200 | 2 | 1 | 1 | 1 | 4 | 1926 | 06/01/1976 | 06/01/1976 | TOR17-005 | P |
| 78 - 989851 | TOR0016 | 2 | 1914 W 218TH ST. | 200 | 2 | 1 | 1 | 1 | 4 | 1926 | 03/01/1979 | 03/01/1979 | TOR17-005 | P |
| 76 - 800623 | TOR0017 | 2 | 2063 LINCOLN AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1923 | 10/01/1975 | 10/01/1975 | TOR17-005 | P |
| 79 - 72658 | TOR0017 | 3 | 2409 ARLINGTON AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1923 | 10/01/1975 | 10/01/1975 | TOR17-005 | P |
| 75 - 744164 | TOR0017 | 3 | 2409 ARLINGTON AVE | 200 | 2 | 1 | 1 | 1 | 4 | 1923 | 10/01/1975 | 10/01/1975 | TOR17-005 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK Prio | Address or Location | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline info | |
|-------------------|-------------|-----------|-----------------------------------|-------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|----------------|---------------------------------|
| | | | | | | | | | | | | | Segment Number | Pipeline (C=CURRENT P=PREVIOUS) |
| 79 - 72681 | TOR0017 | 3 | S/E COR SANTA FE & ARLINGTON | 4 | | 1 | 1 | 1 | 4 | 1922 | 04/01/1979 | 04/01/1979 | TOR17-006 | P |
| 76 - 845298 | TOR0017 | 3 | ARLINGTON & PLAZA DEL AMO | 4 | | 1 | 1 | 1 | 4 | 1922 | 08/01/1976 | 08/01/1976 | TOR17-006A | C |
| 84 - 38699 | TOR0017 | 3 | N/E COR OF LINCOLN & ARLINGTON AV | 4 | | 4 | 1 | 1 | 4 | 1922 | 03/23/1984 | 03/23/1984 | TOR17-006A | C |
| 86 - 38883 | TOR0017 | 3 | 2410 ARLINGTON AVE | 4 | | 1 | 1 | 1 | 4 | 1922 | 06/20/1986 | 06/20/1986 | TOR17-006A | C |
| 79 - 105707 | TOR0017 | 3 | 2409 ARLINGTON | 4 | | 1 | 1 | 1 | 4 | 1922 | 10/01/1979 | 10/01/1979 | TOR17-006A | C |
| 78 - 976047 | TOR0017 | 3 | 2202 ARLINGTON AVE | 4 | | 1 | 1 | 1 | 4 | 1956 | 11/01/1978 | 11/01/1978 | TOR17-0068 | P |
| 90 - 2358 | TOR0017 | 3 | 2030 SANTA FE AVE | 3 | | 1 | 1 | 1 | 4 | 1930 | 05/11/1990 | 02/11/1991 | TOR17-0088 | C |
| 83 - 29958 | TOR0017 | 2 | 1966 1/2 PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1941 | 05/13/1983 | 05/13/1983 | TOR17-012A | C |
| 78 - 992455 | TOR0017 | 2 | 1912 PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1916 | 09/01/1978 | 09/01/1978 | TOR17-014A | C |
| 79 - 72659 | TOR0017 | 3 | 1912 PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1916 | 03/01/1979 | 03/01/1979 | TOR17-014A | C |
| 85 - 1065 | TOR0017 | 3 | 1912 PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1965 | 05/15/1985 | 01/15/1986 | TOR17-015 | C |
| 83 - 22621 | TOR0017 | 3 | 2303 ANDREO | 2 | | 1 | 1 | 1 | 4 | 1965 | 05/17/1983 | 01/17/1984 | TOR17-016B | C |
| 78 - 933845 | TOR0017 | 1 | ALLEY S/O PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1916 | 07/01/1978 | 07/01/1978 | TOR17-017 | P |
| 78 - 990402 | TOR0017 | 1 | ALLEY S/O PLAZA DEL AMO & | 2 | | 1 | 1 | 1 | 4 | 1916 | 07/01/1978 | 07/01/1978 | TOR17-017 | P |
| 78 - 914046 | TOR0017 | 1 | 2408 CABRILLO | 2 | | 1 | 1 | 1 | 4 | 1916 | 06/01/1978 | 06/01/1978 | TOR17-017 | P |
| 78 - 990256 | TOR0017 | 1 | 1880 PLAZA DEL AMO | 2 | | 1 | 1 | 1 | 4 | 1916 | 06/01/1978 | 06/01/1978 | TOR17-017 | P |
| 83 - 22627 | TOR0017 | 3 | 835 MARINETTE AVE | 3 | | 1 | 1 | 1 | 4 | 1949 | 05/17/1983 | 02/17/1984 | TOR17-023 | C |
| 78 - 990274 | TOR0017 | 2 | 2219 BORDER AVE | 2 | | 1 | 1 | 1 | 4 | 1913 | 06/01/1978 | 06/01/1978 | TOR17-027 | P |
| 77 - 876994 | TOR0017 | 3 | 2213 BORDER AVE | 2 | | 1 | 1 | 1 | 4 | 1913 | 08/01/1977 | 08/01/1977 | TOR17-027 | P |
| 78 - 990257 | TOR0017 | 2 | 2230 CABRILLO | 2 | | 1 | 1 | 1 | 4 | 1913 | 06/01/1978 | 06/01/1978 | TOR17-027 | P |
| 78 - 914049 | TOR0017 | 1 | 2207 BOLDER AVE | 2 | | 1 | 1 | 1 | 4 | 1913 | 06/01/1978 | 06/01/1978 | TOR17-027 | P |
| 84 - 51725 | TOR0017 | 3 | 1780 PLAZA DEL AMO | 4 | | 1 | 1 | 1 | 4 | 1923 | 07/31/1984 | 08/31/1984 | TOR17-031A | C |
| 79 - 150264 | TOR0017 | 3 | 22500 BLOCK WESTERN | 2 | | 1 | 1 | 1 | 2 | 1949 | 09/01/1979 | 09/01/1979 | TOR17-031A | C |
| 77 - 908120 | TOR0017 | 1 | 22501 WESTERN AVE | 2 | | 1 | 1 | 1 | 2 | 1949 | 07/01/1977 | 07/01/1977 | TOR17-031A | C |
| 83 - 22605 | TOR0017 | 3 | 22501 WESTERN | 4 | | 1 | 1 | 1 | 2 | 1981 | 06/15/1983 | 07/15/1983 | TOR17-031C | C |
| 79 - 150265 | TOR0017 | 3 | 1700 BLOCK PLAZA DEL AMO | 8 | | 1 | 1 | 1 | 2 | 1949 | 09/01/1979 | 09/01/1979 | TOR17-032A | C |
| 81 - 18581 | TOR0017 | 3 | NORTHWEST CORNER PLAZA DEL AMO & | 2 | | 1 | 1 | 1 | 2 | 1952 | 06/02/1981 | 06/02/1981 | TOR17-035 | C |
| 85 - 1068 | TOR0017 | 3 | 1921 22ND ST | 2 | | 1 | 1 | 1 | 2 | 1922 | 05/15/1985 | 02/15/1986 | TOR17-040 | C |
| 71 - 256014 | TOR0009 | 1 | LLEWELLYN & TORRANCE BL | 2 | | 1 | 1 | 2 | 4 | 1931 | 05/01/1971 | 05/01/1971 | TOR09-001 | P |
| 72 - 460197 | TOR0009 | 2 | ALLEY W/CRAVENS AVE | 2 | | 1 | 1 | 2 | 4 | 1913 | 06/01/1972 | 06/01/1972 | TOR09-001 | C |
| 74 - 704347 | TOR0009 | 3 | ALLEY BETWEEN ENGRACIA AND POST | 3 | | 1 | 1 | 6 | 4 | 1912 | 12/01/1974 | 12/01/1974 | TOR09-004A | P |
| 86 - 26735 | TOR0009 | 1 | 1423 POST AV | 3 | | 1 | 1 | 2 | 3 | 1976 | 08/18/1986 | 08/18/1986 | TOR09-004A | C |
| 84 - 51729 | TOR0009 | 3 | 2014 TORRANCE BLVD XST SARTORI | 3 | | 1 | 1 | 2 | 4 | 1949 | 08/10/1984 | 08/10/1984 | TOR09-005 | P |
| 70 - 127157 | TOR0009 | 2 | 2ND ALLEY S/TOR BLVD AND W/POST A | 2 | | 1 | 1 | 2 | 4 | 1913 | 09/01/1970 | 09/01/1970 | TOR09-005 | C |
| 82 - 22028 | TOR0009 | 3 | 1330 EL PRADO | 2 | | 1 | 1 | 5 | 4 | 1949 | 09/16/1982 | 09/16/1983 | TOR09-008 | C |
| 80 - 2097 | TOR0009 | 3 | 1414 CRAVENS | 2 | | 1 | 1 | 2 | 4 | 1954 | 09/05/1980 | 03/05/1981 | TOR09-009 | C |
| 74 - 686428 | TOR0009 | 3 | 1407 SARTORI | 3 | | 1 | 1 | 2 | 2 | 1949 | 08/01/1974 | 08/01/1974 | TOR09-010 | C |
| 70 - 127076 | TOR0009 | 2 | 1434 MARCELINA | 2 | | 1 | 1 | 2 | 4 | 1913 | 09/01/1970 | 09/01/1970 | TOR09-011 | P |
| 70 - 127077 | TOR0009 | 2 | ALLEY E/O MARCELINA | 3 | | 1 | 1 | 2 | 4 | 1912 | 09/01/1970 | 09/01/1970 | TOR09-011 | P |
| 70 - 127086 | TOR0009 | 2 | 1434 MARCELINA | 3 | | 1 | 1 | 2 | 4 | 1912 | 09/01/1970 | 09/01/1970 | TOR09-011 | P |
| 83 - 30124 | TOR0009 | 3 | N/E CORNER ALLEY E/O SARTORI | 2 | | 1 | 1 | 2 | 4 | 1926 | 07/20/1983 | 07/20/1983 | TOR09-013A | C |
| 89 - 40449 | TOR0009 | 3 | ALLEY W/O VAN NESS AT TORRANCE BL | 8 | | 1 | 1 | 2 | 3 | 1927 | 08/22/1989 | 08/22/1990 | TOR09-013A | C |
| 71 - 190166 | TOR0009 | 2 | TOR BL E/ LLEWELLYN | 8 | | 1 | 1 | 6 | 4 | 1912 | 05/01/1971 | 05/01/1971 | TOR09-015 | P |
| 71 - 208016 | TOR0009 | 1 | 1853 TORR BLVD | 8 | | 1 | 1 | 4 | 4 | 1912 | 10/01/1971 | 10/01/1971 | TOR09-015 | P |
| 85 - 35024 | TOR0010 | 2 | 1313 DATE | 1 | | 1 | 1 | 2 | 1 | 1939 | 01/10/1985 | 01/10/1985 | TOR10-005D | C |
| 71 - 111119 | TOR0010 | 1 | 1/S GREINSHAW BL ELDORADO ST | 3 | | 1 | 1 | 2 | 4 | 1924 | 07/01/1971 | 07/01/1971 | TOR10-006 | P |
| 90 - 2616 | TOR0010 | 3 | 2515 EL DORADO ST | 2 | | 1 | 1 | 2 | 3 | 1927 | 10/30/1990 | 12/30/1990 | TOR10-007A | C |
| 72 - 190437 | TOR0010 | 1 | 2555 SONOMA ST | 2 | | 1 | 1 | 2 | 4 | 1924 | 06/01/1972 | 06/01/1972 | TOR10-0088 | C |
| 78 - 914288 | TOR0010 | 1 | 2555 SONOMA | 2 | | 1 | 1 | 2 | 4 | 1935 | 07/01/1978 | 07/01/1978 | TOR10-009 | P |
| 72 - 459902 | TOR0010 | 3 | 1512 DATE AVE | 2 | | 1 | 1 | 2 | 4 | 1924 | 08/01/1972 | 08/01/1972 | TOR10-009 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRIO | Address or Location | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline Info | |
|-------------------|-------------|-----------|-------------------------------------|-------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|----------------|------|
| | | | | | | | | | | | | | Segment Number | Pipe |
| 72 | -460371 | TOR0010 | 1 1416 CRENSHAW BLVD | 200 | | 1 | 1 | 2 | 4 | 1927 | 07/01/1972 | 07/01/1972 | TOR10-011 | P |
| 73 | -503780 | TOR0010 | 3 2371 TORR BLVD. | 300 | | 1 | 1 | 2 | 4 | 1927 | 06/01/1973 | 06/01/1973 | TOR10-012C | C |
| 82 | - 21720 | TOR0010 | 1 1104 AMAPOLA | 200 | | 1 | 1 | 2 | 3 | 1924 | 06/09/1982 | 09/09/1982 | TOR10-012D | C |
| 73 | -214711 | TOR0010 | 3 2325-23-TORR. BL. ALLEY N/O TORR. | 200 | | 3 | 2 | 2 | 4 | 1922 | 07/01/1973 | 07/01/1973 | TOR10-012D | P |
| 82 | - 21427 | TOR0010 | 3 1104 AMAPOLA | 200 | | 1 | 1 | 2 | 3 | 1924 | 06/09/1982 | 07/09/1982 | TOR10-012D | P |
| 84 | - 31450 | TOR0010 | 2 811 BEECH AVE | 200 | | 2 | 1 | 2 | 4 | 1928 | 11/16/1984 | 11/30/1984 | TOR10-013 | P |
| 86 | - 60326 | TOR0010 | 3 1020 ACACIA AVE | 200 | | 1 | 2 | 2 | 4 | 1927 | 11/26/1986 | 11/26/1987 | TOR10-015 | P |
| 73 | -503935 | TOR0010 | 2 2263 TORR BLVD | 200 | | 1 | 2 | 1 | 4 | 1917 | 06/01/1973 | 06/01/1973 | TOR10-019B | P |
| 71 | -190878 | TOR0010 | 1 1217 BEECH AVE | 200 | | 1 | 2 | 1 | 4 | 1927 | 09/01/1971 | 09/01/1971 | TOR10-024A | P |
| 71 | -190876 | TOR0010 | 1 1217 BEECH AVE | 200 | | 1 | 2 | 1 | 4 | 1927 | 09/01/1971 | 09/01/1971 | TOR10-024A | P |
| 82 | - 22170 | TOR0010 | 3 1230 CRENSHAW BLVD | 200 | | 1 | 2 | 1 | 4 | 1927 | 12/17/1982 | 02/17/1983 | TOR10-024A | P |
| 83 | - 37585 | TOR0015 | 3 1424 BEECH AVE | 200 | | 1 | 2 | 1 | 4 | 1927 | 04/25/1983 | 04/25/1983 | TOR10-025 | P |
| 73 | -643336 | TOR0010 | 3 2414 SONOMA ST | 200 | | 1 | 2 | 1 | 4 | 1927 | 12/01/1973 | 12/01/1973 | TOR10-025 | P |
| 78 | -933836 | TOR0010 | 1 1221 ACACIA AVE | 200 | | 1 | 2 | 1 | 4 | 1927 | 06/01/1978 | 06/01/1978 | TOR10-025 | P |
| 71 | -190225 | TOR0010 | 3 ELDORADO SE & ALLEY E/O ACACIA | 200 | | 1 | 2 | 1 | 4 | 1927 | 10/01/1971 | 10/01/1971 | TOR10-026 | P |
| 84 | - 51893 | TOR0010 | 3 1315 - B MADRID | 200 | | 1 | 4 | 2 | 2 | 1927 | 09/20/1984 | 09/20/1984 | TOR10-026 | P |
| 70 | -188101 | TOR0010 | 1 1319 ARLINGTON | 200 | | 1 | 2 | 1 | 4 | 1922 | 10/01/1970 | 10/01/1970 | TOR10-036 | P |
| 92 | - 82210 | TOR0010 | 3 1422 ENGRACIA AV | 300 | | 1 | 1 | 2 | 4 | 1900 | 08/12/1992 | 08/12/1992 | TOR10-039A | C |
| 78 | -976080 | TOR0010 | 2 2166 TORR BLVD | 200 | | 2 | 1 | 2 | 4 | 1922 | 10/01/1978 | 10/01/1978 | TOR10-040D | P |
| 73 | -503939 | TOR0010 | 2 1213 COTA AVE | 200 | | 1 | 2 | 1 | 4 | 1921 | 06/01/1973 | 06/01/1973 | TOR10-040D | P |
| 74 | -686329 | TOR0010 | 3 2208 TORRANCE BLVD | 200 | | 1 | 2 | 1 | 4 | 1922 | 07/01/1974 | 07/01/1974 | TOR10-040E | P |
| 84 | - 7451 | TOR0010 | 1 ON TORRANCE BLVD 27/ W/W AMAPOLA | 200 | | 1 | 2 | 1 | 4 | 1921 | 09/11/1984 | 09/11/1984 | TOR10-102 | P |
| 77 | -84466 | TOR0015 | 1 1726 DATE AVE | 200 | | 1 | 2 | 1 | 4 | 1927 | 08/01/1977 | 08/01/1977 | TOR15-003A | C |
| 72 | -208364 | TOR0015 | 3 2303 JEFFERSON | 400 | | 1 | 1 | 2 | 4 | 1927 | 05/01/1982 | 05/01/1982 | TOR15-008A | C |
| 89 | - 40348 | TOR0015 | 1 2414 SONOMA ST | 200 | | 1 | 1 | 2 | 4 | 1927 | 08/15/1990 | 08/15/1990 | TOR15-008A | C |
| 79 | -105354 | TOR0015 | 3 1631 AMAPOLA AVE | 300 | | 1 | 2 | 1 | 4 | 1972 | 08/01/1979 | 08/01/1979 | TOR15-009 | P |
| 86 | - 37998 | TOR0015 | 3 1614 COTA AVE | 300 | | 1 | 2 | 1 | 4 | 1921 | 02/10/1986 | 02/10/1986 | TOR15-012B | C |
| 71 | -179615 | TOR0015 | 2 CARSON ST & COTA AV | 300 | | 1 | 6 | 2 | 2 | 1912 | 05/01/1971 | 05/01/1971 | TOR15-012C | C |
| 92 | - 80532 | TOR0015 | 1 1452 EL PRADO | 200 | | 1 | 2 | 1 | 4 | 1913 | 03/18/1992 | 03/18/1992 | TOR15-015 | C |
| 78 | -935946 | TOR0016 | 3 N/E CORNER/CARSON & ALLEY E CABRI | 600 | | 1 | 2 | 1 | 4 | 1913 | 08/01/1978 | 08/01/1978 | TOR16-001 | P |
| 72 | -190415 | TOR0016 | 1 1871 CARSON ST | 400 | | 1 | 1 | 2 | 4 | 1941 | 02/01/1972 | 02/01/1972 | TOR16-010 | C |
| 71 | -180366 | TOR0016 | 3 BORDER AV AND CARSON STREET | 400 | | 1 | 2 | 1 | 4 | 1912 | 06/01/1978 | 06/01/1978 | TOR16-013 | P |
| 72 | -459961 | TOR0016 | 2 1645 ARLINGTON | 400 | | 1 | 2 | 1 | 4 | 1922 | 10/01/1972 | 10/01/1972 | TOR16-014 | P |
| 71 | -180357 | TOR0016 | 3 2118 CARSON STREET | 400 | | 1 | 4 | 2 | 4 | 1912 | 03/01/1971 | 03/01/1971 | TOR16-014 | P |
| 71 | -180358 | TOR0016 | 3 1645 ARLINGTON AVENUE | 400 | | 1 | 1 | 2 | 4 | 1912 | 03/01/1971 | 03/01/1971 | TOR16-014 | P |
| 85 | - 35245 | TOR0016 | 3 1746 ABALONE AVE | 400 | | 1 | 2 | 1 | 3 | 1913 | 02/06/1985 | 02/06/1985 | TOR16-015 | P |
| 73 | -684156 | TOR0016 | 3 1740 ABALONE AV | 400 | | 1 | 1 | 2 | 4 | 1913 | 12/01/1973 | 12/01/1973 | TOR16-015 | P |
| 80 | - 1867 | TOR0016 | 3 1740 ABALONE AVE | 400 | | 1 | 1 | 2 | 3 | 1913 | 06/18/1980 | 07/18/1980 | TOR16-015 | P |
| 71 | -188370 | TOR0016 | 3 1720 CABRILLO | 300 | | 1 | 1 | 2 | 4 | 1919 | 01/01/1971 | 01/01/1971 | TOR16-016 | C |
| 71 | -190956 | TOR0016 | 2 1718 ANDREO | 300 | | 1 | 1 | 2 | 4 | 1912 | 09/01/1971 | 09/01/1971 | TOR16-016 | C |
| 74 | -684175 | TOR0016 | 3 2012 CABRILLO | 200 | | 1 | 1 | 2 | 4 | 1913 | 05/01/1974 | 05/01/1974 | TOR16-016C | P |
| 74 | -684174 | TOR0016 | 3 2025 BORDER AV | 200 | | 1 | 1 | 2 | 4 | 1913 | 05/01/1974 | 05/01/1974 | TOR16-016C | P |
| 73 | -502783 | TOR0016 | 3 2104 CABRELO AVE | 200 | | 1 | 2 | 1 | 4 | 1913 | 05/01/1973 | 05/01/1973 | TOR16-016D | C |
| 71 | -180373 | TOR0016 | 3 2100 BLK/BORDER AVENUE | 400 | | 1 | 1 | 2 | 4 | 1918 | 04/01/1971 | 04/01/1971 | TOR16-016D | C |
| 71 | -180371 | TOR0016 | 3 2117 BORDER AVENUE | 400 | | 1 | 1 | 2 | 4 | 1918 | 04/01/1971 | 04/01/1971 | TOR16-016D | C |
| 90 | - 11358 | TOR0016 | 1 1817 BORDER AV | 200 | | 1 | 1 | 2 | 4 | 1913 | 12/19/1990 | 12/19/1990 | TOR16-017 | P |
| 71 | -188206 | TOR0016 | 2 1876 BORDER | 200 | | 1 | 1 | 2 | 4 | 1923 | 02/01/1971 | 02/01/1971 | TOR16-017 | P |
| 91 | - 10111 | TOR0016 | 3 ALLEY EAST OF CABRILLO | 200 | | 1 | 1 | 2 | 4 | 1913 | 01/08/1991 | 01/08/1991 | TOR16-017 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS LEAK SHEET PRIO | Address or Location | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Installed | Year | Detect Date | Action Date | Pipeline info | |
|-------------------|-----------------------|-------------------------------------|-------------------|----------|---------|-------|-------------|----------|-----------|------|-------------|-------------|----------------|--------------------------------------|
| | | | | | | | | | | | | | Segment Number | Pipeline info (C=CURRENT P=PREVIOUS) |
| 90 - 10092 | TOR0016 | 3 1907 BORDER AV | 200 | 2 | 1 | 4 | 2 | 1 | 4 | 1913 | 12/19/1990 | 12/19/1991 | TOR16-017 | P |
| 90 - 10091 | TOR0016 | 3 1720 CABRILLO AV | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1957 | 12/19/1990 | 01/19/1991 | TOR16-017A | P |
| 74 - 686192 | TOR0016 | 1 1720 MARTINA | 300 | 3 | 1 | 1 | 2 | 1 | 4 | 1913 | 04/01/1974 | 04/01/1974 | TOR16-018 | P |
| 72 - 460196 | TOR0017 | 2 ALLEY S/CARSON ST | 300 | 3 | 1 | 1 | 2 | 1 | 4 | 1913 | 06/01/1972 | 06/01/1972 | TOR16-018 | P |
| 73 - 513287 | TOR0016 | 1 1743 CABRILLO | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1912 | 03/01/1973 | 03/01/1973 | TOR16-021 | P |
| 71 - 192899 | TOR0016 | 2 1917 19 W 218TH STREET | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1912 | 04/01/1971 | 04/01/1971 | TOR16-021 | P |
| 71 - 180361 | TOR0016 | 2 1753 CABRILLO AVENUE | 200 | 2 | 1 | 4 | 2 | 1 | 4 | 1912 | 05/01/1971 | 05/01/1971 | TOR16-021 | P |
| 72 - 460194 | TOR0016 | 2 1723 MARTINA AVE | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1913 | 06/01/1972 | 06/01/1972 | TOR16-028 | P |
| 74 - 704011 | TOR0017 | 3 2067 LINCOLN AVE | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1923 | 08/01/1974 | 08/01/1974 | TOR17-005 | P |
| 71 - 190782 | TOR0017 | 2 2415 ARLINGTON | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1926 | 11/01/1971 | 11/01/1971 | TOR17-005 | P |
| 74 - 643175 | TOR0017 | 3 2503 ARLINGTON AVE | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1923 | 07/01/1974 | 07/01/1974 | TOR17-005A | P |
| 76 - 853719 | TOR0017 | 3 ARLINGTON & PLAZA DEL AMO | 400 | 4 | 1 | 4 | 2 | 6 | 4 | 1922 | 09/01/1976 | 09/01/1976 | TOR17-006A | C |
| 73 - 570307 | TOR0017 | 3 EAST SIDE OF ARLINGTON&PLAZADELAM | 400 | 4 | 1 | 1 | 2 | 1 | 4 | 1922 | 08/01/1973 | 08/01/1973 | TOR17-006A | C |
| 85 - 1066 | TOR0017 | 3 2732 ANDREO | 400 | 4 | 1 | 1 | 2 | 6 | 4 | 1923 | 05/15/1985 | 04/15/1986 | TOR17-009 | C |
| 85 - 1064 | TOR0017 | 3 2407 GRAMERCY AVE | 100 | 1 | 1 | 1 | 2 | 3 | 1 | 1943 | 05/15/1985 | 01/15/1986 | TOR17-011 | C |
| 78 - 992421 | TOR0017 | 3 1912 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1916 | 11/01/1978 | 11/01/1978 | TOR17-014A | C |
| 74 - 704013 | TOR0017 | 3 1912 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1965 | 10/01/1974 | 10/01/1974 | TOR17-015 | C |
| 91 - 7617 | TOR0017 | 1 2413 CABRILLO ALLEY BEHIND | 200 | 2 | 1 | 1 | 2 | 1 | 4 | 1941 | 05/14/1991 | 05/14/1991 | TOR17-018 | C |
| 79 - 150267 | TOR0017 | 3 2213 BORDER | 200 | 2 | 1 | 1 | 2 | 1 | 3 | 1913 | 08/01/1979 | 08/01/1979 | TOR17-027 | P |
| 81 - 18659 | TOR0017 | 3 N/W CORN O/PLAZA DE AMO/WESTERN | 400 | 4 | 1 | 1 | 2 | 2 | 2 | 1949 | 06/17/1981 | 06/17/1981 | TOR17-031C | P |
| 78 - 914045 | TOR0017 | 1 22501 WESTERN AVE | 400 | 4 | 1 | 4 | 2 | 4 | 2 | 1949 | 07/01/1978 | 07/01/1978 | TOR17-031C | P |
| 73 - 684158 | TOR0017 | 3 1600 226TH ST | 200 | 2 | 1 | 1 | 2 | 2 | 2 | 1947 | 12/01/1973 | 12/01/1973 | TOR17-036B | C |
| 89 - 1514 | TOR0009 | 1 1955 TORRANCE BL | 600 | 6 | 1 | 1 | 4 | 4 | 4 | 1900 | 05/05/1989 | 05/05/1989 | TOR09-014A | C |
| 88 - 55883 | TOR0015 | 1 2800 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 4 | 5 | 6 | 1988 | 07/20/1988 | 07/20/1988 | TOR15-016C | C |
| 87 - 12544 | TOR0015 | 1 2573 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 4 | 3 | 6 | 1987 | 09/16/1987 | 09/16/1987 | TOR15-016C | C |
| 85 - 37220 | TOR0015 | 1 PLAZA DEL AMO & CARSON | 200 | 2 | 1 | 1 | 4 | 3 | 6 | 1985 | 10/14/1985 | 10/14/1985 | TOR15-016C | C |
| 88 - 55144 | TOR0015 | 1 2800 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 4 | 6 | 6 | 1985 | 02/06/1988 | 02/06/1988 | TOR15-016C | C |
| 89 - 1672 | TOR0015 | 1 2800 PLAZA DEL AMO | 200 | 2 | 1 | 1 | 4 | 6 | 6 | 1989 | 06/13/1989 | 06/13/1989 | TOR15-016C | C |
| 77 - 856089 | TOR0009 | 3 POST AVE & ALLEY W/O SARTORI | 300 | 3 | 1 | 3 | 8 | 3 | 4 | 1912 | 01/01/1977 | 01/01/1977 | TOR09-004B | P |
| 84 - 51900 | TOR0010 | 1 1/S CRENSHAW & SONOMA | 200 | 2 | 1 | 1 | 8 | 2 | 6 | 1983 | 09/21/1984 | 09/21/1984 | TOR10-008 | C |
| 72 - 460266 | TOR0009 | 3 1414 CRAVENS | 200 | 2 | 1 | 3 | 9 | 6 | 4 | 1924 | 07/01/1971 | 07/01/1971 | TOR10-006 | P |
| 71 - 190015 | TOR0010 | 1 1/S ELDORADO CRENSHAW | 300 | 3 | 1 | 4 | 9 | 6 | 4 | 1924 | 07/01/1971 | 07/01/1971 | TOR10-011 | P |
| 91 - 15485 | TOR0010 | 1 1/S ELDORADO ST CRENSHAW | 200 | 2 | 1 | 3 | 9 | 6 | 4 | 1917 | 12/05/1984 | 12/05/1984 | TOR10-020C | C |
| 84 - 39720 | TOR0010 | 1 819 PORTOLA | 200 | 2 | 1 | 1 | 9 | 1 | 4 | 1927 | 09/01/1971 | 09/01/1971 | TOR10-024A | P |
| 71 - 190877 | TOR0010 | 1 1217 BEECH AVE | 200 | 2 | 1 | 3 | 9 | 6 | 4 | 1927 | 09/01/1970 | 09/01/1970 | TOR09-010 | P |
| 70 - 127078 | TOR0009 | 1 1304 EL PRADO | 300 | 3 | 1 | 4 | 10 | 4 | 4 | 1927 | 08/17/1989 | 08/17/1989 | TOR10-012C | C |
| 89 - 60025 | TOR0010 | 3 2371 TORRANCE BLVD | 300 | 3 | 1 | 2 | 10 | 4 | 4 | 1983 | 02/09/1990 | 02/09/1990 | TOR10-024A | C |
| 90 - 7035 | TOR0010 | 1 1222 CRENSHAW BLVD | 300 | 3 | 1 | 2 | 10 | 3 | 6 | 1937 | 06/01/1975 | 06/01/1975 | TOR10-039 | P |
| 75 - 686098 | TOR0010 | 2 1504 ENGRACIA AVE | 300 | 3 | 1 | 1 | 10 | 4 | 4 | 1913 | 02/01/1971 | 02/01/1971 | TOR15-015 | C |
| 71 - 179616 | TOR0015 | 1 1623 COTA AVE | 200 | 2 | 1 | 4 | 10 | 6 | 4 | 1913 | 02/01/1971 | 02/01/1971 | TOR15-015 | C |
| 87 - 11864 | TOR0016 | 3 2061 - 220TH ST | 200 | 2 | 1 | 2 | 10 | 1 | 4 | 1958 | 05/20/1987 | 05/20/1987 | TOR16-026A | C |
| 87 - 11125 | TOR0016 | 3 1717 MARTINA AVE | 200 | 2 | 1 | 4 | 10 | 6 | 1 | 1974 | 02/10/1987 | 02/10/1987 | TOR16-028 | P |
| 83 - 22622 | TOR0017 | 3 2409 ARLINGTON AVE | 400 | 4 | 1 | 4 | 10 | 3 | 6 | 1922 | 05/17/1983 | 02/17/1984 | TOR17-006A | C |
| 76 - 844861 | TOR0009 | 1 1335 POST | 200 | 2 | 1 | 6 | 11 | 5 | 4 | 1913 | 06/01/1976 | 06/01/1976 | TOR09-003 | P |
| 90 - 2469 | TOR0009 | 3 1318 S CRAVENS | 200 | 2 | 1 | 1 | 11 | 6 | 3 | 1936 | 08/03/1990 | 08/03/1990 | TOR09-003 | P |
| 79 - 51171 | TOR0009 | 3 1326 1/2 ENGRACIA AVE | 300 | 3 | 1 | 4 | 11 | 6 | 3 | 1976 | 01/01/1979 | 01/01/1979 | TOR09-004A | C |
| 81 - 11917 | TOR0009 | 3 1331 POST AVE | 300 | 3 | 1 | 4 | 11 | 1 | 4 | 1912 | 09/28/1981 | 12/28/1981 | TOR09-004C | P |
| 81 - 11915 | TOR0009 | 3 1330 EL PRADO | 200 | 2 | 1 | 3 | 11 | 6 | 4 | 1949 | 09/28/1981 | 10/28/1981 | TOR09-008 | C |
| 80 - 2098 | TOR0009 | 3 1330 EL PRADO | 200 | 2 | 1 | 3 | 11 | 6 | 5 | 1949 | 09/05/1980 | 03/05/1981 | TOR09-008 | C |
| 89 - 40450 | TOR0009 | 3 ALLEY W/O VAN NESS AT ENGRACIA AV | 200 | 2 | 1 | 3 | 11 | 6 | 1 | 1927 | 08/22/1989 | 08/22/1990 | TOR09-013A | C |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRIO | Address or Location | DIAMETER (inches) | Facility | LEAK In | Cause | Repair Type | Material | Installed | Year | Detect Date | Action Date | Pipeline Info | |
|-------------------|-------------|-----------|---------------------|-------------------|------------------------------------|---------|-------|-------------|----------|------------|------------|-------------|-------------|----------------|---------------------------------|
| | | | | | | | | | | | | | | Segment Number | Pipeline (C=CURRENT P=PREVIOUS) |
| 80 | - | 9579 | TOR0009 | 1 | 1920 TORRANCE | 2 | 1 | 4 | 11 | 11/07/1980 | 11/07/1980 | | | TOR09-0138 | C |
| 84 | - | 56812 | TOR0009 | 3 | 900 VAN NESS | 6 | 1 | 4 | 11 | 03/12/1984 | 01/12/1985 | | | TOR09-014A | C |
| 86 | - | 38274 | TOR0009 | 2 | 1010 VAN NESS | 6 | 1 | 4 | 11 | 03/20/1986 | 04/03/1986 | | | TOR09-014A | C |
| 91 | - | 2929 | TOR0009 | 3 | 923 VAN NESS AV | 6 | 1 | 4 | 11 | 08/15/1991 | 11/15/1991 | | | TOR09-014A | C |
| 77 | - | 856088 | TOR0009 | 3 | MULLIN & CABRILLO | 6 | 1 | 2 | 11 | 03/01/1977 | 03/01/1977 | | | TOR09-014A | C |
| 72 | - | 412553 | TOR0009 | 3 | W/S MULLIN AVE | 6 | 1 | 2 | 11 | 02/01/1972 | 02/01/1972 | | | TOR09-014A | C |
| 86 | - | 38275 | TOR0009 | 2 | 1010 VAN NESS | 6 | 1 | 5 | 11 | 03/20/1986 | 03/20/1986 | | | TOR09-014A | C |
| 71 | - | 190349 | TOR0009 | 3 | VAN NESS AND TORR BL | 8 | 1 | 4 | 11 | 04/01/1971 | 04/01/1971 | | | TOR09-014A | C |
| 76 | - | 856051 | TOR0009 | 3 | MULLIN & TORR BLVD | 6 | 1 | 4 | 11 | 06/01/1976 | 06/01/1976 | | | TOR09-0148 | C |
| 82 | - | 22030 | TOR0009 | 3 | 1200 CABRILLO | 6 | 1 | 4 | 11 | 09/16/1982 | 05/16/1983 | | | TOR09-014C | C |
| 92 | - | 82159 | TOR0009 | 1 | 1250 S CABRILLO AV | 6 | 1 | 4 | 11 | 08/06/1992 | 08/06/1992 | | | TOR09-014C | C |
| 79 | - | 135369 | TOR0009 | 3 | 1328 CABRILLO | 6 | 1 | 4 | 11 | 11/01/1979 | 11/01/1979 | | | TOR09-014D | C |
| 87 | - | 11565 | TOR0009 | 3 | VAN NESS & MULLIN AVE | 2 | 1 | 3 | 11 | 04/15/1987 | 04/15/1987 | | | TOR09-014E | C |
| 80 | - | 2127 | TOR0009 | 3 | TORRANCE & HUBER ST | 8 | 1 | 3 | 11 | 08/21/1987 | 03/21/1988 | | | TOR09-018 | C |
| 87 | - | 12392 | TOR0009 | 3 | 213TH & CABRILLO | 3 | 1 | 3 | 11 | 03/08/1985 | 03/08/1985 | | | TOR09-023 | C |
| 85 | - | 35500 | TOR0009 | 3 | 1739 213 ST | 3 | 1 | 3 | 11 | 03/12/1984 | 01/12/1985 | | | TOR09-023 | C |
| 84 | - | 56814 | TOR0009 | 3 | 1739 213TH ST | 3 | 1 | 3 | 11 | 09/28/1981 | 12/28/1981 | | | TOR09-023 | C |
| 81 | - | 1918 | TOR0009 | 3 | 1/5 213ST & CABRILLO AVE | 8 | 1 | 3 | 11 | 08/11/1987 | 08/11/1987 | | | TOR09-030A | C |
| 87 | - | 12392 | TOR0009 | 3 | 9' S/N TORRANCE BLD & 272' W/W W | 2 | 1 | 2 | 11 | 09/01/1970 | 09/01/1970 | | | TOR09-032 | C |
| 88 | - | 61465 | TOR0009 | 2 | 1619 GRAMERCY AVE | 2 | 1 | 2 | 11 | 07/01/1971 | 07/01/1971 | | | TOR10-006 | P |
| 70 | - | 127075 | TOR0009 | 2 | 1628 CRAVENS | 2 | 1 | 2 | 11 | 12/01/1973 | 12/01/1973 | | | TOR10-007 | P |
| 86 | - | 37927 | TOR0010 | 3 | 1313 DATE AVE | 2 | 1 | 6 | 11 | 01/31/1986 | 01/31/1986 | | | TOR10-005B | C |
| 71 | - | 111118 | TOR0010 | 1 | 1/5 ELDORADO CRENSHAW | 3 | 1 | 2 | 11 | 07/01/1971 | 07/01/1971 | | | TOR10-007 | C |
| 73 | - | 643335 | TOR0010 | 3 | 1/5 ALLEY S/TORR BL & E/CRENSHAW | 2 | 1 | 3 | 11 | 02/01/1973 | 02/01/1973 | | | TOR10-007 | C |
| 84 | - | 7091 | TOR0010 | 3 | 2515 ELDORADO | 2 | 1 | 6 | 11 | 11/19/1984 | 12/19/1984 | | | TOR10-007A | C |
| 78 | - | 992401 | TOR0010 | 1 | ALLEY N/TORR E/CRENSHAW | 2 | 1 | 3 | 11 | 08/01/1978 | 08/01/1978 | | | TOR10-013 | P |
| 86 | - | 60290 | TOR0010 | 3 | 1103 BEECH AVE | 2 | 1 | 3 | 11 | 02/03/1986 | 05/03/1987 | | | TOR10-013 | P |
| 90 | - | 10021 | TOR0010 | 1 | 812 BEECH AVE | 2 | 1 | 4 | 11 | 10/30/1990 | 10/30/1990 | | | TOR10-014A | C |
| 82 | - | 28681 | TOR0010 | 1 | 2310 SIERRA ST | 2 | 1 | 6 | 11 | 05/28/1982 | 05/28/1982 | | | TOR10-016A | C |
| 90 | - | 2619 | TOR0010 | 3 | 2309 SIERRA AV | 2 | 1 | 4 | 11 | 10/30/1990 | 06/30/1991 | | | TOR10-018A | C |
| 89 | - | 1798 | TOR0010 | 3 | 1011 PORTOLA | 2 | 1 | 4 | 11 | 07/17/1989 | 07/17/1989 | | | TOR10-020A | C |
| 84 | - | 39690 | TOR0010 | 1 | 1103 PORTOLA AVE | 2 | 1 | 1 | 4 | 11/30/1984 | 11/30/1984 | | | TOR10-020A | C |
| 78 | - | 933840 | TOR0010 | 2 | 1217 ACACIA AVE | 2 | 1 | 3 | 11 | 06/01/1978 | 06/01/1978 | | | TOR10-025 | P |
| 84 | - | 51914 | TOR0010 | 3 | 1313 MADRID AVE | 2 | 1 | 4 | 11 | 09/25/1984 | 09/25/1984 | | | TOR10-026 | P |
| 82 | - | 22000 | TOR0010 | 2 | 1432 ENGRACIA AVE | 3 | 1 | 4 | 11 | 06/11/1982 | 06/25/1982 | | | TOR10-039A | C |
| 84 | - | 7093 | TOR0010 | 3 | 1310 MANUEL AVE | 3 | 1 | 4 | 11 | 11/21/1984 | 12/21/1984 | | | TOR10-039A | C |
| 82 | - | 21999 | TOR0010 | 3 | W/SIDE ALLEY S/O ENGRACIA AVE | 3 | 1 | 4 | 11 | 06/11/1983 | 06/11/1983 | | | TOR10-039A | C |
| 78 | - | 933843 | TOR0010 | 2 | 1432 ENGRACIA AVE | 3 | 1 | 2 | 11 | 07/01/1978 | 07/01/1978 | | | TOR10-039A | C |
| 77 | - | 460469 | TOR0010 | 3 | CRENSHAW BLVD. & ALLEY S/O TORRAN | 3 | 1 | 2 | 11 | 09/01/1972 | 09/01/1972 | | | TOR10-040A | C |
| 83 | - | 50595 | TOR0010 | 2 | 2260 TORRANCE BLVD | 2 | 1 | 3 | 11 | 07/15/1983 | 07/15/1983 | | | TOR10-040D | P |
| 86 | - | 38081 | TOR0015 | 3 | CRENSHAW BLVD/CARSON ST | 8 | 1 | 2 | 11 | 02/24/1986 | 02/24/1986 | | | TOR15-004B | P |
| 86 | - | 37946 | TOR0015 | 3 | 1/5 CRENSHAW BL & JEFFERSON ST | 4 | 1 | 3 | 11 | 04/03/1986 | 04/03/1986 | | | TOR15-008 | C |
| 81 | - | 18786 | TOR0015 | 3 | 2341 JEFFERSON | 4 | 1 | 6 | 11 | 07/22/1981 | 07/22/1981 | | | TOR15-008A | C |
| 77 | - | 800962 | TOR0015 | 3 | 29 W/E CRENSHAW BL | 4 | 1 | 3 | 11 | 01/01/1977 | 01/01/1977 | | | TOR15-008A | C |
| 86 | - | 37869 | TOR0015 | 3 | N/W CORNER ALLEY N/CARSON & H/COTA | 3 | 1 | 3 | 11 | 01/22/1986 | 01/22/1986 | | | TOR15-012B | C |
| 77 | - | 908347 | TOR0015 | 1 | 2265 CARSON APT B | 2 | 1 | 4 | 11 | 06/01/1977 | 06/01/1977 | | | TOR15-015 | C |
| 79 | - | 51151 | TOR0015 | 3 | 1736 WATSON AVE | 2 | 1 | 4 | 11 | 01/01/1979 | 01/01/1979 | | | TOR15-017B | C |
| 88 | - | 20400 | TOR0015 | 3 | 1729 MANUEL AVE | 2 | 1 | 4 | 11 | 08/30/1988 | 05/30/1989 | | | TOR15-018A | C |
| 85 | - | 39847 | TOR0016 | 2 | 1532 EL PRADO AVE | 2 | 1 | 4 | 11 | 01/02/1985 | 01/16/1985 | | | TOR16-001 | P |
| 83 | - | 50533 | TOR0016 | 3 | 1613 CRAVENS | 3 | 1 | 2 | 11 | 06/24/1983 | 06/24/1983 | | | TOR16-004 | C |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | ATLAS SHEET | LEAK PRIORITY | Address or Location | DIAMETER SIZE (inches) | Facility | LEAK In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline info | |
|-------------------|-------------|---------------|----------------------------------|------------------------|----------|---------|-------|-------------|----------|----------------|-------------|-------------|----------------|------------------------------|
| | | | | | | | | | | | | | Segment Number | Info (C=CURRENT, P=PREVIOUS) |
| 90 - 10099 | TOR0016 | 3 | 1613 CRAVELINA AV | 300 | 1 | 6 | 11 | 6 | 4 | 1912 | 12/27/1990 | 01/27/1991 | TOR16-004 | C |
| 90 - 2299 | TOR0016 | 3 | 1528 MARCELINA AV | 300 | 3 | 1 | 11 | 1 | 2 | 1912 | 03/14/1990 | 11/14/1990 | TOR16-004 | C |
| 89 - 1350 | TOR0016 | 1 | 1619 GRAMERCY | 200 | 1 | 1 | 11 | 1 | 4 | 1954 | 03/17/1989 | 03/17/1989 | TOR16-007 | C |
| 78 - 990285 | TOR0016 | 2 | 1652 CABRILLO | 600 | 6 | 1 | 4 | 11 | 6 | 1913 | 09/01/1978 | 09/01/1978 | TOR16-010 | P |
| 77 - 876991 | TOR0016 | 3 | ALLEY E/O CABRILLO N/O CARSON | 600 | 6 | 1 | 3 | 11 | 5 | 1913 | 08/01/1977 | 08/01/1977 | TOR16-010 | P |
| 76 - 844795 | TOR0016 | 2 | 1718 ANDREO | 300 | 3 | 1 | 6 | 11 | 4 | 1912 | 07/01/1976 | 07/01/1976 | TOR16-016 | C |
| 71 - 180363 | TOR0016 | 3 | 2015 BORDER AVENUE | 200 | 2 | 1 | 2 | 11 | 4 | 1900 | 04/01/1971 | 04/01/1971 | TOR16-016C | P |
| 98 - 990469 | TOR0016 | 1 | 1914 W 218 ST. | 200 | 2 | 1 | 4 | 11 | 5 | 1900 | 11/01/1978 | 11/01/1978 | TOR16-021 | P |
| 79 - 105706 | TOR0017 | 3 | 2409 ARLINGTON | 200 | 2 | 1 | 3 | 11 | 6 | 1923 | 10/01/1979 | 10/01/1979 | TOR17-005 | P |
| 78 - 51056 | TOR0017 | 3 | 2432 ARLINGTON AVE | 400 | 4 | 1 | 4 | 11 | 4 | 1922 | 09/01/1978 | 09/01/1978 | TOR17-006A | C |
| 76 - 685841 | TOR0017 | 1 | I/S PLAZA DEL AMO & ARLINGTON | 300 | 3 | 1 | 3 | 11 | 4 | 1926 | 08/01/1977 | 08/01/1977 | TOR17-006B | C |
| 77 - 908377 | TOR0017 | 1 | 2220 ARLINGTON | 400 | 4 | 1 | 3 | 11 | 4 | 1956 | 09/01/1974 | 09/01/1974 | TOR17-006B | P |
| 74 - 704012 | TOR0017 | 3 | 2202 ARLINGTON AVE | 400 | 4 | 1 | 1 | 11 | 4 | 1930 | 05/11/1987 | 02/11/1988 | TOR17-008B | C |
| 87 - 80358 | TOR0017 | 3 | N/W SANTA FE & ANDREO | 300 | 3 | 1 | 3 | 11 | 6 | 1930 | 09/01/1974 | 09/01/1974 | TOR17-008B | C |
| 74 - 704015 | TOR0017 | 3 | N/W CORNER SANTA F | 300 | 3 | 1 | 3 | 11 | 4 | 1930 | 09/01/1974 | 09/01/1974 | TOR17-008B | C |
| 89 - 40195 | TOR0017 | 3 | N/W COR ANDREO AVE & SANTA FE AV | 300 | 3 | 1 | 3 | 11 | 2 | 1930 | 05/15/1989 | 04/15/1990 | TOR17-008B | C |
| 79 - 72656 | TOR0017 | 3 | I/S SANTA FE AVE & ANDREO AVE | 300 | 3 | 1 | 3 | 11 | 6 | 1930 | 04/01/1979 | 04/01/1979 | TOR17-008B | C |
| 83 - 22626 | TOR0017 | 3 | SANTA FE & ANDREO | 300 | 3 | 1 | 3 | 11 | 2 | 1930 | 05/17/1983 | 02/17/1984 | TOR17-008B | C |
| 84 - 30613 | TOR0017 | 3 | I/S GRAMERCY & SEPULVEDA | 200 | 2 | 1 | 3 | 11 | 6 | 1947 | 01/04/1984 | 01/04/1984 | TOR17-010 | P |
| 91 - 2890 | TOR0017 | 3 | ALLEY W/O ANDREO & S/O PLAZA DEL | 200 | 2 | 1 | 4 | 11 | 2 | 1941 | 05/14/1991 | 10/14/1991 | TOR17-012A | C |
| 87 - 80362 | TOR0017 | 3 | 2443 ANDREO AVE | 200 | 2 | 1 | 4 | 11 | 1 | 1941 | 05/11/1987 | 02/11/1988 | TOR17-012A | C |
| 86 - 3589 | TOR0017 | 3 | 100 S/S PL OF 222ND ST | 200 | 2 | 1 | 6 | 11 | 4 | 1913 | 05/12/1986 | 05/12/1987 | TOR17-013 | C |
| 87 - 80361 | TOR0017 | 3 | 1880 LINCOLN AVE | 200 | 2 | 1 | 4 | 11 | 2 | 1948 | 05/11/1987 | 03/11/1988 | TOR17-020 | C |
| 82 - 21741 | TOR0017 | 3 | 2308 CABRILLO AVE | 200 | 2 | 1 | 2 | 11 | 4 | 1913 | 06/09/1982 | 04/09/1983 | TOR17-027 | P |
| 83 - 22604 | TOR0017 | 3 | 2323 BORDER | 200 | 2 | 1 | 6 | 11 | 2 | 1913 | 06/15/1983 | 02/15/1984 | TOR17-027 | P |
| 79 - 72660 | TOR0017 | 3 | CABRILLO AVE 140' W/W BORDER | 100 | 1 | 1 | 3 | 11 | 6 | 1965 | 04/01/1979 | 04/01/1979 | TOR17-028 | C |
| 79 - 990314 | TOR0017 | 3 | 22501 WESTERN AVE | 400 | 4 | 1 | 3 | 11 | 5 | 1923 | 02/01/1979 | 02/01/1979 | TOR17-031 | C |
| 77 - 908172 | TOR0017 | 1 | 22501 S. WESTERN AVE | 400 | 4 | 1 | 3 | 11 | 6 | 1949 | 06/01/1977 | 06/01/1977 | TOR17-031C | P |
| 90 - 2359 | TOR0017 | 3 | 226TH & WESTERN | 200 | 2 | 1 | 3 | 11 | 2 | 1964 | 05/11/1990 | 02/11/1991 | TOR17-036A | C |
| 91 - 2887 | TOR0017 | 3 | VALVE N/E COR 226TH & WESTERN | 200 | 2 | 1 | 3 | 11 | 6 | 1949 | 05/07/1991 | 12/07/1991 | TOR17-036A | C |
| 82 - 22029 | TOR0009 | 3 | 1409 CRAVENS AV | 200 | 2 | 1 | 6 | 12 | 2 | 1937 | 09/16/1982 | 09/16/1983 | TOR09-005 | P |
| 84 - 56811 | TOR0009 | 3 | 1020 SARTONI ALLEY R/O | 200 | 2 | 1 | 6 | 12 | 5 | 1927 | 03/12/1984 | 01/12/1985 | TOR09-013A | C |
| 81 - 11114 | TOR0009 | 3 | 1426 CABRILLO AVE | 600 | 6 | 1 | 6 | 12 | 2 | 1913 | 03/19/1981 | 02/19/1982 | TOR09-014 | P |
| 80 - 2096 | TOR0009 | 3 | 1502 CABRILLO | 600 | 6 | 1 | 6 | 12 | 5 | 1913 | 09/05/1980 | 09/05/1981 | TOR09-014 | P |
| 81 - 11115 | TOR0009 | 3 | S/E CORNER OF DOUBLE ST IN THE | 600 | 6 | 1 | 6 | 12 | 2 | 1913 | 03/19/1981 | 02/19/1982 | TOR09-014 | P |
| 80 - 2095 | TOR0009 | 3 | 1420 CABRILLO | 600 | 6 | 1 | 6 | 12 | 5 | 1913 | 09/05/1980 | 09/05/1981 | TOR09-014 | P |
| 84 - 7387 | TOR0010 | 3 | 1326 DATE AVE | 200 | 2 | 1 | 6 | 12 | 2 | 1935 | 12/05/1984 | 04/05/1985 | TOR10-005B | C |
| 85 - 35069 | TOR0010 | 3 | 2555 SONOMA AVE/DATE ST | 200 | 2 | 1 | 6 | 12 | 5 | 1924 | 01/17/1985 | 04/17/1985 | TOR10-008B | C |
| 84 - 39630 | TOR0010 | 2 | 815 BEECH ST | 200 | 2 | 1 | 6 | 12 | 2 | 1928 | 11/20/1984 | 08/20/1985 | TOR10-013 | P |
| 84 - 39601 | TOR0010 | 2 | 917 BEECH AVE | 200 | 2 | 1 | 1 | 12 | 4 | 1928 | 11/15/1984 | 11/29/1984 | TOR10-013 | P |
| 78 - 25333 | TOR0010 | 3 | 1016 BEECH AVE | 200 | 2 | 1 | 6 | 12 | 4 | 1927 | 07/01/1978 | 07/01/1978 | TOR10-014 | P |
| 86 - 60327 | TOR0010 | 3 | ALLEY E/O OF ACACIA | 200 | 2 | 1 | 6 | 12 | 4 | 1927 | 11/26/1986 | 11/26/1987 | TOR10-015 | P |
| 84 - 7391 | TOR0010 | 3 | 1327 ACACIA | 200 | 2 | 1 | 6 | 12 | 2 | 1917 | 12/05/1984 | 12/05/1985 | TOR10-020C | C |
| 84 - 7394 | TOR0010 | 3 | 2325 SONOMA | 200 | 2 | 1 | 6 | 12 | 4 | 1927 | 12/05/1984 | 12/05/1985 | TOR10-025 | P |
| 84 - 7449 | TOR0010 | 3 | 1307 PORTOLA | 200 | 2 | 1 | 6 | 12 | 4 | 1927 | 12/05/1984 | 12/05/1985 | TOR10-027 | P |
| 84 - 7452 | TOR0010 | 3 | ON TORRANCE BLVD 2 W/W AMAPOLA | 200 | 2 | 1 | 6 | 12 | 2 | 1921 | 09/11/1984 | 09/11/1985 | TOR10-102 | P |
| 84 - 7455 | TOR0010 | 3 | ON TORRANCE BLVD 54 W/W AMAPOLA | 200 | 2 | 1 | 6 | 12 | 2 | 1921 | 09/11/1984 | 09/11/1985 | TOR10-102 | P |
| 84 - 7455 | TOR0010 | 3 | ALLEY W/AMAPOLA 15 S/MAIN TIE IN | 200 | 2 | 1 | 6 | 12 | 2 | 1925 | 09/11/1984 | 09/11/1985 | TOR10-102 | P |

MAIN REPAIR LEAKS - MODIFIED LEAK REPAIR ORDER DATABASE

| Leak Order Number | Atlas Leak Sheet Prio | Address or Location | Diameter (inches) | Leak In | Cause | Repair Type | Material | Year Installed | Detect Date | Action Date | Pipeline info | |
|-------------------|-----------------------|------------------------------------|-------------------|---------|-------|-------------|----------|----------------|-------------|-------------|---------------|------|
| | | | | | | | | | | | Facility | Size |
| 83 - 22724 | TOR0017 | 3 2740 GRAMERCY AVE | 200 | 1 | 6 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22728 | TOR0017 | 3 2756 GRAMERCY AVE | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22727 | TOR0017 | 3 IN GRAMERCY 150' N/NPL SEPULVEDA | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22725 | TOR0017 | 3 2741 GRAMERCY AVE | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22726 | TOR0017 | 3 2748 GRAMERCY AVE | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22729 | TOR0017 | 3 IN GRAMERCY 90'N/NPL O/SEPULVEDA | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 83 - 22723 | TOR0017 | 3 2732 GRAMERCY AVE | 200 | 2 | 1 | 12 | 2 | 1947 | 07/06/1983 | 01/06/1984 | TOR17-010 | P |
| 88 - 20210 | TOR0017 | 3 2213 BORDEN AVE | 200 | 2 | 1 | 12 | 2 | 1913 | 05/18/1988 | 07/18/1988 | TOR17-027 | P |
| 81 - 11347 | TOR0017 | 3 22501 WESTEREN AVE TORRANCE | 200 | 2 | 1 | 12 | 2 | 1949 | 06/10/1981 | 07/10/1981 | TOR17-031A | C |

**NATIONAL CENTER FOR EARTHQUAKE ENGINEERING RESEARCH
LIST OF TECHNICAL REPORTS**

The National Center for Earthquake Engineering Research (NCEER) publishes technical reports on a variety of subjects related to earthquake engineering written by authors funded through NCEER. These reports are available from both NCEER's Publications Department and the National Technical Information Service (NTIS). Requests for reports should be directed to the Publications Department, National Center for Earthquake Engineering Research, State University of New York at Buffalo, Red Jacket Quadrangle, Buffalo, New York 14261. Reports can also be requested through NTIS, 5285 Port Royal Road, Springfield, Virginia 22161. NTIS accession numbers are shown in parenthesis, if available.

- NCEER-87-0001 "First-Year Program in Research, Education and Technology Transfer," 3/5/87, (PB88-134275).
- NCEER-87-0002 "Experimental Evaluation of Instantaneous Optimal Algorithms for Structural Control," by R.C. Lin, T.T. Soong and A.M. Reinhorn, 4/20/87, (PB88-134341).
- NCEER-87-0003 "Experimentation Using the Earthquake Simulation Facilities at University at Buffalo," by A.M. Reinhorn and R.L. Ketter, to be published.
- NCEER-87-0004 "The System Characteristics and Performance of a Shaking Table," by J.S. Hwang, K.C. Chang and G.C. Lee, 6/1/87, (PB88-134259). This report is available only through NTIS (see address given above).
- NCEER-87-0005 "A Finite Element Formulation for Nonlinear Viscoplastic Material Using a Q Model," by O. Gyebe and G. Dasgupta, 11/2/87, (PB88-213764).
- NCEER-87-0006 "Symbolic Manipulation Program (SMP) - Algebraic Codes for Two and Three Dimensional Finite Element Formulations," by X. Lee and G. Dasgupta, 11/9/87, (PB88-218522).
- NCEER-87-0007 "Instantaneous Optimal Control Laws for Tall Buildings Under Seismic Excitations," by J.N. Yang, A. Akbarpour and P. Ghaemmaghami, 6/10/87, (PB88-134333). This report is only available through NTIS (see address given above).
- NCEER-87-0008 "IDARC: Inelastic Damage Analysis of Reinforced Concrete Frame - Shear-Wall Structures," by Y.J. Park, A.M. Reinhorn and S.K. Kunnath, 7/20/87, (PB88-134325).
- NCEER-87-0009 "Liquefaction Potential for New York State: A Preliminary Report on Sites in Manhattan and Buffalo," by M. Budhu, V. Vijayakumar, R.F. Giese and L. Baumgras, 8/31/87, (PB88-163704). This report is available only through NTIS (see address given above).
- NCEER-87-0010 "Vertical and Torsional Vibration of Foundations in Inhomogeneous Media," by A.S. Veletsos and K.W. Dotson, 6/1/87, (PB88-134291).
- NCEER-87-0011 "Seismic Probabilistic Risk Assessment and Seismic Margins Studies for Nuclear Power Plants," by Howard H.M. Hwang, 6/15/87, (PB88-134267).
- NCEER-87-0012 "Parametric Studies of Frequency Response of Secondary Systems Under Ground-Acceleration Excitations," by Y. Yong and Y.K. Lin, 6/10/87, (PB88-134309).
- NCEER-87-0013 "Frequency Response of Secondary Systems Under Seismic Excitation," by J.A. HoLung, J. Cai and Y.K. Lin, 7/31/87, (PB88-134317).
- NCEER-87-0014 "Modelling Earthquake Ground Motions in Seismically Active Regions Using Parametric Time Series Methods," by G.W. Ellis and A.S. Cakmak, 8/25/87, (PB88-134283).
- NCEER-87-0015 "Detection and Assessment of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 8/25/87, (PB88-163712).

- NCEER-87-0016 "Pipeline Experiment at Parkfield, California," by J. Isenberg and E. Richardson, 9/15/87, (PB88-163720). This report is available only through NTIS (see address given above).
- NCEER-87-0017 "Digital Simulation of Seismic Ground Motion," by M. Shinozuka, G. Deodatis and T. Harada, 8/31/87, (PB88-155197). This report is available only through NTIS (see address given above).
- NCEER-87-0018 "Practical Considerations for Structural Control: System Uncertainty, System Time Delay and Truncation of Small Control Forces," J.N. Yang and A. Akbarpour, 8/10/87, (PB88-163738).
- NCEER-87-0019 "Modal Analysis of Nonclassically Damped Structural Systems Using Canonical Transformation," by J.N. Yang, S. Sarkani and F.X. Long, 9/27/87, (PB88-187851).
- NCEER-87-0020 "A Nonstationary Solution in Random Vibration Theory," by J.R. Red-Horse and P.D. Spanos, 11/3/87, (PB88-163746).
- NCEER-87-0021 "Horizontal Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by A.S. Veletsos and K.W. Dotson, 10/15/87, (PB88-150859).
- NCEER-87-0022 "Seismic Damage Assessment of Reinforced Concrete Members," by Y.S. Chung, C. Meyer and M. Shinozuka, 10/9/87, (PB88-150867). This report is available only through NTIS (see address given above).
- NCEER-87-0023 "Active Structural Control in Civil Engineering," by T.T. Soong, 11/11/87, (PB88-187778).
- NCEER-87-0024 "Vertical and Torsional Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by K.W. Dotson and A.S. Veletsos, 12/87, (PB88-187786).
- NCEER-87-0025 "Proceedings from the Symposium on Seismic Hazards, Ground Motions, Soil-Liquefaction and Engineering Practice in Eastern North America," October 20-22, 1987, edited by K.H. Jacob, 12/87, (PB88-188115).
- NCEER-87-0026 "Report on the Whittier-Narrows, California, Earthquake of October 1, 1987," by J. Pantelic and A. Reinhorn, 11/87, (PB88-187752). This report is available only through NTIS (see address given above).
- NCEER-87-0027 "Design of a Modular Program for Transient Nonlinear Analysis of Large 3-D Building Structures," by S. Srivastav and J.F. Abel, 12/30/87, (PB88-187950).
- NCEER-87-0028 "Second-Year Program in Research, Education and Technology Transfer," 3/8/88, (PB88-219480).
- NCEER-88-0001 "Workshop on Seismic Computer Analysis and Design of Buildings With Interactive Graphics," by W. McGuire, J.F. Abel and C.H. Conley, 1/18/88, (PB88-187760).
- NCEER-88-0002 "Optimal Control of Nonlinear Flexible Structures," by J.N. Yang, F.X. Long and D. Wong, 1/22/88, (PB88-213772).
- NCEER-88-0003 "Substructuring Techniques in the Time Domain for Primary-Secondary Structural Systems," by G.D. Manolis and G. Juhn, 2/10/88, (PB88-213780).
- NCEER-88-0004 "Iterative Seismic Analysis of Primary-Secondary Systems," by A. Singhal, L.D. Lutes and P.D. Spanos, 2/23/88, (PB88-213798).
- NCEER-88-0005 "Stochastic Finite Element Expansion for Random Media," by P.D. Spanos and R. Ghanem, 3/14/88, (PB88-213806).
- NCEER-88-0006 "Combining Structural Optimization and Structural Control," by F.Y. Cheng and C.P. Pantelides, 1/10/88, (PB88-213814).

- NCEER-88-0007 "Seismic Performance Assessment of Code-Designed Structures," by H.H-M. Hwang, J-W. Jaw and H-J. Shau, 3/20/88, (PB88-219423).
- NCEER-88-0008 "Reliability Analysis of Code-Designed Structures Under Natural Hazards," by H.H-M. Hwang, H. Ushiba and M. Shinozuka, 2/29/88, (PB88-229471).
- NCEER-88-0009 "Seismic Fragility Analysis of Shear Wall Structures," by J-W Jaw and H.H-M. Hwang, 4/30/88, (PB89-102867).
- NCEER-88-0010 "Base Isolation of a Multi-Story Building Under a Harmonic Ground Motion - A Comparison of Performances of Various Systems," by F-G Fan, G. Ahmadi and I.G. Tadjbakhsh, 5/18/88, (PB89-122238).
- NCEER-88-0011 "Seismic Floor Response Spectra for a Combined System by Green's Functions," by F.M. Lavelle, L.A. Bergman and P.D. Spanos, 5/1/88, (PB89-102875).
- NCEER-88-0012 "A New Solution Technique for Randomly Excited Hysteretic Structures," by G.Q. Cai and Y.K. Lin, 5/16/88, (PB89-102883).
- NCEER-88-0013 "A Study of Radiation Damping and Soil-Structure Interaction Effects in the Centrifuge," by K. Weissman, supervised by J.H. Prevost, 5/24/88, (PB89-144703).
- NCEER-88-0014 "Parameter Identification and Implementation of a Kinematic Plasticity Model for Frictional Soils," by J.H. Prevost and D.V. Griffiths, to be published.
- NCEER-88-0015 "Two- and Three- Dimensional Dynamic Finite Element Analyses of the Long Valley Dam," by D.V. Griffiths and J.H. Prevost, 6/17/88, (PB89-144711).
- NCEER-88-0016 "Damage Assessment of Reinforced Concrete Structures in Eastern United States," by A.M. Reinhorn, M.J. Seidel, S.K. Kunnath and Y.J. Park, 6/15/88, (PB89-122220).
- NCEER-88-0017 "Dynamic Compliance of Vertically Loaded Strip Foundations in Multilayered Viscoelastic Soils," by S. Ahmad and A.S.M. Israil, 6/17/88, (PB89-102891).
- NCEER-88-0018 "An Experimental Study of Seismic Structural Response With Added Viscoelastic Dampers," by R.C. Lin, Z. Liang, T.T. Soong and R.H. Zhang, 6/30/88, (PB89-122212). This report is available only through NTIS (see address given above).
- NCEER-88-0019 "Experimental Investigation of Primary - Secondary System Interaction," by G.D. Manolis, G. Juhn and A.M. Reinhorn, 5/27/88, (PB89-122204).
- NCEER-88-0020 "A Response Spectrum Approach For Analysis of Nonclassically Damped Structures," by J.N. Yang, S. Sarkani and F.X. Long, 4/22/88, (PB89-102909).
- NCEER-88-0021 "Seismic Interaction of Structures and Soils: Stochastic Approach," by A.S. Veletsos and A.M. Prasad, 7/21/88, (PB89-122196).
- NCEER-88-0022 "Identification of the Serviceability Limit State and Detection of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 6/15/88, (PB89-122188). This report is available only through NTIS (see address given above).
- NCEER-88-0023 "Multi-Hazard Risk Analysis: Case of a Simple Offshore Structure," by B.K. Bhartia and E.H. Vanmarcke, 7/21/88, (PB89-145213).
- NCEER-88-0024 "Automated Seismic Design of Reinforced Concrete Buildings," by Y.S. Chung, C. Meyer and M. Shinozuka, 7/5/88, (PB89-122170). This report is available only through NTIS (see address given above).

- NCEER-88-0025 "Experimental Study of Active Control of MDOF Structures Under Seismic Excitations," by L.L. Chung, R.C. Lin, T.T. Soong and A.M. Reinhorn, 7/10/88, (PB89-122600).
- NCEER-88-0026 "Earthquake Simulation Tests of a Low-Rise Metal Structure," by J.S. Hwang, K.C. Chang, G.C. Lee and R.L. Ketter, 8/1/88, (PB89-102917).
- NCEER-88-0027 "Systems Study of Urban Response and Reconstruction Due to Catastrophic Earthquakes," by F. Kozin and H.K. Zhou, 9/22/88, (PB90-162348).
- NCEER-88-0028 "Seismic Fragility Analysis of Plane Frame Structures," by H.H-M. Hwang and Y.K. Low, 7/31/88, (PB89-131445).
- NCEER-88-0029 "Response Analysis of Stochastic Structures," by A. Kardara, C. Bucher and M. Shinozuka, 9/22/88, (PB89-174429).
- NCEER-88-0030 "Nonnormal Accelerations Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 9/19/88, (PB89-131437).
- NCEER-88-0031 "Design Approaches for Soil-Structure Interaction," by A.S. Veletsos, A.M. Prasad and Y. Tang, 12/30/88, (PB89-174437). This report is available only through NTIS (see address given above).
- NCEER-88-0032 "A Re-evaluation of Design Spectra for Seismic Damage Control," by C.J. Turkstra and A.G. Tallin, 11/7/88, (PB89-145221).
- NCEER-88-0033 "The Behavior and Design of Noncontact Lap Splices Subjected to Repeated Inelastic Tensile Loading," by V.E. Sagan, P. Gergely and R.N. White, 12/8/88, (PB89-163737).
- NCEER-88-0034 "Seismic Response of Pile Foundations," by S.M. Mamoon, P.K. Banerjee and S. Ahmad, 11/1/88, (PB89-145239).
- NCEER-88-0035 "Modeling of R/C Building Structures With Flexible Floor Diaphragms (IDARC2)," by A.M. Reinhorn, S.K. Kunnath and N. Panahshahi, 9/7/88, (PB89-207153).
- NCEER-88-0036 "Solution of the Dam-Reservoir Interaction Problem Using a Combination of FEM, BEM with Particular Integrals, Modal Analysis, and Substructuring," by C-S. Tsai, G.C. Lee and R.L. Ketter, 12/31/88, (PB89-207146).
- NCEER-88-0037 "Optimal Placement of Actuators for Structural Control," by F.Y. Cheng and C.P. Pantelides, 8/15/88, (PB89-162846).
- NCEER-88-0038 "Teflon Bearings in Aseismic Base Isolation: Experimental Studies and Mathematical Modeling," by A. Mokha, M.C. Constantinou and A.M. Reinhorn, 12/5/88, (PB89-218457). This report is available only through NTIS (see address given above).
- NCEER-88-0039 "Seismic Behavior of Flat Slab High-Rise Buildings in the New York City Area," by P. Weidlinger and M. Ettouney, 10/15/88, (PB90-145681).
- NCEER-88-0040 "Evaluation of the Earthquake Resistance of Existing Buildings in New York City," by P. Weidlinger and M. Ettouney, 10/15/88, to be published.
- NCEER-88-0041 "Small-Scale Modeling Techniques for Reinforced Concrete Structures Subjected to Seismic Loads," by W. Kim, A. El-Attar and R.N. White, 11/22/88, (PB89-189625).
- NCEER-88-0042 "Modeling Strong Ground Motion from Multiple Event Earthquakes," by G.W. Ellis and A.S. Cakmak, 10/15/88, (PB89-174445).

- NCEER-88-0043 "Nonstationary Models of Seismic Ground Acceleration," by M. Grigoriu, S.E. Ruiz and E. Rosenblueth, 7/15/88, (PB89-189617).
- NCEER-88-0044 "SARCF User's Guide: Seismic Analysis of Reinforced Concrete Frames," by Y.S. Chung, C. Meyer and M. Shinozuka, 11/9/88, (PB89-174452).
- NCEER-88-0045 "First Expert Panel Meeting on Disaster Research and Planning," edited by J. Pantelic and J. Stoyke, 9/15/88, (PB89-174460).
- NCEER-88-0046 "Preliminary Studies of the Effect of Degrading Infill Walls on the Nonlinear Seismic Response of Steel Frames," by C.Z. Chrysostomou, P. Gergely and J.F. Abel, 12/19/88, (PB89-208383).
- NCEER-88-0047 "Reinforced Concrete Frame Component Testing Facility - Design, Construction, Instrumentation and Operation," by S.P. Pessiki, C. Conley, T. Bond, P. Gergely and R.N. White, 12/16/88, (PB89-174478).
- NCEER-89-0001 "Effects of Protective Cushion and Soil Compliancy on the Response of Equipment Within a Seismically Excited Building," by J.A. HoLung, 2/16/89, (PB89-207179).
- NCEER-89-0002 "Statistical Evaluation of Response Modification Factors for Reinforced Concrete Structures," by H.H-M. Hwang and J-W. Jaw, 2/17/89, (PB89-207187).
- NCEER-89-0003 "Hysteretic Columns Under Random Excitation," by G-Q. Cai and Y.K. Lin, 1/9/89, (PB89-196513).
- NCEER-89-0004 "Experimental Study of 'Elephant Foot Bulge' Instability of Thin-Walled Metal Tanks," by Z-H. Jia and R.L. Ketter, 2/22/89, (PB89-207195).
- NCEER-89-0005 "Experiment on Performance of Buried Pipelines Across San Andreas Fault," by J. Isenberg, E. Richardson and T.D. O'Rourke, 3/10/89, (PB89-218440). This report is available only through NTIS (see address given above).
- NCEER-89-0006 "A Knowledge-Based Approach to Structural Design of Earthquake-Resistant Buildings," by M. Subramani, P. Gergely, C.H. Conley, J.F. Abel and A.H. Zaghaw, 1/15/89, (PB89-218465).
- NCEER-89-0007 "Liquefaction Hazards and Their Effects on Buried Pipelines," by T.D. O'Rourke and P.A. Lane, 2/1/89, (PB89-218481).
- NCEER-89-0008 "Fundamentals of System Identification in Structural Dynamics," by H. Imai, C-B. Yun, O. Maruyama and M. Shinozuka, 1/26/89, (PB89-207211).
- NCEER-89-0009 "Effects of the 1985 Michoacan Earthquake on Water Systems and Other Buried Lifelines in Mexico," by A.G. Ayala and M.J. O'Rourke, 3/8/89, (PB89-207229).
- NCEER-89-R010 "NCEER Bibliography of Earthquake Education Materials," by K.E.K. Ross, Second Revision, 9/1/89, (PB90-125352).
- NCEER-89-0011 "Inelastic Three-Dimensional Response Analysis of Reinforced Concrete Building Structures (IDARC-3D), Part I - Modeling," by S.K. Kunnath and A.M. Reinhorn, 4/17/89, (PB90-114612).
- NCEER-89-0012 "Recommended Modifications to ATC-14," by C.D. Poland and J.O. Malley, 4/12/89, (PB90-108648).
- NCEER-89-0013 "Repair and Strengthening of Beam-to-Column Connections Subjected to Earthquake Loading," by M. Corazao and A.J. Durrani, 2/28/89, (PB90-109885).
- NCEER-89-0014 "Program EXKAL2 for Identification of Structural Dynamic Systems," by O. Maruyama, C-B. Yun, M. Hoshiya and M. Shinozuka, 5/19/89, (PB90-109877).

- NCEER-89-0015 "Response of Frames With Bolted Semi-Rigid Connections, Part I - Experimental Study and Analytical Predictions," by P.J. DiCorso, A.M. Reinhorn, J.R. Dickerson, J.B. Radzimirski and W.L. Harper, 6/1/89, to be published.
- NCEER-89-0016 "ARMA Monte Carlo Simulation in Probabilistic Structural Analysis," by P.D. Spanos and M.P. Mignolet, 7/10/89, (PB90-109893).
- NCEER-89-P017 "Preliminary Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 6/23/89, (PB90-108606).
- NCEER-89-0017 "Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 12/31/89, (PB90-207895). This report is available only through NTIS (see address given above).
- NCEER-89-0018 "Multidimensional Models of Hysteretic Material Behavior for Vibration Analysis of Shape Memory Energy Absorbing Devices, by E.J. Graesser and F.A. Cozzarelli, 6/7/89, (PB90-164146).
- NCEER-89-0019 "Nonlinear Dynamic Analysis of Three-Dimensional Base Isolated Structures (3D-BASIS)," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 8/3/89, (PB90-161936). This report is available only through NTIS (see address given above).
- NCEER-89-0020 "Structural Control Considering Time-Rate of Control Forces and Control Rate Constraints," by F.Y. Cheng and C.P. Pantelides, 8/3/89, (PB90-120445).
- NCEER-89-0021 "Subsurface Conditions of Memphis and Shelby County," by K.W. Ng, T-S. Chang and H-H.M. Hwang, 7/26/89, (PB90-120437).
- NCEER-89-0022 "Seismic Wave Propagation Effects on Straight Jointed Buried Pipelines," by K. Elhmadi and M.J. O'Rourke, 8/24/89, (PB90-162322).
- NCEER-89-0023 "Workshop on Serviceability Analysis of Water Delivery Systems," edited by M. Grigoriu, 3/6/89, (PB90-127424).
- NCEER-89-0024 "Shaking Table Study of a 1/5 Scale Steel Frame Composed of Tapered Members," by K.C. Chang, J.S. Hwang and G.C. Lee, 9/18/89, (PB90-160169).
- NCEER-89-0025 "DYNA1D: A Computer Program for Nonlinear Seismic Site Response Analysis - Technical Documentation," by Jean H. Prevost, 9/14/89, (PB90-161944). This report is available only through NTIS (see address given above).
- NCEER-89-0026 "1:4 Scale Model Studies of Active Tendon Systems and Active Mass Dampers for Aseismic Protection," by A.M. Reinhorn, T.T. Soong, R.C. Lin, Y.P. Yang, Y. Fukao, H. Abe and M. Nakai, 9/15/89, (PB90-173246).
- NCEER-89-0027 "Scattering of Waves by Inclusions in a Nonhomogeneous Elastic Half Space Solved by Boundary Element Methods," by P.K. Hadley, A. Askar and A.S. Cakmak, 6/15/89, (PB90-145699).
- NCEER-89-0028 "Statistical Evaluation of Deflection Amplification Factors for Reinforced Concrete Structures," by H.H.M. Hwang, J-W. Jaw and A.L. Ch'ng, 8/31/89, (PB90-164633).
- NCEER-89-0029 "Bedrock Accelerations in Memphis Area Due to Large New Madrid Earthquakes," by H.H.M. Hwang, C.H.S. Chen and G. Yu, 11/7/89, (PB90-162330).
- NCEER-89-0030 "Seismic Behavior and Response Sensitivity of Secondary Structural Systems," by Y.Q. Chen and T.T. Soong, 10/23/89, (PB90-164658).

- NCEER-89-0031 "Random Vibration and Reliability Analysis of Primary-Secondary Structural Systems," by Y. Ibrahim, M. Grigoriu and T.T. Soong, 11/10/89, (PB90-161951).
- NCEER-89-0032 "Proceedings from the Second U.S. - Japan Workshop on Liquefaction, Large Ground Deformation and Their Effects on Lifelines, September 26-29, 1989," Edited by T.D. O'Rourke and M. Hamada, 12/1/89, (PB90-209388).
- NCEER-89-0033 "Deterministic Model for Seismic Damage Evaluation of Reinforced Concrete Structures," by J.M. Bracci, A.M. Reinhorn, J.B. Mander and S.K. Kunnath, 9/27/89.
- NCEER-89-0034 "On the Relation Between Local and Global Damage Indices," by E. DiPasquale and A.S. Cakmak, 8/15/89, (PB90-173865).
- NCEER-89-0035 "Cyclic Undrained Behavior of Nonplastic and Low Plasticity Silts," by A.J. Walker and H.E. Stewart, 7/26/89, (PB90-183518).
- NCEER-89-0036 "Liquefaction Potential of Surficial Deposits in the City of Buffalo, New York," by M. Budhu, R. Giese and L. Baumgrass, 1/17/89, (PB90-208455).
- NCEER-89-0037 "A Deterministic Assessment of Effects of Ground Motion Incoherence," by A.S. Veletsos and Y. Tang, 7/15/89, (PB90-164294).
- NCEER-89-0038 "Workshop on Ground Motion Parameters for Seismic Hazard Mapping," July 17-18, 1989, edited by R.V. Whitman, 12/1/89, (PB90-173923).
- NCEER-89-0039 "Seismic Effects on Elevated Transit Lines of the New York City Transit Authority," by C.J. Costantino, C.A. Miller and E. Heymsfield, 12/26/89, (PB90-207887).
- NCEER-89-0040 "Centrifugal Modeling of Dynamic Soil-Structure Interaction," by K. Weissman, Supervised by J.H. Prevost, 5/10/89, (PB90-207879).
- NCEER-89-0041 "Linearized Identification of Buildings With Cores for Seismic Vulnerability Assessment," by I.K. Ho and A.E. Aktan, 11/1/89, (PB90-251943).
- NCEER-90-0001 "Geotechnical and Lifeline Aspects of the October 17, 1989 Loma Prieta Earthquake in San Francisco," by T.D. O'Rourke, H.E. Stewart, F.T. Blackburn and T.S. Dickerman, 1/90, (PB90-208596).
- NCEER-90-0002 "Nonnormal Secondary Response Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 2/28/90, (PB90-251976).
- NCEER-90-0003 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/16/90, (PB91-251984).
- NCEER-90-0004 "Catalog of Strong Motion Stations in Eastern North America," by R.W. Busby, 4/3/90, (PB90-251984).
- NCEER-90-0005 "NCEER Strong-Motion Data Base: A User Manual for the GeoBase Release (Version 1.0 for the Sun3)," by P. Friberg and K. Jacob, 3/31/90 (PB90-258062).
- NCEER-90-0006 "Seismic Hazard Along a Crude Oil Pipeline in the Event of an 1811-1812 Type New Madrid Earthquake," by H.H.M. Hwang and C-H.S. Chen, 4/16/90(PB90-258054).
- NCEER-90-0007 "Site-Specific Response Spectra for Memphis Sheahan Pumping Station," by H.H.M. Hwang and C.S. Lee, 5/15/90, (PB91-108811).
- NCEER-90-0008 "Pilot Study on Seismic Vulnerability of Crude Oil Transmission Systems," by T. Ariman, R. Dobry, M. Grigoriu, F. Kozin, M. O'Rourke, T. O'Rourke and M. Shinozuka, 5/25/90, (PB91-108837).

- NCEER-90-0009 "A Program to Generate Site Dependent Time Histories: EQGEN," by G.W. Ellis, M. Srinivasan and A.S. Cakmak, 1/30/90, (PB91-108829).
- NCEER-90-0010 "Active Isolation for Seismic Protection of Operating Rooms," by M.E. Talbott, Supervised by M. Shinozuka, 6/8/9, (PB91-110205).
- NCEER-90-0011 "Program LINEARID for Identification of Linear Structural Dynamic Systems," by C-B. Yun and M. Shinozuka, 6/25/90, (PB91-110312).
- NCEER-90-0012 "Two-Dimensional Two-Phase Elasto-Plastic Seismic Response of Earth Dams," by A.N. Yiagos, Supervised by J.H. Prevost, 6/20/90, (PB91-110197).
- NCEER-90-0013 "Secondary Systems in Base-Isolated Structures: Experimental Investigation, Stochastic Response and Stochastic Sensitivity," by G.D. Manolis, G. Juhn, M.C. Constantinou and A.M. Reinhorn, 7/1/90, (PB91-110320).
- NCEER-90-0014 "Seismic Behavior of Lightly-Reinforced Concrete Column and Beam-Column Joint Details," by S.P. Pessiki, C.H. Conley, P. Gergely and R.N. White, 8/22/90, (PB91-108795).
- NCEER-90-0015 "Two Hybrid Control Systems for Building Structures Under Strong Earthquakes," by J.N. Yang and A. Danielians, 6/29/90, (PB91-125393).
- NCEER-90-0016 "Instantaneous Optimal Control with Acceleration and Velocity Feedback," by J.N. Yang and Z. Li, 6/29/90, (PB91-125401).
- NCEER-90-0017 "Reconnaissance Report on the Northern Iran Earthquake of June 21, 1990," by M. Mehrain, 10/4/90, (PB91-125377).
- NCEER-90-0018 "Evaluation of Liquefaction Potential in Memphis and Shelby County," by T.S. Chang, P.S. Tang, C.S. Lee and H. Hwang, 8/10/90, (PB91-125427).
- NCEER-90-0019 "Experimental and Analytical Study of a Combined Sliding Disc Bearing and Helical Steel Spring Isolation System," by M.C. Constantinou, A.S. Mokha and A.M. Reinhorn, 10/4/90, (PB91-125385).
- NCEER-90-0020 "Experimental Study and Analytical Prediction of Earthquake Response of a Sliding Isolation System with a Spherical Surface," by A.S. Mokha, M.C. Constantinou and A.M. Reinhorn, 10/11/90, (PB91-125419).
- NCEER-90-0021 "Dynamic Interaction Factors for Floating Pile Groups," by G. Gazetas, K. Fan, A. Kaynia and E. Kausel, 9/10/90, (PB91-170381).
- NCEER-90-0022 "Evaluation of Seismic Damage Indices for Reinforced Concrete Structures," by S. Rodriguez-Gomez and A.S. Cakmak, 9/30/90, (PB91-171322).
- NCEER-90-0023 "Study of Site Response at a Selected Memphis Site," by H. Desai, S. Ahmad, E.S. Gazetas and M.R. Oh, 10/11/90, (PB91-196857).
- NCEER-90-0024 "A User's Guide to Strongmo: Version 1.0 of NCEER's Strong-Motion Data Access Tool for PCs and Terminals," by P.A. Friberg and C.A.T. Susch, 11/15/90, (PB91-171272).
- NCEER-90-0025 "A Three-Dimensional Analytical Study of Spatial Variability of Seismic Ground Motions," by L-L. Hong and A.H.-S. Ang, 10/30/90, (PB91-170399).
- NCEER-90-0026 "MUMOID User's Guide - A Program for the Identification of Modal Parameters," by S. Rodriguez-Gomez and E. DiPasquale, 9/30/90, (PB91-171298).
- NCEER-90-0027 "SARCF-II User's Guide - Seismic Analysis of Reinforced Concrete Frames," by S. Rodriguez-Gomez, Y.S. Chung and C. Meyer, 9/30/90, (PB91-171280).

- NCEER-90-0028 "Viscous Dampers: Testing, Modeling and Application in Vibration and Seismic Isolation," by N. Makris and M.C. Constantinou, 12/20/90 (PB91-190561).
- NCEER-90-0029 "Soil Effects on Earthquake Ground Motions in the Memphis Area," by H. Hwang, C.S. Lee, K.W. Ng and T.S. Chang, 8/2/90, (PB91-190751).
- NCEER-91-0001 "Proceedings from the Third Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction, December 17-19, 1990," edited by T.D. O'Rourke and M. Hamada, 2/1/91, (PB91-179259).
- NCEER-91-0002 "Physical Space Solutions of Non-Proportionally Damped Systems," by M. Tong, Z. Liang and G.C. Lee, 1/15/91, (PB91-179242).
- NCEER-91-0003 "Seismic Response of Single Piles and Pile Groups," by K. Fan and G. Gazetas, 1/10/91, (PB92-174994).
- NCEER-91-0004 "Damping of Structures: Part 1 - Theory of Complex Damping," by Z. Liang and G. Lee, 10/10/91, (PB92-197235).
- NCEER-91-0005 "3D-BASIS - Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures: Part II," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 2/28/91, (PB91-190553).
- NCEER-91-0006 "A Multidimensional Hysteretic Model for Plasticity Deforming Metals in Energy Absorbing Devices," by E.J. Graesser and F.A. Cozzarelli, 4/9/91, (PB92-108364).
- NCEER-91-0007 "A Framework for Customizable Knowledge-Based Expert Systems with an Application to a KBES for Evaluating the Seismic Resistance of Existing Buildings," by E.G. Ibarra-Anaya and S.J. Fenves, 4/9/91, (PB91-210930).
- NCEER-91-0008 "Nonlinear Analysis of Steel Frames with Semi-Rigid Connections Using the Capacity Spectrum Method," by G.G. Deierlein, S-H. Hsieh, Y-J. Shen and J.F. Abel, 7/2/91, (PB92-113828).
- NCEER-91-0009 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/30/91, (PB91-212142).
- NCEER-91-0010 "Phase Wave Velocities and Displacement Phase Differences in a Harmonically Oscillating Pile," by N. Makris and G. Gazetas, 7/8/91, (PB92-108356).
- NCEER-91-0011 "Dynamic Characteristics of a Full-Size Five-Story Steel Structure and a 2/5 Scale Model," by K.C. Chang, G.C. Yao, G.C. Lee, D.S. Hao and Y.C. Yeh, " 7/2/91, (PB93-116648).
- NCEER-91-0012 "Seismic Response of a 2/5 Scale Steel Structure with Added Viscoelastic Dampers," by K.C. Chang, T.T. Soong, S-T. Oh and M.L. Lai, 5/17/91, (PB92-110816).
- NCEER-91-0013 "Earthquake Response of Retaining Walls; Full-Scale Testing and Computational Modeling," by S. Alampalli and A-W.M. Elgamal, 6/20/91, to be published.
- NCEER-91-0014 "3D-BASIS-M: Nonlinear Dynamic Analysis of Multiple Building Base Isolated Structures," by P.C. Tsopelas, S. Nagarajaiah, M.C. Constantinou and A.M. Reinhorn, 5/28/91, (PB92-113885).
- NCEER-91-0015 "Evaluation of SEAOC Design Requirements for Sliding Isolated Structures," by D. Theodossiou and M.C. Constantinou, 6/10/91, (PB92-114602).
- NCEER-91-0016 "Closed-Loop Modal Testing of a 27-Story Reinforced Concrete Flat Plate-Core Building," by H.R. Somaprasad, T. Toksoy, H. Yoshiyuki and A.E. Aktan, 7/15/91, (PB92-129980).
- NCEER-91-0017 "Shake Table Test of a 1/6 Scale Two-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91, (PB92-222447).

- NCEER-91-0018 "Shake Table Test of a 1/8 Scale Three-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91, (PB93-116630).
- NCEER-91-0019 "Transfer Functions for Rigid Rectangular Foundations," by A.S. Veletsos, A.M. Prasad and W.H. Wu, 7/31/91.
- NCEER-91-0020 "Hybrid Control of Seismic-Excited Nonlinear and Inelastic Structural Systems," by J.N. Yang, Z. Li and A. Danielians, 8/1/91, (PB92-143171).
- NCEER-91-0021 "The NCEER-91 Earthquake Catalog: Improved Intensity-Based Magnitudes and Recurrence Relations for U.S. Earthquakes East of New Madrid," by L. Seeber and J.G. Armbruster, 8/28/91, (PB92-176742).
- NCEER-91-0022 "Proceedings from the Implementation of Earthquake Planning and Education in Schools: The Need for Change - The Roles of the Changemakers," by K.E.K. Ross and F. Winslow, 7/23/91, (PB92-129998).
- NCEER-91-0023 "A Study of Reliability-Based Criteria for Seismic Design of Reinforced Concrete Frame Buildings," by H.H.M. Hwang and H-M. Hsu, 8/10/91, (PB92-140235).
- NCEER-91-0024 "Experimental Verification of a Number of Structural System Identification Algorithms," by R.G. Ghanem, H. Gavin and M. Shinozuka, 9/18/91, (PB92-176577).
- NCEER-91-0025 "Probabilistic Evaluation of Liquefaction Potential," by H.H.M. Hwang and C.S. Lee, 11/25/91, (PB92-143429).
- NCEER-91-0026 "Instantaneous Optimal Control for Linear, Nonlinear and Hysteretic Structures - Stable Controllers," by J.N. Yang and Z. Li, 11/15/91, (PB92-163807).
- NCEER-91-0027 "Experimental and Theoretical Study of a Sliding Isolation System for Bridges," by M.C. Constantinou, A. Kartoum, A.M. Reinhorn and P. Bradford, 11/15/91, (PB92-176973).
- NCEER-92-0001 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 1: Japanese Case Studies," Edited by M. Hamada and T. O'Rourke, 2/17/92, (PB92-197243).
- NCEER-92-0002 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 2: United States Case Studies," Edited by T. O'Rourke and M. Hamada, 2/17/92, (PB92-197250).
- NCEER-92-0003 "Issues in Earthquake Education," Edited by K. Ross, 2/3/92, (PB92-222389).
- NCEER-92-0004 "Proceedings from the First U.S. - Japan Workshop on Earthquake Protective Systems for Bridges," Edited by I.G. Buckle, 2/4/92, (PB94-142239, A99, MF-A06).
- NCEER-92-0005 "Seismic Ground Motion from a Haskell-Type Source in a Multiple-Layered Half-Space," A.P. Theoharis, G. Deodatis and M. Shinozuka, 1/2/92, to be published.
- NCEER-92-0006 "Proceedings from the Site Effects Workshop," Edited by R. Whitman, 2/29/92, (PB92-197201).
- NCEER-92-0007 "Engineering Evaluation of Permanent Ground Deformations Due to Seismically-Induced Liquefaction," by M.H. Baziar, R. Dobry and A-W.M. Elgamal, 3/24/92, (PB92-222421).
- NCEER-92-0008 "A Procedure for the Seismic Evaluation of Buildings in the Central and Eastern United States," by C.D. Poland and J.O. Malley, 4/2/92, (PB92-222439).
- NCEER-92-0009 "Experimental and Analytical Study of a Hybrid Isolation System Using Friction Controllable Sliding Bearings," by M.Q. Feng, S. Fujii and M. Shinozuka, 5/15/92, (PB93-150282).
- NCEER-92-0010 "Seismic Resistance of Slab-Column Connections in Existing Non-Ductile Flat-Plate Buildings," by A.J. Durrani and Y. Du, 5/18/92.

- NCEER-92-0011 "The Hysteretic and Dynamic Behavior of Brick Masonry Walls Upgraded by Ferrocement Coatings Under Cyclic Loading and Strong Simulated Ground Motion," by H. Lee and S.P. Prawl, 5/11/92, to be published.
- NCEER-92-0012 "Study of Wire Rope Systems for Seismic Protection of Equipment in Buildings," by G.F. Demetriades, M.C. Constantinou and A.M. Reinhorn, 5/20/92.
- NCEER-92-0013 "Shape Memory Structural Dampers: Material Properties, Design and Seismic Testing," by P.R. Witting and F.A. Cozzarelli, 5/26/92.
- NCEER-92-0014 "Longitudinal Permanent Ground Deformation Effects on Buried Continuous Pipelines," by M.J. O'Rourke, and C. Nordberg, 6/15/92.
- NCEER-92-0015 "A Simulation Method for Stationary Gaussian Random Functions Based on the Sampling Theorem," by M. Grigoriu and S. Balopoulou, 6/11/92, (PB93-127496).
- NCEER-92-0016 "Gravity-Load-Designed Reinforced Concrete Buildings: Seismic Evaluation of Existing Construction and Detailing Strategies for Improved Seismic Resistance," by G.W. Hoffmann, S.K. Kunnath, A.M. Reinhorn and J.B. Mander, 7/15/92, (PB94-142007, A08, MF-A02).
- NCEER-92-0017 "Observations on Water System and Pipeline Performance in the Limón Area of Costa Rica Due to the April 22, 1991 Earthquake," by M. O'Rourke and D. Ballantyne, 6/30/92, (PB93-126811).
- NCEER-92-0018 "Fourth Edition of Earthquake Education Materials for Grades K-12," Edited by K.E.K. Ross, 8/10/92.
- NCEER-92-0019 "Proceedings from the Fourth Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction," Edited by M. Hamada and T.D. O'Rourke, 8/12/92, (PB93-163939).
- NCEER-92-0020 "Active Bracing System: A Full Scale Implementation of Active Control," by A.M. Reinhorn, T.T. Soong, R.C. Lin, M.A. Riley, Y.P. Wang, S. Aizawa and M. Higashino, 8/14/92, (PB93-127512).
- NCEER-92-0021 "Empirical Analysis of Horizontal Ground Displacement Generated by Liquefaction-Induced Lateral Spreads," by S.F. Bartlett and T.L. Youd, 8/17/92, (PB93-188241).
- NCEER-92-0022 "IDARC Version 3.0: Inelastic Damage Analysis of Reinforced Concrete Structures," by S.K. Kunnath, A.M. Reinhorn and R.F. Lobo, 8/31/92, (PB93-227502, A07, MF-A02).
- NCEER-92-0023 "A Semi-Empirical Analysis of Strong-Motion Peaks in Terms of Seismic Source, Propagation Path and Local Site Conditions, by M. Kamiyama, M.J. O'Rourke and R. Flores-Berrones, 9/9/92, (PB93-150266).
- NCEER-92-0024 "Seismic Behavior of Reinforced Concrete Frame Structures with Nonductile Details, Part I: Summary of Experimental Findings of Full Scale Beam-Column Joint Tests," by A. Beres, R.N. White and P. Gergely, 9/30/92, (PB93-227783, A05, MF-A01).
- NCEER-92-0025 "Experimental Results of Repaired and Retrofitted Beam-Column Joint Tests in Lightly Reinforced Concrete Frame Buildings," by A. Beres, S. El-Borgi, R.N. White and P. Gergely, 10/29/92, (PB93-227791, A05, MF-A01).
- NCEER-92-0026 "A Generalization of Optimal Control Theory: Linear and Nonlinear Structures," by J.N. Yang, Z. Li and S. Vongchavalitkul, 11/2/92, (PB93-188621).
- NCEER-92-0027 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part I - Design and Properties of a One-Third Scale Model Structure," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, (PB94-104502, A08, MF-A02).

- NCEER-92-0028 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part II - Experimental Performance of Subassemblages," by L.E. Aycardi, J.B. Mander and A.M. Reinhorn, 12/1/92, (PB94-104510, A08, MF-A02).
- NCEER-92-0029 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part III - Experimental Performance and Analytical Study of a Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, (PB93-227528, A09, MF-A01).
- NCEER-92-0030 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part I - Experimental Performance of Retrofitted Subassemblages," by D. Choudhuri, J.B. Mander and A.M. Reinhorn, 12/8/92, (PB93-198307, A07, MF-A02).
- NCEER-92-0031 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part II - Experimental Performance and Analytical Study of a Retrofitted Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/8/92, (PB93-198315, A09, MF-A03).
- NCEER-92-0032 "Experimental and Analytical Investigation of Seismic Response of Structures with Supplemental Fluid Viscous Dampers," by M.C. Constantinou and M.D. Symans, 12/21/92, (PB93-191435).
- NCEER-92-0033 "Reconnaissance Report on the Cairo, Egypt Earthquake of October 12, 1992," by M. Khater, 12/23/92, (PB93-188621).
- NCEER-92-0034 "Low-Level Dynamic Characteristics of Four Tall Flat-Plate Buildings in New York City," by H. Gavin, S. Yuan, J. Grossman, E. Pekelis and K. Jacob, 12/28/92, (PB93-188217).
- NCEER-93-0001 "An Experimental Study on the Seismic Performance of Brick-Infilled Steel Frames With and Without Retrofit," by J.B. Mander, B. Nair, K. Wojtkowski and J. Ma, 1/29/93, (PB93-227510, A07, MF-A02).
- NCEER-93-0002 "Social Accounting for Disaster Preparedness and Recovery Planning," by S. Cole, E. Pantoja and V. Razak, 2/22/93, (PB94-142114, A12, MF-A03).
- NCEER-93-0003 "Assessment of 1991 NEHRP Provisions for Nonstructural Components and Recommended Revisions," by T.T. Soong, G. Chen, Z. Wu, R-H. Zhang and M. Grigoriu, 3/1/93, (PB93-188639).
- NCEER-93-0004 "Evaluation of Static and Response Spectrum Analysis Procedures of SEAOC/UBC for Seismic Isolated Structures," by C.W. Winters and M.C. Constantinou, 3/23/93, (PB93-198299).
- NCEER-93-0005 "Earthquakes in the Northeast - Are We Ignoring the Hazard? A Workshop on Earthquake Science and Safety for Educators," edited by K.E.K. Ross, 4/2/93, (PB94-103066, A09, MF-A02).
- NCEER-93-0006 "Inelastic Response of Reinforced Concrete Structures with Viscoelastic Braces," by R.F. Lobo, J.M. Bracci, K.L. Shen, A.M. Reinhorn and T.T. Soong, 4/5/93, (PB93-227486, A05, MF-A02).
- NCEER-93-0007 "Seismic Testing of Installation Methods for Computers and Data Processing Equipment," by K. Kosar, T.T. Soong, K.L. Shen, J.A. HoLung and Y.K. Lin, 4/12/93, (PB93-198299).
- NCEER-93-0008 "Retrofit of Reinforced Concrete Frames Using Added Dampers," by A. Reinhorn, M. Constantinou and C. Li, to be published.
- NCEER-93-0009 "Seismic Behavior and Design Guidelines for Steel Frame Structures with Added Viscoelastic Dampers," by K.C. Chang, M.L. Lai, T.T. Soong, D.S. Hao and Y.C. Yeh, 5/1/93, (PB94-141959, A07, MF-A02).
- NCEER-93-0010 "Seismic Performance of Shear-Critical Reinforced Concrete Bridge Piers," by J.B. Mander, S.M. Waheed, M.T.A. Chaudhary and S.S. Chen, 5/12/93, (PB93-227494, A08, MF-A02).

- NCEER-93-0011 "3D-BASIS-TABS: Computer Program for Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures," by S. Nagarajah, C. Li, A.M. Reinhorn and M.C. Constantinou, 8/2/93, (PB94-141819, A09, MF-A02).
- NCEER-93-0012 "Effects of Hydrocarbon Spills from an Oil Pipeline Break on Ground Water," by O.J. Helweg and H.H.M. Hwang, 8/3/93, (PB94-141942, A06, MF-A02).
- NCEER-93-0013 "Simplified Procedures for Seismic Design of Nonstructural Components and Assessment of Current Code Provisions," by M.P. Singh, L.E. Suarez, E.E. Matheu and G.O. Maldonado, 8/4/93, (PB94-141827, A09, MF-A02).
- NCEER-93-0014 "An Energy Approach to Seismic Analysis and Design of Secondary Systems," by G. Chen and T.T. Soong, 8/6/93, (PB94-142767, A11, MF-A03).
- NCEER-93-0015 "Proceedings from School Sites: Becoming Prepared for Earthquakes - Commemorating the Third Anniversary of the Loma Prieta Earthquake," Edited by F.E. Winslow and K.E.K. Ross, 8/16/93.
- NCEER-93-0016 "Reconnaissance Report of Damage to Historic Monuments in Cairo, Egypt Following the October 12, 1992 Dahshur Earthquake," by D. Sykora, D. Look, G. Croci, E. Karaesmen and E. Karaesmen, 8/19/93, (PB94-142221, A08, MF-A02).
- NCEER-93-0017 "The Island of Guam Earthquake of August 8, 1993," by S.W. Swan and S.K. Harris, 9/30/93, (PB94-141843, A04, MF-A01).
- NCEER-93-0018 "Engineering Aspects of the October 12, 1992 Egyptian Earthquake," by A.W. Elgamal, M. Amer, K. Adalier and A. Abul-Fadl, 10/7/93, (PB94-141983, A05, MF-A01).
- NCEER-93-0019 "Development of an Earthquake Motion Simulator and its Application in Dynamic Centrifuge Testing," by I. Krstelj, Supervised by J.H. Prevost, 10/23/93, (PB94-181773, A-10, MF-A03).
- NCEER-93-0020 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a Friction Pendulum System (FPS)," by M.C. Constantinou, P. Tsopelas, Y-S. Kim and S. Okamoto, 11/1/93, (PB94-142775, A08, MF-A02).
- NCEER-93-0021 "Finite Element Modeling of Elastomeric Seismic Isolation Bearings," by L.J. Billings, Supervised by R. Shepherd, 11/8/93, to be published.
- NCEER-93-0022 "Seismic Vulnerability of Equipment in Critical Facilities: Life-Safety and Operational Consequences," by K. Porter, G.S. Johnson, M.M. Zadeh, C. Scawthorn and S. Eder, 11/24/93, (PB94-181765, A16, MF-A03).
- NCEER-93-0023 "Hokkaido Nansei-oki, Japan Earthquake of July 12, 1993, by P.I. Yanev and C.R. Scawthorn, 12/23/93, (PB94-181500, A07, MF-A01).
- NCEER-94-0001 "An Evaluation of Seismic Serviceability of Water Supply Networks with Application to the San Francisco Auxiliary Water Supply System," by I. Markov, Supervised by M. Grigoriu and T. O'Rourke, 1/21/94.
- NCEER-94-0002 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of Systems Consisting of Sliding Bearings, Rubber Restoring Force Devices and Fluid Dampers," Volumes I and II, by P. Tsopelas, S. Okamoto, M.C. Constantinou, D. Ozaki and S. Fujii, 2/4/94, (PB94-181740, A09, MF-A02 and PB94-181757, A12, MF-A03).
- NCEER-94-0003 "A Markov Model for Local and Global Damage Indices in Seismic Analysis," by S. Rahman and M. Grigoriu, 2/18/94.

- NCEER-94-0004 "Proceedings from the NCEER Workshop on Seismic Response of Masonry Infills," edited by D.P. Abrams, 3/1/94, (PB94-180783, A07, MF-A02).
- NCEER-94-0005 "The Northridge, California Earthquake of January 17, 1994: General Reconnaissance Report," edited by J.D. Goltz, 3/11/94, (PB193943, A10, MF-A03).
- NCEER-94-0006 "Seismic Energy Based Fatigue Damage Analysis of Bridge Columns: Part I - Evaluation of Seismic Capacity," by G.A. Chang and J.B. Mander, 3/14/94, (PB94-219185, A11, MF-A03).
- NCEER-94-0007 "Seismic Isolation of Multi-Story Frame Structures Using Spherical Sliding Isolation Systems," by T.M. Al-Hussaini, V.A. Zayas and M.C. Constantinou, 3/17/94, (PB193745, A09, MF-A02).
- NCEER-94-0008 "The Northridge, California Earthquake of January 17, 1994: Performance of Highway Bridges," edited by I.G. Buckle, 3/24/94, (PB94-193851, A06, MF-A02).
- NCEER-94-0009 "Proceedings of the Third U.S.-Japan Workshop on Earthquake Protective Systems for Bridges," edited by I.G. Buckle and I. Friedland, 3/31/94, (PB94-195815, A99, MF-MF).
- NCEER-94-0010 "3D-BASIS-ME: Computer Program for Nonlinear Dynamic Analysis of Seismically Isolated Single and Multiple Structures and Liquid Storage Tanks," by P.C. Tsopelas, M.C. Constantinou and A.M. Reinhorn, 4/12/94.
- NCEER-94-0011 "The Northridge, California Earthquake of January 17, 1994: Performance of Gas Transmission Pipelines," by T.D. O'Rourke and M.C. Palmer, 5/16/94.
- NCEER-94-0012 "Feasibility Study of Replacement Procedures and Earthquake Performance Related to Gas Transmission Pipelines," by T.D. O'Rourke and M.C. Palmer, 5/25/94, (PB94-206638, A09, MF-A02).
- NCEER-94-0013 "Seismic Energy Based Fatigue Damage Analysis of Bridge Columns: Part II - Evaluation of Seismic Demand," by G.A. Chang and J.B. Mander, 6/1/94, (PB95-18106, A08, MF-A02).
- NCEER-94-0014 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a System Consisting of Sliding Bearings and Fluid Restoring Force/Damping Devices," by P. Tsopelas and M.C. Constantinou, 6/13/94, (PB94-219144, A10, MF-A03).
- NCEER-94-0015 "Generation of Hazard-Consistent Fragility Curves for Seismic Loss Estimation Studies," by H. Hwang and J-R. Huo, 6/14/94, (PB95-181996, A09, MF-A02).
- NCEER-94-0016 "Seismic Study of Building Frames with Added Energy-Absorbing Devices," by W.S. Pong, C.S. Tsai and G.C. Lee, 6/20/94, (PB94-219136, A10, A03).
- NCEER-94-0017 "Sliding Mode Control for Seismic-Excited Linear and Nonlinear Civil Engineering Structures," by J. Yang, J. Wu, A. Agrawal and Z. Li, 6/21/94, (PB95-138483, A06, MF-A02).
- NCEER-94-0018 "3D-BASIS-TABS Version 2.0: Computer Program for Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures," by A.M. Reinhorn, S. Nagarajiah, M.C. Constantinou, P. Tsopelas and R. Li, 6/22/94.
- NCEER-94-0019 "Proceedings of the International Workshop on Civil Infrastructure Systems: Application of Intelligent Systems and Advanced Materials on Bridge Systems," Edited by G.C. Lee and K.C. Chang, 7/18/94.
- NCEER-94-0020 "Study of Seismic Isolation Systems for Computer Floors," by V. Lambrou and M.C. Constantinou, 7/19/94, (PB95-138533, A10, MF-A03).

- NCEER-94-0021 "Proceedings of the U.S.-Italian Workshop on Guidelines for Seismic Evaluation and Rehabilitation of Unreinforced Masonry Buildings," Edited by D.P. Abrams and G.M. Calvi, 7/20/94, (PB95-138749, A13, MF-A03).
- NCEER-94-0022 "NCEER-Taisei Corporation Research Program on Sliding Seismic Isolation Systems for Bridges: Experimental and Analytical Study of a System Consisting of Lubricated PTFE Sliding Bearings and Mild Steel Dampers," by P. Tsopelas and M.C. Constantinou, 7/22/94, (PB95-182184, A08, MF-A02).
- NCEER-94-0023 "Development of Reliability-Based Design Criteria for Buildings Under Seismic Load," by Y.K. Wen, H. Hwang and M. Shinozuka, 8/1/94.
- NCEER-94-0024 "Experimental Verification of Acceleration Feedback Control Strategies for an Active Tendon System," by S.J. Dyke, B.F. Spencer, Jr., P. Quast, M.K. Sain, D.C. Kaspari, Jr. and T.T. Soong, 8/29/94.
- NCEER-94-0025 "Seismic Retrofitting Manual for Highway Bridges," Edited by I.G. Buckle and I.F. Friedland, to be published.
- NCEER-94-0026 "Proceedings from the Fifth U.S.-Japan Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures Against Soil Liquefaction," Edited by T.D. O'Rourke and M. Hamada, 11/7/94.
- NCEER-95-0001 "Experimental and Analytical Investigation of Seismic Retrofit of Structures with Supplemental Damping: Part 1 - Fluid Viscous Damping Devices," by A.M. Reinhorn, C. Li and M.C. Constantinou, 1/3/95.
- NCEER-95-0002 "Experimental and Analytical Study of Low-Cycle Fatigue Behavior of Semi-Rigid Top-And-Seat Angle Connections," by G. Pekcan, J.B. Mander and S.S. Chen, 1/5/95.
- NCEER-95-0003 "NCEER-ATC Joint Study on Fragility of Buildings," by T. Anagnos, C. Rojahn and A.S. Kiremidjian, 1/20/95.
- NCEER-95-0004 "Nonlinear Control Algorithms for Peak Response Reduction," by Z. Wu, T.T. Soong, V. Gattulli and R.C. Lin, 2/16/95.
- NCEER-95-0005 "Pipeline Replacement Feasibility Study: A Methodology for Minimizing Seismic and Corrosion Risks to Underground Natural Gas Pipelines," by R.T. Eguchi, H.A. Seligson and D.G. Honegger, 3/2/95.

